

This document is superseded and
is for information purposes only.

Queensland Electricity Connection Manual

Service and Installation Rules

Effective from 24 August 2018



Part of the Energy Queensland Group

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

Table of Contents

Distributors Contact Details	1
Dial Before You Dig	1
Foreword	3
Purpose and Scope	4
Definitions, Abbreviations and Acronyms	4
References	4
Responsibilities	5
1. Important Information	16
1.1. Use of this document	16
1.2. Scope	16
1.3. Failure to comply with this manual	17
1.4. Exceptional Circumstances	17
1.5. Enquiries	17
1.6. Distributors Contact Details for QECM Correspondence	18
1.7. Historic Buildings and Flora with Vegetation Protection Orders	18
1.8. Revisions and alterations	18
1.9. Drawings	18
2. Customers Installations	20
2.1. Request for Electrical Connection	20
2.2. Request for Initial Connection, Service Alteration, Metering Change or Inverter change	20
2.3. Alterations and Additions	21
2.4. Breaking of Metering Terminal Cover/Metering Isolation Link/Metering Neutral Link Seals	21
2.5. Examination, Test and Connection	22
2.6. Unmetered Supplies	22
2.7. Identification in Multiple Installations	22
2.8. Protective Fault Current Devices	22
2.9. Power Factor	23
2.10. Limitations on Starting Currents of AC Motors	23
2.11. Interference with Supply of Electricity to Other <i>Customers</i>	25
2.12. High Voltage Installations	25
2.13. <i>Customer's</i> Generating Systems	26
2.14. Determination of Maximum Demand	26
2.15. Requirement for Circuit Breakers in Rural/Isolated Areas	26
3. Determination of the Number of Phases to be Installed	28
3.1. General	28
3.2. Urban Areas	28
3.3. Non-Urban Areas	28
4. Balancing of Load and Limitation on Equipment	30
4.1. General	30
4.2. Connection of Equipment - Current Limitations	30
4.3. Equipment Having Fluctuating Loads.	31
4.4. Harmonic Interference or Wave Form Distortion	31
4.5. Rectifiers	32
4.6. Connection of Equipment - Voltage Limitations	32

4.7.	Connection of Equipment - Isolated Generation Localities	32
5.	Service Lines and Connection point	34
5.1.	General	34
5.2.	Connection point	34
5.3.	Service Lines.....	34
5.4.	Overhead Service Lines.....	35
5.5.	Underground Service Lines.....	40
5.6.	Additional Service Lines in Urban Areas.....	42
5.7.	Additional Service Lines in Non-Urban Areas	42
5.8.	Alterations to Service Lines.....	42
5.9.	Consumer's mains on the Distributor's Poles	43
5.10.	Substations on <i>Customer's</i> Premises	43
5.11.	Joints in Consumer's mains	44
6.	Metering Requirements	62
6.1.	General	62
6.2.	Controlled loads	62
6.3.	Metering Isolation.....	62
6.4.	Metering Active and Neutral Requirements	66
6.5.	Metering and Control Equipment - Accommodation	68
6.6.	Metering and Control Equipment - Position	68
6.7.	Metering and Control Equipment - Housing	72
6.8.	Metering and Control Equipment – Spacing Requirements	73
6.9.	Metering and Control Equipment - Mounting	74
6.10.	Metering Locks.....	75
6.11.	Current Transformer Equipment supplied by the Distributor	75
6.12.	Current Transformer Metering – Housing	75
6.13.	Changes to Existing Current Transformer Metering Installations.....	75
	Electrical Contractor's LV CT Metering Check Sheet.....	77
7.	Controlled Supplies - Method of Control	84
7.1.	General	86
7.2.	Network Devices	86
7.3.	Contactor for Control of Non-Continuous Load	87
7.4.	Size of Network Device Wiring.....	87
8.	Arrangements for Embedded Generating Systems Connected to the Distribution Network	98
8.1.	Explanation of Metering Schemes Available.....	98
8.2.	Agreements.....	98
8.3.	Approval of Equipment.....	98
8.4.	Connection Requirements for EG Systems	99
8.5.	Labelling Requirements to AS/NZS 4777.1	99
9.	High Voltage Metering	102
9.1.	General Requirements.....	102
9.2.	Testing Requirements	102
9.3.	Operation of High Voltage Equipment.....	102
9.4.	Maintenance and Repairs of High Voltage Equipment	102
9.5.	Conversion from Low Voltage Supply to High Voltage Supply	102
9.6.	Metering Requirements.....	103
9.7.	Establishing a Network Connection and <i>NMI</i>	103

Queensland Electricity Connection Manual



Part of the Energy Queensland Group

9.8.	Offer of Supply Letter and/or Network Connection Agreement.....	103
9.9.	Connection point	103
9.10.	Revenue Metering	104
9.11.	Meter Enclosure	105
9.12.	Secondary Wiring.....	106
Appendix A - Specification for Metallic Enclosures for Meters in Direct Connected Installations		108
A.1	Scope and General	108
A.2	Design and Construction.....	108
A.3	Dimensions	110
Appendix B - Glossary of Terms		112
Appendix C - Amendment Record		118

DISTRIBUTORS CONTACT DETAILS

Energex

Web Address	www.energex.com.au
CT Metering Order Form	www.energex.com.au/service_providers/electrical_contractors.html
General Customer Service	13 12 53 E-mail request can be sent to custserve@energex.com.au
Loss of Supply	13 62 62
Emergencies	13 19 62
C&I Substation Manual	Available from Technical Documents section of Energex website: www.energex.com.au
Metering Locks	https://www.energex.com.au/home/our-services/meters/energex-locks
EWR (Form 2) Enquiries/Technical Information - QECM enquiries.	1300 762 397

Ergon Energy

Web Address	www.ergon.com.au
EWR (Form A) and CT Metering Order Form	Available from Electrical Contractors section of Ergon Energy website: www.ergon.com.au
General Customer Service	13 74 66 For all areas - New Applications, Point of Attachment Site Visits, Breaking Meter Seals. E-mail requests can be sent to networkenquiries@ergon.com.au or by completing the Contact Form as provided under "Contact Us" on Ergon Energy's Web site: www.ergon.com.au
24 Hour Faults and Emergencies	13 22 96
Metering Locks	1300 323 301 toll free number. Metering Locks can be purchased from API Locksmiths (Queensland Locksmiths) by phone or on-line at www.queenslandlocksmiths.com.au .
Technical Information - QECM enquiries.	1800 237 466 Electrical Contractor Hotline (EC Use only)

DIAL BEFORE YOU DIG



Queensland Electricity Connection Manual

Phone 1100 - free call (except from mobiles) Fax 1300-652-077

Website www.1100.com.au

Dial before you Dig is the national referral service for information on the location of underground infrastructure.

Australia's major service providers have a single web-enabled information service for information on the location of underground communications, gas, water and electricity infrastructure.

The Dial before you Dig online service is available 24 hours a day and enables users to have more control over their enquiry as you detail the dig site on the mapping software yourself.

Use the website to ensure that you 'Dial Before You Dig' before any excavation work.

When calling the 1100 phone number the operator may require the following:

- your name and address
- name of company
- contact telephone number
- fax number for return information
- contact name on site
- site address and both nearest cross streets
- start date of proposed work
- type of work being carried out

Note: Section 68 of the Electrical Safety Regulation 2013 sets out the duties of persons working near overhead and underground electric lines.

FOREWORD

The Queensland Electricity Connection Manual (QECM) has been compiled in conjunction with *Energex* and *Ergon Energy* and is the same jurisdictional document referred to as the Electricity Connection and Metering Manual (ECMM) in the Metrology Procedure: Part A National Electricity Market.

Note: Printed versions of the QECM are “uncontrolled copies” - the latest version is available on the *Energex* website (www.energex.com.au) or *Ergon Energy* website (www.ergon.com.au).

Safety

In all activities undertaken, the safety of our employees, contractors, *customers* and the community is paramount. Safety is our number one value and there is a commitment to ensuring that "safety must come first" to achieve a no injuries workplace. In accordance with legislative requirements we have developed Policies, Standards and Work Practices that our workers are required to follow to ensure the safety of themselves, other workers, *customers* and the community. We trust that electrical contractors and persons in control of sites will appreciate that our workers will not undertake any work in a situation where there are uncontrolled risks inconsistent with our safe systems of work.

Disclaimer

Whilst the QECM contains material relevant to the electricity industry legislation, codes of practice and standards, it is not intended to provide legal advice on how *electrical contractors* can meet their own statutory obligations or comply with legislation, codes of practice or industry standards such as AS/NZS 3000 (Wiring Rules).

The QECM does not provide advice for the purposes of section 68 of the *Electrical Safety Regulation 2013*. The *Electrical Safety Act 2002*, *Electrical Safety Regulation 2013* and associated codes of practice establish requirements for electrical safety and place obligations on employers, self-employed persons and others. These documents may be obtained from the Queensland Government website (www.worksafe.qld.gov.au).

Whilst care has been taken in the preparation of the QECM, the distribution entities do not guarantee that the information contained in the QECM is accurate, complete or up to date at time of publication. To the extent permitted by the relevant legislation the *distributor* will not be responsible for any loss, damage, cost or expense incurred as a result of any error, omission or misrepresentation in relation to the information contained in the QECM.

Copyright

Copyright © 2018 Energex Limited and Ergon Energy Corporation Limited. This publication is copyright. Except as permitted under the Copyright Act 1968 no part of this publication may be reproduced by any process without the specific written permission of the copyright owner.

All rights reserved.

PURPOSE AND SCOPE

The purpose of this manual is to promote industry uniformity through standardisation of practices throughout Queensland. The document is for use by *Electrical Contractors*, Consulting Engineers, Architects, *Metering Providers* and others directly concerned with electrical installations that are connected, or are to be connected, to the respective supply network.

Electrical installation compliance and obligations contained in this manual forms part of the (Queensland) *Electricity Distribution Network Code* and the *National Electricity Rules*.

DEFINITIONS, ABBREVIATIONS AND ACRONYMS

Unless otherwise stated definitions, abbreviations and acronyms used in AS/NZS 3000 (Wiring Rules) and the current Legislation referenced in the *QECM* have the same meaning when used in this document.

Refer to the Glossary of Terms for general definitions.

Note: Words and terms defined in the Glossary are identified within the text by italicising (e.g. *distributor*).

REFERENCES

Referenced Legislation:

Electricity Act 1994 (Qld)

Electricity Regulation 2006 (Qld)

Electricity Distribution Network Code (made under the Electricity Act 1994 (Qld))

Electrical Safety Act 2002 (Qld)

Electrical Safety Regulation 2013 (Qld)

Electrical Safety Code of Practice 2010 – Working near exposed live parts

Queensland Government Gazette – Notified Prices (Tariff Gazette, <http://www.qca.org.au>)

Work Health and Safety Act 2011 (Qld)

National Electricity Rules

Referenced Standards:

AS 1243	Voltage transformers for measurement and protection
AS/NZS 1269.1	Occupational noise management - Measurement and assessment of noise immission and exposure
AS 1284.4	Electricity metering Socket mounting system
AS 1397	Steel sheet and strip - hot dip zinc-coated or aluminium/zinc-coated
AS 1657	Fixed platforms, walkways, stairways and ladders - Design construction and installation
AS 2067	Substations and high voltage installations exceeding 1kV ac
AS/NZS 3000	Wiring Rules
AS/NZS 3012	Electrical installations - Construction and demolition sites
AS 4645.1	Gas distribution networks – Network management
AS/NZS 4777.1	Grid connection of energy systems via inverters - Installation requirements
AS/NZS 4777.2	Grid connection of energy systems via inverters - Inverter requirements
AS 5601	Australian Gas Code
AS 6002	Domestic electricity meter enclosures
AS 60044 series	Instrument transformers

AS/NZS 60079.10.1	Classification of hazardous areas - Examples of area classification - Flammable gases
AS 60269 series	Low-voltage fuses
AS 60529	Degrees of protection provided by enclosures (IP Code)
AS 60974.6	Arc welding equipment - Welding power sources
AS/NZS 61000 Series	Electromagnetic compatibility (EMC)
AS/IEC 62196	Plugs, socket-outlets, vehicle connectors and vehicle inlets – Conductive charging of electric vehicles
EE STNW1170/ EX STD01143	Connection Standard for Micro Embedded Generating Units (0 – ≤30 kVA)
EE STNW1174 EX STD01618	Standard for Connection of Embedded Generating Systems (>30 kW to 1,500 kW) to a Disitributor's LV Network
STNW1175	Standard for Connection of Embedded Generating Systems to a Disitributor's HV Network

RESPONSIBILITIES

The Customer:

- selects an electricity *retailer*;
- where applicable, negotiates or nominates an agent to negotiate provision of the electricity supply with the *distributor*;
- contacts their *retailer* when advised by an *electrical contractor*;
- for initial connections, the *customer* is responsible to ensure trees are cut/trimmed to provide clear access for an overhead service;
- provides a safe working environment for the *electrical contractor*, meter reader, etc;
- ensures the meter enclosure is accessible at all times. If behind a locked gate ensures that the gate is fitted with the *distributor's* metering lock;
- ensures the meter enclosure is clear of vegetation and that the meter reader can read the meter without stepping on, or damaging valuable plants etc;
- ensures that the *connection point* is clear at all times to allow safe access by the *distributor's* personnel;
- notifies the *retailer*, *distributor* and *metering provider* where applicable, when supply is to be permanently disconnected from a *premises* (supply abolishment); and
- contacts the *retailer* prior to any work being done that may impact on the metering installation.

The Relevant Distributor:

- negotiates provision of the electricity supply with the *customer* or the *customer's* agent (generally an *electrical contractor*);
- transports and delivers electricity which is purchased by *retailers* and sold to *customers*;
- examines and tests the *consumer's mains*, main switchboard and main earth of a *customer's* installation before it is initially connected to the *distributor's* electricity network;
- may be the *metering provider*, where the transitional provisions apply
- provides the *Distributor Network Devices*;
- connects the electricity supply to a *customer's* installation up to the load side of the Metering Isolation Links (subject to rectification of any defects) and subject to the *customer* selecting a *retailer*, and the *retailer* requesting the connection;
- is responsible for the reliability and quality of the electricity supply at the *connection point*;
- is responsible for the issue of *NMIs* (refer to local *distributor's* web site for guidelines).

The Metering Provider:

Queensland Electricity Connection Manual

The *metering provider* must be accredited by AEMO and shall comply with the following responsibilities;

- when appointed by the *metering coordinator*, they are to supply, install and maintain the metering equipment on a *customer's* premises in accordance with this QECM,
- to ensure all *customer* energy is metered and to notify by the appropriate notification form to the *distributor* any unmetered circuits identified,
- notify the *distributor* immediately and cease any work if evidence of tampering of metering or control equipment is detected,
- retain or utilise *distributor's* network devices where the *customer* requires controlled tariffs,
- where the distributor is the *metering provider*, comply with *distributor's* requirements for installation, sealing and testing of metering equipment,
- where the *metering provider* is not the *distributor*, notify the *distributor* by the appropriate process prior to conducting any onsite works,
- the *metering provider* shall attach a label to the metering installation detailing the *NMI*, the *metering provider* and *metering provider* contact details,
- ensure that all safety and security requirements are maintained for all types of metering installations,
- inspect and confirm the metering installation is compliant with this QECM and relevant safety requirements, and issue corrective action notices if defects exist.

The Relevant Retailer:

- purchases electricity and sells it to *customers*;
- nominates prices and negotiates contracts where applicable, for the sale of electricity to *customers*;
- where the *distributor* is not the *metering provider*, provides the *distributor* with details of the *metering coordinator* and/or *metering provider*;
- requests the *distributor* to connect, disconnect or alter the *customer's* installation in accordance with the *customer's* contract (*Service Order Request* if applicable).

The Electrical Contractor:

- ensures all electrical work is in accordance with Queensland Legislation, AS/NZS 3000 (Wiring Rules), other relevant Standards and the requirements of the QECM (in particular ensuring that unterminated cables cannot be energised by inserting a fuse or link or by closing a switch or circuit breaker);
- where 'exceptional circumstances' occur, ensures that permission is obtained by submitting a written request to the *distributor* for a variation;
- ensures that the *distributor* is advised when there is a significant increase in the electrical load at an installation;
- advises the *customer* when increases in load require changes to the electrical installation including meter changes;
- must not work on or remove metering equipment unless they are the appointed *metering provider*;
- on completion of electrical work that involves metering or metering alterations, advises the *customer* that they must contact the *retailer* and notify that the work is complete (See note in Clause 2.2);
- issues the *customer* with a certificate of testing and compliance;
- submits appropriate forms in a timely manner and ensures that the information on the forms is accurate (e.g. correct address);
- notifies the *metering provider* of any broken metering seals;
- notifies the *distributor* of any broken *network device* seals; and

- rectifies any departures from this manual that have been identified by the *distributor/metering provider*;

The Electrical Consultant:


- designs the electrical installation in accordance with Queensland Legislation, AS/NZS 3000 (Wiring Rules), other relevant Standards and the requirements of this manual;
- where 'exceptional circumstances' occur, ensures that permission is obtained by submitting a written request to the *distributor* for a variation;
- on large projects liaises with the *distributor* to ensure adequate supply is available when required;
- ensures that the *distributor* is advised when there is a significant increase in the electrical load at an installation;
- advises the *customer* when increases in load require changes to the electrical installation including meter changes.

Stakeholder Interaction Diagrams:


The following diagrams have been included as a guide to assist the users of this manual to understand the process interaction between the *customer*, *electrical contractor*, *retailer*, *distributor* and *metering provider*:

- 1) Initial Connection - *Direct Connected Metering*;
- 2) Initial Connection - *Current Transformer Metering*;
- 3) Electrical Installation Work Involving Metering Changes;
- 4) Service and Metering Change - Additional Phases;
- 5) Service Alteration - No Metering Changes;
- 6) *Micro Embedded Generating (EG) Unit* Connection to the Distribution Network;
- 7) Initial Connection - High Voltage Installation.


1) Initial Connection - Direct Connected Metering




2) Initial Connection - LV Current Transformer Metering




3) Electrical Installation Work Involving Metering Changes




4) Service and Metering Change - Additional Phases




5) Service Alteration - No Metering Changes



6) Micro EG Unit (up to and including 30 kVA) Connection to the Distribution Network



7) Initial Connection - High Voltage Installation



THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

1. IMPORTANT INFORMATION

1.1. Use of this document

This document is to be read in conjunction with the current:

- (a) Australian Standards, in particular AS/NZS 3000 (Wiring Rules).
- (b) Relevant Legislation and respective Regulations and Codes (see References pg 5).
- (c) The *National Electricity Rules*.
- (d) QECM addendums published in relation to specific topics (on and from the date they are published).
- (e) Queensland Electricity Metering Manual (QEMM)

Note: The requirements of the Queensland Electricity Legislation are to be considered in the design, installation, operation and maintenance of the *customer's* electrical installation

This is a self-contained document except where it specifically refers to other related documents and supersedes previous versions of both the *Energex* and *Ergon Energy* Electricity Connection and Metering Manuals.

1.2. Scope

This document provides guidelines for connection of supply, metering and load control arrangements of a *customer's* installation.

Where departures from these guidelines may be necessary, prior consultation with the *distributor* will be required. (Refer to Clause 1.4, Exceptional Circumstances).

Note: If there is any inconsistency between the guidelines provided in the *QECM* and -

- (a) the relevant legislation (i.e. the *Electricity Act 1994*, the *Electrical Safety Act 2002* and their respective Regulations or Codes of Practice), AS/NZS 3000 (Wiring Rules) and the *National Electricity Rules*, or
- (b) the terms contained in a *distributor's* letter of offer to supply, or a connection agreement; then the relevant legislation set out above at clause 1.2 (a), shall prevail in the first instance, followed by Clause 1.2 (b), the terms of a letter of offer to supply or a connection agreement.

1.2.1 Small Customers

The conditions of supply and metering requirements detailed in this document apply for all *customers* who consume less than 100MWh per annum (i.e. a *Small Customer*) and are connected to the *distributor's* electricity network.

1.2.2 Large Market Customers

The conditions of supply and metering for *customers* who are Registered Participants according to *National Electricity Rules*, consume 100MWh or more annually and have an Electricity Sales Contract with a *retailer* are detailed in the *National Electricity Rules* Chapter 5 - Network Connection.

Where specific detail is not covered by the *National Electricity Rules* the requirements of this document apply. Connections for new *large customers* must comply with the *Queensland Electricity Regulation 2006*.

1.2.3 Un-metered Supplies

The conditions of supply for *customers* whose *connection point* is not metered, and are connected to the distribution network, are detailed in this document.

1.2.4 Remote Generated Areas

The conditions of supply and metering requirements detailed in this document apply to all *customers' installations* and are to be read in conjunction with *Ergon Energy*

document PW000202R114 - "Guidelines for Electrical Installations at Isolated Systems." Call *Customer Service* (refer page 1).

1.3. Failure to comply with this manual

Should an installation not satisfy the requirements of these and/or other applicable rules, the connection of electricity supply may be **delayed** or **withheld**, and installations with supply may be **disconnected**, until such time as the non-compliance(s) has been rectified.

1.4. Exceptional Circumstances

In exceptional circumstances the stated requirements contained within the *QECM* may be waived and/or modified by the submission of a written request to the relevant *distributor*. (Refer to Clause 1.6 for contact details).

The request shall include all of the following:

- (a) A detailed statement of the reasons why non-compliance with this manual is sought.
- (b) Full details and diagrams, as necessary, showing the specific aspect of a requested variation to the *QECM*.
- (c) Property location details.

No action or variation should be undertaken until a written approval from the *distributor*, has been received.

Note: Any variation approval will **only apply to the individual property** as listed in the request (i.e. it does not cover, or set any precedent, for any other installation).

1.4.1 Request for an interpretation of the QECM

A request for an interpretation of the *QECM* must be made in writing to the relevant *distributor*. A reply will be provided by the *distributor* within 10 working days from receipt of the written request.

1.4.2 Request for dispensation from the QECM

A request for dispensation from the requirements of the *QECM* must be made in writing to the relevant *distributor*. A reply will be provided within 10 working days from receipt of the written request.

1.4.3 Request for an QECM amendment

A request for an amendment of the *QECM* must be made in writing to the relevant *distributor*. Acknowledgement of receipt of the amendment will be provided within 10 working days from receipt of the written request.

1.5. Enquiries

Unless indicated, enquiries are to be by email or by written communication.

1.5.1 Enquiries before the work commences or while the work is underway.

Contact the phone numbers on page 1 of the *QECM*.

1.5.2 Enquiries regarding defects identified by the *distributor*

Contact the *distributor* advising the following information:

- (a) *Customer* name and address and *NMI* if available;
- (b) Reference number on the *distributor's* document;
- (c) Nature of enquiry;
- (d) *Electrical contractor's* number and return address details (if applicable).

If the installation has not been connected to supply a reply will be provided within 2 working days from receipt of request.

If the installation has been connected to supply a reply will be provided within 5 working days from receipt of request. (Refer to Clause 1.6 for contact details).

1.6. Distributors Contact Details for QECM Correspondence

Contact details for *QECM* amendments or enquiries are:

Energex: Email customerservice@energex.com.au

Write to: Energex Limited QECM Request
GPO Box 1461
BRISBANE Qld 4001

Ergon Energy: Email: networkenquiries@ergon.com.au

Write to: Ergon Energy QECM Request
PO Box 308
ROCKHAMPTON Qld 4700

1.7. Historic Buildings and Flora with Vegetation Protection Orders

The *electrical contractor* should consult the owner if the building appears to have historical significance. Historic buildings may require the requirements of this manual be waived and/or modified for attachment of overhead services, meter positions etc.

Similarly, flora protected by a Vegetation Protection Order may require special arrangements for the erection or alteration of overhead or underground services.

Electrical contractors should contact the *distributor* before starting work (See Exceptional Circumstances above).

1.8. Revisions and alterations

Energex and *Ergon Energy* reserve the right to revise this publication. The current edition of this document is available on the *Energex* website at www.energex.com.au or the *Ergon Energy* website at www.ergon.com.au.

1.9. Drawings

The drawings have been placed in the body of the document after the section to which they are most relevant but may be referred to in more than one section.

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

2. CUSTOMERS INSTALLATIONS

2.1. Request for Electrical Connection

An application for supply must be made to an electricity *retailer* licensed to operate in Queensland.

The *distributor* cannot energise a *customer's* installation unless:

- (a) The *customer* has a retail sales contract; and
- (b) The *retailer* has then requested the *distributor* to connect the *customer* via a *SOR* transaction; and
- (c) An *Electrical Work Request (EWR)* has been submitted.

Where possible, and to hasten completion, the *customer* should provide the *National Metering Identifier* to the *retailer*.

2.1.1 Large Customers

A *large customer* who consumes 100MWh or more per annum and requires an initial connection by the *distributor* must also arrange for the metering to be installed by an accredited *metering provider*. They must also request their initial connection via their chosen *retailer*.

To enable the connection to be completed to schedule, a *customer* will be required to advise the *distributor* of their expected annual consumption.

2.2. Request for Initial Connection, Service Alteration, Metering Change or Inverter change

Electrical Contractors shall submit an *Electrical Work Request (EWR)* when they:

- (a) Require an initial supply at an installation; or
- (b) Require service alterations.

Where alterations to an installation are to be carried out, the *distributor* shall be advised of any of the following situations:

- (a) Where the electricity service may be over or in the vicinity of a swimming pool or hazardous area as defined in AS/NZS 3000 (Wiring Rules);
- (b) Any proposal for new or additions to an existing HV installation (i.e. the *connection point* and or the metering transformer may need upgrading).

For major changes or load increases the *customer*, or their *electrical contractor* or consultant, should contact the *distributor* at the earliest opportunity to obtain an estimate of the time that may be required to modify the network to accommodate the changes or load increases; or

- (c) Complete work that requires additional metering or a change to existing metering when the *distributor* is the *metering provider*; or
- (d) Complete work that requires additional load control equipment or a change to existing load control equipment; or
- (e) Require Micro EG unit Inverter additions, upgrades or replacement.

2.3. Alterations and Additions

The *electrical contractor* shall submit an *Electrical Work Request (EWR)* in adequate time for the modification to the *distributor's* service and or network to be completed before supply is required.

Examples of alterations and/or additions to the *customer* electrical installation that require submission of an EWR may include:

- (a) The installation of additional phase/s;
- (b) The relocation of the *connection point*;
- (c) Any increase in loading that requires an increase in the capacity of the service or distribution network;
- (d) The installation of a service following repair works (e.g. repair works after storm damage).

Note: *Customers* with a *NMI* classification - Large, are to provide the contact details of their *metering provider*.

2.4. Breaking of Metering Terminal Cover/Metering Isolation Link/Metering Neutral Link Seals

In the interests of electrical safety and to ensure the integrity of metering and *network devices* the *metering provider* and/or the *distributor* will seal this equipment.

Approval will be given for the metering terminal cover/metering isolation link/metering neutral link seals only, to be removed by an *electrical contractor* provided notification is given to the *distributor* or the *metering provider* either before the removal of the seals or as soon as practicable after the event.

An *Electrical Work Request (EWR)* must be submitted to the *distributor* as soon as possible after metering alterations are completed.

Within the *Ergon Energy* distribution area, notification of broken seals (for Receiver bridging only) can be done via a phone call to the National Contact Centre.

Where the metering terminal cover has been damaged or alterations to the metering cable entry point allows contact with live parts, the *electrical contractor* shall leave the installation in a safe state (e.g. fill/cover holes with a suitable material) and submit an *EWR* that advises a new metering terminal cover is required. Alterations to metering terminal covers are not permitted.

Note: For remotely read interval meter installations, the *customer* is to provide the contact details of their *metering provider*. The nominated *metering provider* is responsible to ensure the metering installation complies with the requirements of Chapter 7, of the *National Electricity Rules* and this document where applicable.

2.5. Examination, Test and Connection

The *distributor's* electricity connection officer is required to examine and test the *consumer's* *mains* and main switchboard of an installation before the initial connection to supply (up to the load side of the Metering Isolation Link and Metering Neutral Link).

The examination, test, and connection shall **not be regarded as implying compliance** with any specification and the *electrical contractor* remains responsible for the standard of the work, regardless of whether an officer from the *distributor* examines, or tests, the whole or part of the installation.

The re-energisation of an installation after customer requested switching shall **not be regarded as implying compliance** with any specification and the *electrical contractor* remains responsible for the standard of the work, regardless of whether an officer from the *distributor* examines, or tests, the whole or part of the installation.

2.6. Unmetered Supplies

Unmetered supply may be available where the *distributor* considers it impractical to read or maintain metering equipment or where metering equipment would be susceptible to damage. Approval must be obtained from the *distributor* prior to the installation of an *unmetered supply*. Where the *distributor* consents to an *unmetered supply* (e.g. telephone cabinet, bus shelter, traffic signals, etc.) the following general conditions will apply:

- (a) Approval must be gained (as appropriate) from any relevant authority for equipment installed in the road reserve. (Refer to the *Electricity Regulation 2006*);
- (b) The *distributor* must be advised prior to any changes to the loading of the installation;
- (c) Socket outlets are not permitted;
- (d) The installation shall consist of a small steady uniform load. (Refer to Clause 5.9(a) for installation of *consumer's mains* on the *distributor's* pole).

2.7. Identification in Multiple Installations

Each individually metered section of a multiple installation shall be clearly identifiable (e.g. shop, unit or factory number). The number shall be permanently marked on the main switchboard, distribution board (if applicable), meter, isolator and front door of the individual shop/unit so that the *distributor* may install the required connection for the installation. A site plan of the overall layout of the site shall also be permanently displayed on the inside door of the main switchboard.

An electrical test must be carried out to ensure that the meter wiring does supply that particular part of the installation that is identified by the switchboard and unit marking. This is required to confirm the relationship between the national metering identifier (NMI), the meter number/s and the address are correct.

2.8. Protective Fault Current Devices

Protective devices installed by the *customer* shall have an interrupting capacity adequate for the prospective short circuit current at the point of installation.

In the event of the fault current being increased at any point on an installation because of provisions for additional load, the *customer* shall be responsible for the upgrading of all equipment not rated for the prospective fault level.

Prospective fault level details may be obtained by contacting the *distributor*. (Refer to page 1 for contact details).

Notes:

1. The *distributor's* (HRC) low voltage service fuse rated up to 100A will provide suitable fault current limiting for a *customer's* installation. Refer to QEMM for additional meter protection requirements.

2. For low voltage supplies the *distributor's* service fuse shall not be considered as overload protection for the *consumer's* mains.
3. Installation of fault current limiters may be required to protect *direct connected metering* on the *customer's* installation. (Refer to Clause 6.3.1).

Information on high fault currents can be found in the Electrical Safety Office - Code of Practice for Electrical Work and the Electrical Safety Office web site.

2.9. Power Factor

The *distributor* requires a *customer* to ensure that the power factor of any electrical installation measured at the *connection point* under normal load conditions is not less than 0.8 lagging (Refer to TABLE 2.1).

If the power factor falls outside the power factor range specified in TABLE 2.1 at the *connection point*, the *customer* will be responsible for taking action to ensure compliance (as agreed with the *distributor*).

TABLE 2.1 provides the power factor performance standard.

TABLE 2.1

POWER FACTOR PERFORMANCE STANDARD	
Nominal Supply Voltage	Power Factor Range
50kV - 250kV	0.95 lagging to unity
1kV <50kV	0.90 lagging to 0.90 leading
<1kV*	>0.8 lagging but not leading
<p>* <i>Electricity Regulation 2006.</i> At all other voltage ranges the requirements are as specified by the <i>National Electricity Rules</i>, unless detailed in a contract.</p>	

Customers shall ensure that shunt capacitors installed for power factor correction are designed to avoid attenuating the *distributor's* audio-frequency signals used for load control. The *distributor* will supply the details of the audio-frequency signals in any region upon request. *Customers* are also required to meet the harmonic emission limits specified for their installation even under resonant conditions due to their capacitor bank.

2.10. Limitations on Starting Currents of AC Motors

2.10.1 General Requirements

Except as required by Clause 2.10.4 motor installations and any associated starting devices shall be so designed and operated as to comply with either of the following conditions:

Single Phase Motors 230 Volts and 480 Volts

TABLE 2.2

MOTOR VOLTAGE	MOTOR SIZE	ALLOWABLE STARTING CURRENT
230V	All Sizes	$I = 45 \text{ Amps}$
480V	Not exceeding 7.5kW	$I = (17.5 \times k) \text{ Amps}$, where k is the continuous output rating (kW) of the motor.
	Exceeding 7.5kW	Shall not be connected.

Note: The *distributor* must be contacted before motors are installed in SWER areas of supply. (Refer to page 1 for contact details).

Three Phase Motors 400 Volts

TABLE 2.3

MOTOR SIZE	ALLOWABLE STARTING CURRENT
Not exceeding 1.5kW	$I = 26 \text{ Amps}$
Exceeding 1.5kW and up to 3.75kW	$I = (kW \times 17.5) \text{ Amps}$
Exceeding 3.75kW and up to 10kW	$I = (53 + 3.3 \times k) \text{ Amps}$, where k is the continuous rating, (kW) of the largest motor in the installation.
Exceeding 10kW	Contact <i>distributor</i> .

Exception:

1. No limitation may be placed on the starting current of any motor that is not frequently started and the rated output does not exceed 10% of the total motor load connected for a *customer* to the one service.
2. In *premises* which are supplied directly from a substation or in other appropriate supply conditions as determined by the *distributor*, starting currents in excess of those laid down may be permitted provided that written approval is obtained from the *distributor*. (Refer to page 1 for contact details).

Note: Motors should not be started simultaneously and the starting current of the motors should be limited to 2 to 3 times full rated current by fitting with an appropriate starter.

2.10.2 Fall in Voltage

The starting current shall not cause a fall in Voltage of more than 5% of the nominal voltage at the *connection point* for more than 0.02 seconds when connected to a typical 400/230V, 3 phase, 50Hz supply system which for this purpose shall be considered to have the following impedance:

$$Z = 0.2 + j0.2 \text{ ohms (phase - neutral);}$$

$$Z = 0.1 + j0.1 \text{ ohms (line impedance per phase).}$$

2.10.3 Test Methods

- (a) Fall in Voltage shall be measured by instrumentation with a high-speed measurement capability.
- (b) Starting currents shall be measured by instrumentation with a high-speed measurement capability or by the locked rotor method, with the rated voltage and frequency applied to the terminals of the motor.
- (c) In any case where the test methods specified in paragraphs (a) and (b) above cannot conveniently be applied, another test method that conforms to recognised practices in the electrical industry may be used.

Note: The *distributor* will accept test results from a recognised testing laboratory or manufacturer's certified test results.

2.10.4 Special Provisions

For both three phase and single phase motors the *distributor* may require maximum starting currents lower than those set out or may limit the rating of any motor to be connected if such lower starting currents or limits of motor capacity are necessary to prevent interference with supply to other *customers*.

For isolated generation areas within the *Ergon Energy* distribution area, special limitations may be applied on starting currents of electric motors (including air conditioners) and also may require time delay controls on motor starting circuits after a power outage. Any special requirements are outlined in the *Ergon Energy* document PW000202R114 - "Guidelines for Electrical Installations at Isolated Systems" which is available on request by contacting *Ergon Energy* Customer Service. (Refer to page 1 for contact details).

2.11. Interference with Supply of Electricity to Other Customers

Customers shall take reasonable precautions to prevent transformer arc welding machines, motor starting, fluorescent lighting, Micro Embedded Generation and any other equipment from interfering with the satisfactory operation of the *distributor's* network or other *customers* systems etc.

The requirements of AS/NZS 61000 series standards "Electromagnetic Compatibility (EMC)" shall be observed at all times.

The fact that the *distributor* may have connected the apparatus or equipment causing the interference shall not exempt the *customer* from this requirement. Also see Clauses 4.2 to 4.6 of this manual.

Note: *Customers* with an electrical installation or equipment which may be sensitive to voltage variation, transients, loss of one or more phases of supply or due to leakage current are advised to install protective equipment to limit possible damage.

2.12. High Voltage Installations

Any person intending to install high voltage equipment at a *premise* shall consult the *distributor* before taking steps to obtain or install such equipment.

Where the *distributor* agrees, subject to certain conditions, (such as a minimum demand being met), with a *customer's* request for a high voltage connection, the agreed voltage is the standard voltage for the supply. (Refer to the *Electricity Regulation 2006* for standard voltages). The *distributor* will provide a letter of offer or connection agreement outlining these conditions.

The *Electrical Safety Act 2002* requires all new or altered high voltage electrical installations to be inspected by an *Accredited Auditor* before connection to supply. For additional information on *Accredited Auditors* contact the Electrical Safety Office. The auditor should be involved in the project at an early stage.

More information in relation to high voltage installations is included in Chapter 9 of this manual

2.13. Customer's Generating Systems

2.13.1 General

The installation of *customer's* generating systems shall comply with AS/NZS 3000 (Wiring Rules). The *consumer's mains* neutral shall not be switched or broken on the distribution supply side of the MEN connection. The generating system neutral is required to be clearly identified at the main neutral link.

2.13.2 Non-Parallel Operation with *Distributors* Supply

Customer's generating system for emergency supply

This section applies for the installation of generating system on a *customer's premises* to provide a supply of electricity to the *customer's* electrical installation, during an interruption of the supply of electricity.

- (a) The *customer* shall ensure that, when the generating system is operating to give emergency supply, it is installed with effective isolation between—
 - (i) all active conductors of the part of the electrical installation or electrical installations to which the generating system is connected; and
 - (ii) the part of the electrical installation still connected to the supply from the *distributor*.
- (b) The connection of the generating system shall be so arranged that the *metering provider's* revenue meters do not meter the alternate supply and all metering equipment, including CTs are able to be isolated to enable access whilst the generating system is in service (i.e. the changeover switch must be installed on the load side of the meter).

2.13.3 Parallel Operation with *Distributor's* Supply (Co-Generation)

Customer's generating system for interconnection to supply network

- (a) A *customer* shall not install generating plant for interconnection with the *distributor's* supply network without prior agreement.
- (b) The agreement shall include the conditions for securing safe and stable parallel operation of the supply network and the generating system. (refer to section 28 of the *Electricity Regulation 2006*).

Note: Co-generation is allowable from all forms of alternative energy supplies such as solar panel (photovoltaic), wind turbine, diesel generation etc.

Refer to Section 8 for details of the metering schemes for interconnection of *EG systems* connected to the distribution network.

Appropriate revenue metering will be installed in accordance with the negotiated supply arrangements.

2.14. Determination of Maximum Demand

Unless limited by a fixed setting circuit breaker, the determination of the maximum demand of an installation shall be calculated, measured or assessed in accordance with the guidelines given in AS/NZS 3000 (Wiring Rules).

2.15. Requirement for Circuit Breakers in Rural/Isolated Areas

The *distributor* requires circuit breaker/s for main switch/s as part of the *customer's* installation and these circuit breaker/s are required to coordinate with the service fuse/circuit breaker. The *distributor* may require the *customer's* protective device to be changed or altered to provide adequate discrimination. *Electricity Regulation 2006, sections 29 and 30*.

Notes:

1. These regulations refer to the *customer* owned circuit breaker main switch/s provided as part of the *customer's* installation and not to the *customer's* sub-circuit protection or the *distributor's* service fuse/circuit breaker.
2. Refer to Glossary of Terms for definition of *rural/isolated area*.

3. DETERMINATION OF THE NUMBER OF PHASES TO BE INSTALLED

3.1. General

The number of phases provided to supply load at an installation shall be the number required by Section 4 of this manual for individual apparatus or the number determined by this section, whichever is the greater.

Note: The *electrical contractor* or designer should consult with the *customer* to determine future loading requirements. Provision for additional phases or larger *consumer's mains* may be required (e.g. air conditioning load, *Micro EG Unit*, *EVSE*).

3.2. Urban Areas

3.2.1 Single Customer Installations

Other than where multi-phase appliances are installed on the *premises*, if the maximum demand as calculated in accordance with AS/NZS 3000 (Wiring Rules) is:

- (a) not greater than 80A, then supply shall be one phase and neutral;
- (b) between 80 and 140A, then supply shall be two phases and neutral;
- (c) greater than 140A, then supply shall be three phases and neutral.

The *distributor* approves the use of 3 phase underground or overhead supply where 3 phase load (e.g. air conditioner or pump) is connected and the remainder of the installation is balanced across the 3 phases.

3.2.2 Multi Customer Installations

Other than where multi-phase appliances are installed on the *premises* the number of phases shall be determined by the following methods:

- (a) A maximum of two individually metered units may be connected to a single phase supply if the maximum demand calculated in accordance with AS/NZS 3000 (Wiring Rules) does not exceed 70A.
- (b) Where there are more than two individually metered units, the installation shall be arranged for a three phase supply (e.g. three units - one per phase) unless otherwise advised by the *distributor*.

Note: Separate services and meter positions shall be installed for a duplex (two units divided by a common wall) where each portion has a separate (freehold) title. (Refer also to Clause 6.6.3.5 for Community Title Scheme arrangements).

3.3. Non-Urban Areas

In non-urban areas connection of additional phases to the *customer's* electrical installation may be necessary even though not required under the guidelines given in Clause 3.2.

Notes:

1. Where single phase 11kV only is available the maximum demand may be increased up to 100A depending on the capacity of the local transformer and supporting high voltage infrastructure.
2. Load limitations may apply for single wire earth return (SWER) systems.

For electrical installations in these areas *electrical contractors* should consult the *distributor*. (Refer to page 1 for contact details).

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

4. BALANCING OF LOAD AND LIMITATION ON EQUIPMENT

4.1. General

The load of an installation (including all primary and secondary tariff loads), or separately metered portion of an installation supplied by separate *consumer's mains* or submains, shall be so balanced that at the time of maximum demand on such installation or portion of such installation the current in any phase does not exceed the current in any other phase by more than 20A or 20% whichever is the greater (unless otherwise approved in writing by the *distributor*). The principal tariff load (and secondary tariff load where possible) shall be balanced across all supplied phases and the use of controlled or time of use tariffs to balance another tariff across phases will not be accepted.

The *distributor* may apply additional conditions when large loads are connected in rural (non-urban) areas.

4.2. Connection of Equipment - Current Limitations

Equipment (not specified elsewhere in this part, or a lighting installation or a sign) designed to operate at 230V and whose rating is:

- (a) Not greater than 25A will be connected between one phase and neutral.
 - (i) In exceptional circumstances the *distributor* may approve the connection of single phase appliances rated at more than 25A; and
 - (ii) In multiphase electrical installations the equipment may, with the approval of the *distributor*, be connected to more than one phase and neutral provided the load of the installation is to be balanced across the supply phases.
- (b) Greater than 25A, but not greater than 50A, shall be connected between two phases and neutral, except that in multiphase electrical installations the equipment may, with the approval of the *distributor* be connected to more than two phases and neutral.
- (c) Greater than 50A, shall be connected to three phases and neutral.

4.2.1 Domestic Ranges

Urban Areas

Where an individually metered installation includes a cooking range or ranges, a total rating not exceeding 13kW may be connected to one phase and neutral.

If the total rating exceeds 13kW then:

- (a) For one range it shall be connected to at least two phases and neutral; or
- (b) For two or more ranges each range may be connected to one phase and neutral of a multiphase supply.

Non-Urban Areas

Where in accordance with Clause 3.2 an electrical installation is required to be connected to either two phase and neutral, or three phase and neutral, all ranges should be balanced over the number of phases connected.

4.2.2 Commercial Cooking Appliances

Any such appliance, whose total rating at 230V is:

- (a) Not greater than 35A, shall be connected to one phase and neutral; or
- (b) Greater than 35A, shall be connected to a minimum of two phases and neutral.

4.2.3 Water Heaters

(a) Instantaneous water heater systems

I. Residential

The rated current of an instantaneous water heater shall not exceed 40A (total load) for a three phase system or 20A for a single phase system in a residential building, unless otherwise approved in writing by the *distributor*.

II. Commercial/Industrial

The rated current of an instantaneous water heater shall not exceed 40A (total load) for a three phase system or 40A for a single phase system (Energex only) or 20A for a single phase system (Ergon Energy only) in a commercial or industrial building, unless otherwise approved in writing by the *distributor*.

(b) For the suitability of water heaters for controlled or night rate supplies reference should be made to the Network Tariff Guide (available from the distributor's web site) e.g. where the heating unit rating exceeds 1800W, it shall not exceed 13.5W per litre of heat storage volume for heat exchange type water heaters or 15.5W per litre of rated hot water delivery for other storage type water heaters.

4.2.4 Kilns in Domestic Installations

A kiln, which has a total rating not exceeding 30A, shall be connected to one phase and neutral in domestic installations.

A kiln with a total rating exceeding 30A shall be connected to two or more phases and balanced over the number of phases connected to the installation.

4.2.5 Electric Vehicle Supply Equipment

Electric vehicle supply equipment shall be compliant with AS/IEC 62196.

I. Residential

The rated current of the *EVSE* shall not exceed 40A (total load) for a three phase system or 20A for a single phase system in a residential building, unless otherwise approved in writing by the *distributor*.

II. Commercial/Industrial

The rated current of the *EVSE* shall not exceed 40A (total load) for a three phase system or 40A for a single phase system (*Energex* only) or 20A for a single phase system (*Ergon Energy* only) in a commercial or industrial building, unless otherwise approved in writing by the *distributor*.

4.3. Equipment Having Fluctuating Loads.

Examples of equipment having fluctuating loads are: Welding Machines, X-Ray equipment, furnaces etc.

The *distributor* reserves the right to specify the conditions under which an electricity supply will be given for equipment having rapidly fluctuating loads such as welding machines (other than welding machines complying with AS 60974.6, or previous standards superseded by this standard, and marked "Limited Input"), X-ray equipment and furnaces.

No work should be carried out by a *customer* until advice has been received on the terms on which supply will be given. (Refer to Clause 2.11 "Interference with Supply of Electricity to Other Customers").

4.4. Harmonic Interference or Wave Form Distortion

The *distributor* reserves the right to specify the conditions under which an electricity supply will be given for equipment which would cause excessive distortion to the wave form of the supply

system voltage. (e.g. rectifiers, frequency converters, load control devices using thyristors or saturable reactors).

4.5. Rectifiers

Alternating to direct current rectifying equipment shall not be connected to the *distributor's* system unless:

- (a) The rectifier is of the full-wave type; or
- (b) A double-wound transformer is interposed between the rectifier and the supply system; or
- (c) The rectifier is used in conjunction with an electrical measuring instrument or in similar applications where the rectified current does not exceed 100mA.

Note: Further information regarding general limits may be obtained from AS/NZS 61000 series "Electromagnetic Compatibility (EMC)".

Additional limits apply to avoid harmonic interference to the *distributor's* audio frequency load control system. (Refer to Clause 2.9 of this manual).

4.6. Connection of Equipment - Voltage Limitations

All equipment must be able to operate satisfactorily within the voltage limits detailed in the current Queensland Electricity Legislation.

4.7. Connection of Equipment - Isolated Generation Localities

Load restrictions on electric motors, welders, air conditioners and other electrical equipment in excess of 2.4kW may apply in isolated remote generation areas throughout *Ergon Energy*. Call Customer Service (refer page 1) to clarify any restrictions contained in *Ergon Energy* document PW000202R114 - "Guidelines for Electrical Installations at Isolated Systems".

Queensland Electricity Connection Manual



Part of the Energy Queensland Group

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

5. SERVICE LINES AND CONNECTION POINT

5.1. General

Each individual electrical installation (as defined in AS/NZS 3000 (Wiring Rules)) shall have a separate and individual connection to the supply network (i.e. Separate *connection point* - *service line*, *point of attachment*, *consumer's mains* etc).

Note: The *distributor* will not accept any "Joint Use" arrangements where two or more *customers* share the same property pole and/or property line and/or overhead service (e.g. small lot subdivisions).

5.2. Connection point

Unless otherwise determined or approved by the *distributor*, the *connection point* shall be located as detailed in Clauses 5.2.1 and 5.2.2.

5.2.1 Low Voltage

The *connection point* shall be located -

- (a) at the termination of the overhead *service line* onto a building or structure where the *service line* is installed without the use of property poles (i.e. typically the first span of *service line* to the first structure); or
- (b) on the first property pole (termination pole) from the point of origin of the *service line* where supply is connected by means of a property line.

Unless otherwise approved by the *distributor*, the termination pole shall not be located more than 20m from the property boundary. Where the *service line* does not cross a property boundary the first property pole shall not be located more than 20m from the origin of the *service line*.

In the case where the *service line* crosses a road reserve and extends into private property, the total length of the *service line* from the *distributor's* supply pole to the first property pole shall not exceed 50m; or

Note: To comply with this requirement, the distance that the first property pole is located within the property may need to be reduced so that the 50m limit of the *service line* is not exceeded (in special situations the service length may be increased at the discretion of the *distributor*).

- (c) in a service pillar or pit at the *customer's* property boundary in underground residential distribution areas and non - CBD commercial and industrial areas; or
- (d) at the termination of the underground *service line* on the *customer's premises*. This arrangement is generally restricted to the CBD; or
- (e) at the low voltage terminals of a distribution transformer installed at the *customer's premises* or at the load terminals of any switch or circuit protective device that may be installed by the *distributor* at such transformer. (Refer to Clause 5.10 "Substations on Customer's Premises").

5.2.2 High Voltage

The *connection point* shall be as agreed by the *distributor* and another *Registered Participant*, *Non-registered customer* or *Franchise Customer* and documented in the connection agreement.

5.3. Service Lines

5.3.1 Working on or near the Distributor's Assets

It is the responsibility of the *electrical contractor* to obtain permission to work on or near the *distributor's* assets. (Refer to *Electricity Act 1994*) Examples where authorisation is required include, work on or near the *point of attachment*, accessing standard

underground pillars or work at the low voltage end of a distribution transformer. Information on the requirements for becoming an authorised person can be obtained from the *distributor's* call centre. (Refer to page 1 for contact details).

5.3.2 General

Unless otherwise advised, the *distributor* will provide either an overhead *service line* or an underground *connection point* (typically an underground service pillar). For further details on each *service line* type refer to Clauses 5.4 and 5.5.

For *service lines* in general:

- (a) A charge may be made by the *distributor* for the installation and removal of a temporary *service line*.
- (b) A charge may be made by the *distributor* for any additional *service line* or additional phases for hobby or other purposes.
- (c) Where a *customer* requests that a type of *service line*, other than that proposed by the *distributor*, be installed and the *distributor* agrees to install such type of *service line*, the *customer* shall be required to pay additional costs in line with the Connection policy.
- (d) Where a *customer* requests that an existing *service line* be altered, and the *distributor* agrees to make such alteration, the *customer* shall be required to pay all costs.
- (e) Where the *customer* requests an alternate point of origin for a *service line*, a capital contribution may be required for any extension of the *distributor's* mains.
- (f) The *customer* shall ensure sufficient clear unobstructed access to, around, and below the *point of attachment* and *connection point* to allow the *distributor* to safely maintain the service. Note requirements of Clause 5.4 below.
- (g) The *customer* via their *electrical contractor* is required to provide the means of connection for either an underground or overhead connection, e.g. a *suitable mains connection box* or suitably sized enclosure with insulating shrouds to suit, complete with 12mm stainless steel bolts, nuts, washers and spring washers. The *electrical contractor* shall lug the conductors. Where aluminium cable is used for underground *consumer's mains*, cable ends are required to be terminated with suitable bi-metallic connectors, for connection to fuses and neutral link.

5.4. Overhead Service Lines

The *distributor* shall determine the point of origin, the route, the *point of attachment* and the facilities required for the attachment and connection of the *service line*. NOTE: This may include provision of a *customer* property pole as a suitable point of attachment, (Refer to Clause 5.4.2 for requirements). A direct line service is always the preferred option i.e. direct from the appropriate network distribution pole to the *customer's* first *point of attachment*. The *customer* or their *electrical contractor* shall consult the *distributor* prior to planning the installation. (Refer to service clearance details in Drawings QECM 5.1 and 5.2).

The *distributor* will not erect or connect a *service line* that crosses an adjacent property or premises.

Only a person authorised by the *distributor*, shall install and connect an overhead *service line* to the *customer's* installation.

The *distributor* shall determine the type of overhead *service line* and shall supply, install and maintain the *service line* at its own cost (the *service line* will be installed from the *distributor's* works to the *connection point*), except that:

- (a) Where the service is a Standard Control Service and the distributor has agreed to an overhead service line in excess of 20m (either low or high voltage) the customer may be charged for all costs of the length of service line in excess of 20m. This distance is measured from the point where it crosses the customer's property alignment, or where such service line does not cross the property alignment, in excess of 20m from the point of origin of the service line. The contribution to be made by the customer is to be calculated in line with the Connection policy.
- (b) All poles or other structures on the *customer's premises* for the attachment of an overhead *service line* and overhead *consumer's mains* shall be provided and maintained by the *customer*.
- (c) The *distributor* will not erect an overhead *service line* at any height over a hazardous area or pool zone as defined in AS/NZS 3000 (Wiring Rules). (Refer to Drawing QECM 6.4)
- (d) A *customer* shall provide suitable facilities on their *premises*, acceptable to the *distributor* for the attachment and connection of a *service line*. This may require the *customer* to install a property pole.
- (e) A *customer* must ensure that the route for a new overhead *service line* is cleared of trees and other flora that may contact the line and that the line clearances remain unaffected by subsequent works on the *premises*. (e.g. building alterations, land fill, driveways, trafficable areas, changes in landscape etc).
- (f) Overhead conductors after the *connection point* are the responsibility of the *customer*.
- (g) Flying fox services are at the discretion of the *distributor* and prior written approval is mandatory.

Prior approval for a flying fox service arrangement is essential; the *distributor* will not approve any flying fox arrangement without prior consultation.

Additional costs associated with the flying fox service connection (refer 5.3.2 (c) and (d)) will be payable in full prior to connection.

Note: Details of overhead services line clearances are shown in Drawings QECM 5.1 and 5.2.

5.4.1 Cross Road Service Poles

The *distributor* shall only install cross road service poles:

- (a) Where required to maintain statutory clearances across the roadway; and
- (b) Where no property pole would be required if the *distributor's* mains poles were erected on the same side of the road as the property (consultation with the *distributor* required).

5.4.2 Property Poles

- (a) Precautions must be taken to prevent both internal and external corrosion in steel property poles. Due to the difficulties of assessing the extent of internal corrosion of steel in ground poles a rag bolt assembly is mandatory where a steel pole is used for the first property pole. Refer to Drawings QECM 5.3, 5.5 and 5.6 for a 1.0kN SWL design or 5.4, 5.7 and 5.8 for a 3.5kN SWL design. Note that these drawings have prior *RPEQ* certification and if this design is used exactly as detailed in the drawings then additional *RPEQ* certification is not required. If ANY

modification is made to this design (including simple welding of attachments) then *RPEQ* certification is required for that modification hence *electrical contractors* should not be making on-site modifications without

obtaining *RPEQ* sign off. Similarly pole manufacturers should not change the design of the drawings without obtaining *RPEQ* sign off. These drawings are not mandatory but provided as an example of an approved design. *Electrical contractors* can use other designs but must have *RPEQ* certification and provide a copy of the *RPEQ* certificate with the pole for approval by the *distributor* connection officer prior to connecting supply.

For Builder's Temporary Supply (BTS), where a steel reusable pole is used, refer to Drawings QECM 5.9, 5.10 and 5.11 for details of an approved design. The connection of the overhead *service line* can be facilitated with the use of a mains connection box suitable for copper conductors.

The *point of attachment* is to be mounted within 600mm from the top of the pole (however this distance can be increased to ensure the point of attachment is no higher than 8m from the ground) and the *connection point* is to be as per Clause 5.4.5 (a).

- (b) Timber property poles are to be suitably treated and have a minimum SWL rating of 5kN (as indicated on the pole disc). Other types of timber property poles are acceptable provided they meet the requirements of AS/NZS 3000 (Wiring Rules) Appendix D.

Within the *Ergon Energy* distribution area it is required that all *customer* property poles be a minimum of 5.0m out of the ground.

- (c) Other types of property poles are acceptable that have an *RPEQ* certificate and are rated fit for use i.e. (1kN, 3.5kN or 7kN) and must also comply with Clause 5.4.6.
- (d) Private equipment can be installed on a property pole. The private equipment must not be located above the *service line*, shall be at least 1.2m below the *point of attachment* (does not include *consumer's mains/sub mains*) and must be in a position that does not limit access to the *point of attachment*.

5.4.3 Overhead Service Line Attachments

- (a) Standard service cables used are XLPE insulated aluminium in sizes 25mm², 35mm² (*Energex* only), 50mm² (*Ergon Energy* only) and 95mm². Paralleling of 25mm², 35mm² (*Energex* only) and 50mm² (*Ergon Energy* Only) is not allowed for residential connections. Paralleling of 95mm² is allowed for a commercial/industrial connection but is not the preferred arrangement. The preferred arrangement is 240mm² Al 4 core underground cables with a Commercial & Industrial pillar as the connection point. A 6mm² copper *service line* may be used for small *unmetered supplies* such as telephone cabinets etc.
- (b) The following safe working loads (SWL) apply:
 - (i) Attachments for 25mm² and 35mm² (*Energex* only) overhead *service lines* shall have a load rating of 1kN working load. (Refer to Drawing QECM 5.12).
 - (ii) 50mm² (*Ergon Energy* only) and 95mm² services shall have a load rating of 3.5kN working load and parallel (twin) 95mm² overhead *service lines* (refer above condition) shall have a load rating of 7kN working load. Safe working loads shall be determined by applying a factor of 2 to failing loads.

For overhead *service lines* requiring a 3.5kN design for the eye bolt, raiser bracket or service pole, (other than hardwood timber which requires 5kN), the *customer* must provide certification from a suitably qualified person (i.e. an *RPEQ*) that the structure is suitable for the application. (Refer to Drawing QECM 5.15).

- (c) The method of attachment of an overhead *service line* to a structure shall be such that mechanical load is transmitted to the frame of the structure. Details of approved attachment details for 1kN and 3.5kN service attachments are contained in Drawings QECM 5.12; 5.13; 5.14 and 5.15.
- (d) 'J' Hooks are not permitted on fascias or poles. For 1kN services a minimum M12 open eye screw or eye bolt is acceptable. For other services up to 3.5kN a minimum M16 eye bolt is required
- (e) Where any electric line or electrical article of a *customer's* electrical installation is to be supported by any structure, other than a wooden or steel pole conforming to the requirements of AS/NZS 3000 (Wiring Rules), the *customer* must provide certification from a suitably qualified person (i.e. an *RPEQ*) that the structure is suitable for the application.
- (f) The maximum height of the *point of attachment* of any overhead *service line* on a *customer's premises* shall not exceed 8m above ground or floor level and shall have ready and safe access by ladder. This maximum height may only be exceeded in special situations where the *distributor* has approved the arrangement, and given this approval in writing.
- (g) Where raiser brackets or eyebolts are used, the design and installation is to make provision for work to be carried out safely. (Refer to the Workplace Health and Safety Legislation).
- (h) The *point of attachment* must not be positioned such that the *distributor's* personnel need to climb on roofs or enter swimming pool areas. (Refer to Drawing QECM 6.4).

5.4.4 Raiser Brackets

Proprietary raiser brackets (not exceeding 1.2m in height), certified by an *RPEQ*, tested to a suitable SWL (e.g. 1kN or 3.5kN minimum rating for raiser brackets), and approved by *Energex* or *Ergon Energy* are deemed suitable.

Notes:

1. Within the *Ergon Energy* distribution area, the maximum size overhead *service line* that will be erected to 1kN rated brackets is 3 phase 25mm². (Refer to Clause 5.4.3(a) for 3.5kN bracket requirements).
2. Refer to Drawing QECM 5.12 for examples of acceptable service raiser bracket designs i.e. brackets that display an SWL and are fitted with a means of attachment that will retain the service in high wind conditions (e.g. a pigtail or closed loop).
3. Where timber is used as an anchorage for 1kN raiser brackets and eye bolts it is to be a minimum of 100mm X 75mm and securely fastened to or part of the building structural frame. (A bracket mounted on a fascia without suitable bracing to the structural frame is not considered to be an effective method).
4. Through roof mounted service raiser brackets shall be positioned no further than 0.5m back from the edge of the roof or guttering.
5. All service raiser brackets shall be positioned so that any backstay attached to the roof is in line with the direction of the service pull +/- 20 degrees.

6. Where an approved side pull type service raiser bracket is installed, and the angle of the *service line* from the *point of attachment* to the *connection point* exceeds 60 degrees or is greater than that recommended by the manufacture, a service raiser bracket designed for this application shall be installed. The height of this bracket shall not exceed 1.2m.

5.4.5 Connection point Overhead Service Lines

- (a) The *connection point* shall be no more than 600mm from the *point of attachment*.
- (b) The *point of attachment* and the *connection point* are to be positioned on the building or structure where the *distributor's* personnel have unobstructed ready and safe access from the same common ladder position. That is, it must be positioned where personnel do not climb on roofs, enter adjoining properties, or carry ladders through structures, and or buildings for access.
- (c) Clear level and safe access to the *point of attachment* shall be maintained by the *customer* to allow the *distributor* to maintain the service. A clear level area below the *point of attachment* that allows a ladder ratio of 4:1 vertical to horizontal is deemed suitable.
- (d) The *customer* shall, at their expense, relocate the *point of attachment* to an acceptable position complying with Section 5 when the existing *point of attachment* is located in an unsuitable location and:
 - Electrical work is performed at an existing installation resulting in a major alteration as per clause 6.6.5 or;
 - Building works are carried out at premises that results in the requirements of clause 5.4.5 (b) or (c) not being satisfied.

5.4.6 Connection Arrangements at Connection point

- (a) A *suitable mains connection box*, complete with house service connectors, shall be provided by the *customer* for the connection of overhead *service lines* to *consumer's mains*.
- (b) *Suitable mains connection boxes* shall be mounted to provide adequate support by brackets or similar and not be reliant on rigid conduit for support. (Refer to Drawings QECM 5.13; 5.14 and 5.15).
- (c) If *consumer's mains* are replaced or upgraded on an existing installation, a *suitable mains connection box* or an insulated enclosure shall be installed to the same standard as for a new service.
- (d) Where an overhead *service line* is to be connected to overhead *consumer's mains*, clamps suitable for this application shall be provided. This does not apply where parallel overhead *service lines* or parallel *consumer's mains* are installed.
- (e) Where the conductors of either the *service line* or *consumer's mains* are of a size not suitable for a *mains connection box*, the method of connection shall be such that the *consumer's mains* are terminated with cable lugs within a UV resistant insulated enclosure. (Refer to Note 1 below and to Drawings QECM 5.13, 5.14 and 5.15). The *customer* (via their *electrical contractor*) is required to provide an approved UV resistant insulated enclosure and crimp lugs complete with shroud, 12mm stainless steel bolts, nuts, washers and spring washers fitted onto the *consumer's mains*.

Exception: The requirement for a *suitable mains connection box* or UV enclosure is waived where the *distributor's service line* is terminated onto aerial overhead *consumer's mains*.

TABLE 5.1 below gives the suitable sizes of UV resistant insulated enclosures:

TABLE 5.1

UV RESISTANT INSULATED ENCLOSURE	
Service Type	PVC Enclosure Size
Single 35 or 50mm ² LV ABC service	360mm X 270mm X 205mm *
Single & Parallel (Twin) 95mm ² LV ABC service	540mm X 360mm X 220mm

* Certain manufacturers utilise a spacer to achieve 220mm depth.

Notes:

1. *Suitable mains connection boxes* are available for conductors up to 95mm². Where double insulated sheathed cables are used for the *consumer's mains*, the sheathing must be removed in accordance with the manufacturer's instructions before termination into the IPC connector.
2. Refer to Clause 6.5 for phase identification requirements.
3. It is recommended that these enclosures be mounted vertically with entry of *consumer's mains* positioned low, through the bottom of the enclosure.
4. For a builder's temporary supply (BTS), that utilises a reusable steel pole, the connection of the overhead *service line* can be facilitated with the use of a suitable mains connection box. Refer to Drawings QECM 5.9; 5.10 and 5.11 for details of steel BTS poles design. All BTS must be metered.

5.5. Underground Service Lines

The *distributor* shall determine the point of origin, the route and the *point of entry* of the *service line*. The *customer* or *electrical contractor* shall consult the *distributor* prior to planning the installation.

For underground *service lines*:

- (a) Where supply is by either a low voltage or a high voltage underground *service line*, the *customer* shall be charged all costs for the length of *service line* in excess of 7m from the point -
 - (i) where it crosses the *customer's* property alignment; or,
 - (ii) where such a *service line* does not cross the property alignment in excess of 7m from the point of origin of the *service line*, except as provided for in Clause 5.2.1(c).
- (b) Where required by the *distributor* for commercial or industrial installations, *customers* shall provide suitable facilities on their *premises* for the entrance, support, protection and termination of an underground *service line*. (Refer to the *Energex Commercial and Industrial Substation Manual* for details or the *Ergon Energy Indoor Distribution Substation Design Standard*).

5.5.1 Underground Pit Systems

In areas where an underground pit system has been installed (e.g. In the *Energex* distribution area at Northlakes, Inala and Runaway Bay and at various locations in the *Ergon Energy* distribution area) special requirements apply to the installation/upgrade of the *consumer mains*. (Contact the relevant *distributor* for details).

5.5.2 Underground Services in Overhead Areas

Pillars should not be installed in areas subject to regular/frequent flooding (up to 1 in 10 years). This will be defined by Local Government flood maps where available or based upon previous flood events.

Where a *customer* in an overhead service area requests the installation of an underground service, and the *distributor* agrees to the request, supply shall be taken from a service pillar or pit installed on the footpath in line with the side property boundary. This service pillar or pit will be available to provide future underground supply to the adjoining property if required. Full recovery of costs for the additional assets will apply. A typical arrangement for an underground LV service pillar is shown in FIGURE 5.1.

5.5.3 Underground Service Pillars

It is the responsibility of the *electrical contractor* to install the *consumer's mains* and conduit into the service pillar for termination by the *distributor's* personnel. (Refer to Clause 5.3.1 for access details). FIGURE 5.1 shows a typical LV service pillar arrangement.


Ergon Energy Distribution Area

In Ergon Energy a 40mm Lead In (service) conduit is provided for the Electrical Contractor to use for the installation of consumer mains. Each Lead In conduit exits the pillar at a 45 degree angle, is installed 600mm deep and is identifiable with Orange Caution Tape tied to the end of the conduit extending to ground level for ease of location. A 25mm reducer is provided on each Lead In conduit. The reducer can be removed and replaced as necessary. Consumer mains shall only be installed via the Lead In (service) conduits provided. Alternative installation of mains to the pillar without the use of the conduits supplied can result in the pillar being undermined and de-stabilised and can result in damage to the supply cables.

The route of the *consumer's mains* is to be identified in accordance with AS/NZS 3000 (Wiring Rules).

Note: To prevent damage to the *distributors* service fuse, the conduit shall not protrude past the pillar base and shall be positioned to the rear of the fuse panel. The minimum length of the *consumer's mains* shall be sufficient to reach the top of the fuse panel +300mm.

FIGURE 5.1



Note: Refer to Clause 6.12.1 for meter enclosure mounting requirements.

5.6. Additional Service Lines in Urban Areas

The *distributor* shall install only one *service line* to supply one building or group of buildings occupied by one *customer* on one property.

Exception: Where two or more *customers* occupy one property, supply by more than one *service line* shall be at the discretion of the *distributor*.

Where the *distributor* agrees to install an additional *service line*, the *customer* may be required to pay all costs of the second *service line*.

5.7. Additional Service Lines in Non-Urban Areas

In non-urban areas, more than one *service line* may be provided to a *customer* provided that:

- The second *service line* is a considerable distance (e.g. more than 200m) from the first *service line* measured along the *customer's* property alignment and the load to be supplied is a considerable distance (e.g. more than 100m) from any building supplied by the first *service line*;
- In the opinion, and at the discretion of the *distributor*, it is more practical to supply the load on the property through more than one *service line*.

Where the *distributor* agrees to install an additional *service line*, the *customer* may be required to pay all costs of the second *service line*.

5.8. Alterations to Service Lines

Any alteration to a *service line* shall only be made by a person authorised by the *distributor*. The *customer* may be required to pay all costs of a *service line* alteration, unless the alteration is required for the *distributor's* purposes.

Before commencing building alterations or the erection of structures in proximity to *service lines*, the *customer* or *customer's* representative shall contact the *distributor* to ensure electrical safety is not compromised. (Refer to page 1 for contact details).

5.9. Consumer's mains on the Distributor's Poles

In general, *consumer's mains* shall not be installed on the *distributor's* poles. However, approval at the discretion of the *distributor* may be given under the conditions set out in part (a) and (b) below:

(a) Unmetered Installations

Unmetered installations are generally owned by a telecommunications company, public body (or affiliated operator) or other companies (approved by a public body) and installed on public land. (Refer to Clause 2.6).

When the installation does not meet the requirements of an *unmetered supply* (e.g. council public parks) it will be treated as a metered installation.

In no case shall the maximum demand of these installations exceed the rating of a standard overhead service (i.e. 100A per phase). This arrangement generally applies only to Rate 3 Public Lighting where a standard charge per light applies.

Where the above has been satisfied, approval may be granted for the public body (or affiliated operator) or other companies (approved by a public body) to install the *consumer's mains* on poles designated by the *distributor*.

Note: Specific requirements apply (particular poles types are unsuitable). The *customer* must contact the *distributor* for details and approval.

(b) Metered Installations:

In all cases this arrangement is totally at the discretion of the *distributor* and the following criteria must be satisfied:

- (i) The supply network is within the boundaries of the *customer's* property; and
- (ii) The installation actual demand is above 400A (i.e. in excess of a standard overhead service arrangement); or
- (iii) The electrical installation is owned by a Public Body or other companies (approved by a public body) and complies with the following -
 - the installation is for the use of the general public; and
 - the installation is installed on public land; and
 - the public body or other companies (approved by a public body) is able to demonstrate that there is a community benefit in not installing a property pole (e.g. supply to parkland etc.); and
 - the *distributor's* network is within a reasonable distance from the *connection point* (i.e. not more than 20m); and
 - the network is on the same side of the road as the installation; and
 - the installation maximum demand is not greater than 100A per phase.

Note: Special conditions apply for all the above and approval, as well as the details of the requirements, must be obtained from the *distributor* prior to the commencement of any design or installation work. The *customer* shall meet all associated costs.

5.10. Substations on Customer's Premises

Where the aggregate maximum demand exceeds or is reasonably estimated to exceed 100kVA as determined by AS/NZS 3000 (Wiring Rules), the *distributor* may require a *customer* to provide free of charge the space necessary for a substation in accordance with the *Electricity Regulation 2006*.

5.10.1 Consumer's Mains Connections to Transformer Terminals

Where *consumer's mains* originate at the terminals of a transformer, they shall be adequately supported and shall be connected to the transformer terminals by flexible braid connectors and adaptor plates.

The *electrical contractor* is responsible for the supply and installation of the low *voltage support stand/terminal cover, flexible braid connectors, adaptor plates and consumer's mains*, plus any equipment required by the *distributor's* Commercial and Industrial Substation Manual. (Refer to page 1 for details).

5.10.2 Multiple Transformers

Where multiple transformers supply a single switchboard each transformer must be connected to a separate bus section, however, a bus-tie switching arrangement is permitted provided:

- (a) The bus-tie switches are fitted with fail safe interlocking devices to prevent paralleling of the supplies; and
- (b) If the bus-tie switches are a type that cannot be operated under load, fitted with a warning label to indicate the operating requirements; and
- (c) Be installed and identified in accordance with AS/NZS 3000 (Wiring Rules).

In general, where the *distributor* agrees to provide more than one connection point to an installation, the *customer* must ensure that the supplies cannot be connected in parallel.

5.10.3 Buried Earthing Systems

Provision of a high voltage substation requires the installation of buried earthing systems. These earthing systems are generally installed within 5m of the substation, however in some cases additional earthing cables may be required. These additional earthing cables would generally be located under the line and may extend some distance away from the substation. For safety reasons, it is important that building foundations, *customers'* low voltage earths or other metallic structures be located a distance of at least 5m or more away from the high voltage earthing system. The *distributor* will provide advice on the location of the earthing system for specific installations if required.


5.11. Joints in Consumer's mains

Joints in un-metered *consumer's mains* are permitted provided they comply with AS/NZS 3000 (Wiring Rules) and are not vulnerable to tampering by re-instating insulation to equivalent of an unbroken cable.


THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

OVERHEAD SERVICE CLEARANCES

USE IN CONJUNCTION WITH SERVICE CLEARANCES TABLE ON DRAWING QECM 5.2



MAXIMUM OF 500mm




NO CLEARANCE LIMITS IN VICINITY
OF ATTACHMENT POINTS (NOTE 2)

* Applies from where a person is LIKELY to stand as determined by site risk assess

For the purpose of service clearance determination, a person is considered LIKELY TO STAND ON:

- a part of a structure that is strong enough to support a person's weight; and,
- a surrounding wall or handrail where the wall or handrail is at least 200mm wide.



Revision:

OVERHEAD SERVICE CLEARANCES

QECM - 5.1

SERVICE CLEARANCE TABLE

Neutral Screened and Insulated Cables

CODE	LOCATION	DIRECTION	INSULATED SERVICE CABLE
MINIMUM CLEARANCE FROM GROUND ROADS			
A	At centre-line of the carriageway	VERTICALLY	5.5m
B	At kerb line (bottom of kerb)	VERTICALLY	4.9m
C	At fence alignment	VERTICALLY	3.7m

OTHER THAN ROADS

D	Private driveways and areas including elevated areas used by vehicles	VERTICALLY	4.5m
E	Areas not normally used by vehicles	VERTICALLY	2.7m
F	Road cuttings, embankments and other similar places.	HORIZONTALLY	1.5m

MINIMUM CLEARANCE FROM STRUCTURES AND BUILDINGS

G	Unroofed terraces, balconies, sun-decks, paved areas, and similar areas that are subject to pedestrian traffic only, that have a hand rail or wall surrounding the area and on which a person is likely to stand (Note 2) must be-	VERTICALLY ABOVE VERTICALLY BELOW HORIZONTALLY (Note 1)	2.4m 1.2m 0.9m
J	Roofs or similar structures not used for traffic or resort but on which a person is likely to stand, and for parapets surrounding roofs or similar structures not used for traffic or resort but on which a person is likely to stand (Note 2) must be-	VERTICALLY HORIZONTALLY (Note 1)	0.5m 0.2m
L	Covered places of traffic or resort including for example windows which are capable of being opened, roofed open verandahs and covered balconies must be (Note 6)	IN ANY DIRECTION	1.2m
M	Blank walls, windows which cannot be opened (Note 2) must be-	HORIZONTALLY	0.2m
N	Other structures not normally accessible to persons (Note 2) must be-	IN ANY DIRECTION	1.2m


NOTES :


1. Either the vertical clearance or the horizontal clearance stated must be maintained. Also, in the zone outside the vertical alignment of the building or structure, either the horizontal clearance from the vertical alignment, or vertical clearance above the horizontal level on which a person is likely to stand must be maintained.
2. Stated clearances apply to a service line not attached to the part of the building described.
3. The clearance stated does not apply to the part of the low voltage overhead service line not under tension. Drip loops are excluded however, consideration should be given to drip loop positioning. (Note: Point of supply is to be not more than 600mm from the point of attachment - POA).
4. Where there is no formed footpath, the kerb line means:
 - (a) the kerb line of a proposed footpath, or
 - (b) where no footpath is proposed, the edge of the existing carriageway or of any proposed widening thereof.
 - (c) where there is a formed footpath with kerb & channel, the kerb line means to the bottom of the channel.
5. In situations where the eye screw of a consumer's installation is not provided with an earth tag and is in close proximity to metalwork, (eg the metalwork of a fascia) the eye screw shall be bonded to the earth tail of the house service neutral connector.
6. Where a window sill is determined as not being a place a person is likely to stand (eg. hopper windows, security screened windows and sliding windows), a clearance of 2.4m vertically from floor or 1.2m horizontally shall apply
7. For this table a conductor is taken to be insulated if it is insulated in accordance with AS/NZS 5000.1 (Electric cables - Polymeric insulated - For working voltage up to and including 0.6 / 1kV) or AS/NZS 3560.1 (Electric cables - Cross-linked polyethylene insulated - Aerial bundled - For working voltages up to and including 0.6 / 1 (1.2) kV). Otherwise, it is taken to be uninsulated.


Revision:
A

**SERVICE CABLE CLEARANCES
FROM GROUND & STRUCTURES**

QECM - 5.2









QECM - 5.5

CUSTOMER SERVICE POLE (1.0 kN SWL) - STEEL
POLE FABRICATION DETAILS

Revision: A





Revision: **A**


**CUSTOMER SERVICE POLE - (3.5KN SWL) STEEL
FOUNDATION CONSTRUCTION DETAILS**


QECM - 5.8

CONSTRUCTION DETAILS

REINFORCEMENT FABRICATION

FABRICATION, CONSTRUCTION ON SITE AND ALL ELECTRICAL SERVICES / INSTALLATIONS ESTABLISHED ON THE POLE ARE TO COMPLY STRICTLY WITH AS/NZS 3000 INCLUDING ALL THE CURRENT AMENDMENTS THERE IN.





MATERIAL LIST			
Item	Description	No. Off	Description
①	Pole	1	80 N.B. x 4.0 Thk. x 6500Lg. Std. Galv. Pipe
②	Cap or Disc	1	To suit 80N.B. Pipe
③	Service Attachment Ring	1	M16 Eyebolt
④	Mains connection Box Baseplate	1	FL 75 x 300 Lg. Bent 90° as shown on drawing
⑤	Mains Connection Box	1	3 terminal clipsal Cat. No. IP23
⑥	Threaded PVC Bush	1	To suit MCB
⑦	Screw (Drill & tap item-4 to suit MCB)	2	M5 x 12Lg. S/S Grade 304
⑧	Ladder Support Bracket	1	Taper-flange Channel
⑨	Ladder Support Member	1	L 25x25x6x500Lg
⑩	Ladder Stops	2	L 25x6x125Lg
⑪	Strut Attachment Lug	3	FL 75 x 10 x 75Lg.
⑫	Strut Members	3	25N.B. x 3150Lg. Std. Galv. Pipe
⑬	Meter Box Supports	2	FL 50 x 6 x 400Lg.
⑭	Earthing Lug	1	FL 50 x 6 x 50Lg.
⑮	Stabilising fin	1	FL 50 x 6 x 1450Lg.
⑯	Peg	3	L38 x 38 x 6 x 900Lg. (See Detail 3)
⑰	Striking Plate	3	FL 50 x 10 x 50 Lg.
⑱	Bolt & Nut	6	M12 x 40 Lg. Hex. Galv.

SPECIFICATIONS

RATING : This structure has been designed based on the following loads:
Applied tip load - 1.0 kN.

TOLERANCE : All tolerances to be ±5.0

MATERIAL : Structural steel in accordance with AS 4100.

MATERIAL : Structural Steel in Accordance with AS 1204 Grade 250. See material list for details.

FABRICATION : (a) Holes to be drilled or punched undersize & reamed.
(b) Welding to be in accordance with AS 1554.1
(c) All sharp edges and burrs to be removed.

PROTECTIVE COAT : All steelwork to be effectively corrosion protected.

MARKING : SWL 1 kN

NOTES:

1. FOR CONSTRUCTION AND DETAILS REFER QECMM 5.10

2. NB = NOMINAL BORE


Revision: A	TEMPORARY SERVICE POLE (1.0 kN SWL) FABRICATION AND CONSTRUCTION DETAILS	QECM - 5.11
-----------------------	---	-------------

<div><div><div><div><div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></</div></div></div></div></div></div>	
---	--

CUSTOMER TO PROVIDE THE MEANS FOR ATTACHMENT AND CONNECTION OF THE SERVICE TO THE CUSTOMER'S INSTALLATION		
<p>REFER QECM 5.12 FOR SERVICE ATTACHMENT DETAIL. PROVIDED BY CUSTOMER.</p> <p>TERMINATION CLAMP PROVIDED BY DISTRIBUTOR</p> <p>SERVICE</p> <p>FASCIA</p> <p>MCB WITH SERVICE CONNECTORS. PROVIDED BY CUSTOMER.</p> <p>BOND CONNECTION (IF REQUIRED TO BE EQUIVALENT SIZE OF SERVICE MAINS) PROVIDED BY DISTRIBUTOR</p> <p>THREE PHASE SERVICE ARRANGEMENT SHOWN</p> <p>25/35 mm² LVABC SERVICE CONNECTION WOOD OR METAL FASCIA</p>	<p>TERMINATION CLAMP PROVIDED BY DISTRIBUTOR</p> <p>SERVICE</p> <p>MCB WITH SERVICE CONNECTORS. PROVIDED BY CUSTOMER.</p> <p>STAYWIRE PROVIDED BY CUSTOMER</p> <p>BOND CONNECTION (IF REQUIRED TO BE EQUIVALENT SIZE OF SERVICE MAINS) PROVIDED BY DISTRIBUTOR</p> <p>RAISER BRACKET (SWL 1kN) PROVIDED BY CUSTOMER</p> <p>THREE PHASE SERVICE ARRANGEMENT SHOWN</p> <p>25/35 mm² LVABC SERVICE CONNECTION GALVANISED STEEL RAISER BRACKET</p>	
<p>M12 SERVICE ATTACHMENT. OPEN EYE SCREW HOOK, OPEN EYEBOLT (THREADED), OR CLOSED EYEBOLT (THREADED). PROVIDED BY CUSTOMER.</p> <p>TERMINATION CLAMP PROVIDED BY DISTRIBUTOR</p> <p>SERVICE</p> <p>WOOD POLE</p> <p>CUSTOMER MAINS</p> <p>THREE PHASE SERVICE ARRANGEMENT SHOWN</p> <p>25/35 mm² LVABC SERVICE CONNECTION CUSTOMER'S WOOD POLE</p>	<p>BOND CONNECTION (IF REQUIRED TO BE EQUIVALENT SIZE OF SERVICE MAINS) PROVIDED BY DISTRIBUTOR</p> <p>CONDUCTIVE POLE</p> <p>M12 SERVICE ATTACHMENT. OPEN EYE SCREW HOOK, OPEN EYEBOLT (THREADED), OR CLOSED EYEBOLT (THREADED). PROVIDED BY CUSTOMER.</p> <p>TERMINATION CLAMP PROVIDED BY DISTRIBUTOR</p> <p>SERVICE</p> <p>CUSTOMER MAINS</p> <p>THREE PHASE SERVICE ARRANGEMENT SHOWN</p> <p>25/35 mm² LVABC SERVICE CONNECTION CUSTOMER'S CONDUCTIVE POLE</p>	
<p>NOTES</p> <p>1. TO PREVENT CORROSION COPPER CONDUCTORS SHALL NOT BE DIRECTLY CONNECTED TO GALVANISED SURFACES.</p> <p>2. CUSTOMER TO SUPPLY AND INSTALL APPROVED MAINS CONNECTION BOX OR NON-METALLIC UV STABILISED WEATHERPROOF ENCLOSURE. (REFER TO CLAUSE 5.4.6(e) SEE DETAIL FOR MIN SIZE.</p>		
Revision: A	CUSTOMER'S OVERHEAD SERVICE ATTACHMENTS 1.0kN SWL CONNECTION AND BRIDGING DETAIL	QECM - 5.13


CUSTOMER TO PROVIDE THE MEANS FOR ATTACHMENT AND CONNECTION OF THE SERVICE TO THE CUSTOMER'S INSTALLATION

UP TO 200 AMP




SEE NOTES

TYPICAL LVABC TO SINGLE CONSUMERS MAINS CONNECTION DETAIL



LVABC CONNECTION TO SINGLE CONSUMERS MAINS

200/400 AMP




SEE NOTES

TYPICAL LVABC TO PARALLEL SERVICES MAINS CONNECTION DETAIL

NOTES

1. CUSTOMER TO SUPPLY AND INSTALL APPROVED MAINS CONNECTION BOX OR NON-METALLIC UV STABILISED WEATHERPROOF ENCLOSURE AND SUITABLE LUGS. (REFER TO CLAUSE 5.4.6(e). SEE DETAIL FOR MIN SIZE)
2. CUSTOMER TO SUPPLY LUGS TO SUIT CURRENT RATING OF CABLE AND SHALL ACCOMMODATE A 12MM S/S BOLT. CUSTOMER TO SUPPLY LUG DIES WHERE REQUIRED. CONSUMERS MAINS TO ENTER THROUGH BOTTOM OF ENCLOSURE.
3. ALTERNATE CONNECTIONS METHOD USE APPROPRIATE COPPER BUS BAR.
4. COVER WITH INSULATING SHROUD AND SECURE WITH ZIP TIE.
5. THE BONDING OF EXPOSED METALWORK (EYEBOLT) MUST USE A CONDUCTOR SIZE THE SAME AS THE LVABC NEUTRAL.
6. IPC'S MUST BE USED TO CONNECT ALL EARTHING CONDUCTORS TO LVABC NEUTRAL.



LVABC CONNECTION TO PARALLEL CONSUMERS MAINS


Revision:

A


**CUSTOMER'S OVERHEAD SERVICE ATTACHMENTS
CONNECTION AND BRIDGING DETAIL FOR SINGLE AND PARALLEL
LVABC SERVICES FOR C & I INSTALLATIONS (MAX 400 A)**

QECM - 5.14


ERGON ENERGY ONLY




50/95mm² LV ABC SERVICE CONNECTION
WOOD OR METAL FASCIA - 3.5kN SWL



50/95mm² LV ABC SERVICE CONNECTION
GALVANISED STEEL RISER BRACKET - 3.5kN SWL



50/95mm² LV ABC SERVICE CONNECTION
CUSTOMER'S WOOD POLE



50/95mm² LV ABC SERVICE CONNECTION
CUSTOMER'S CONDUCTIVE POLE

Revision:
A

**MAINS CONNECTION BOX WITH SERVICE CONNECTORS
50/95 mm² LVABC SERVICE - 3.5kN SWL ATTACHMENTS**

QECM - 5.15

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

6. METERING REQUIREMENTS

6.1. General

Metering installations are to comply with this document (QECM) and the Queensland Electricity Metering Manual (QEMM)

Where a *customer* directs a *retailer* to request metering or tariff changes, any alterations to the *customer's* switchboard installation or meter enclosure shall be the *customer's* responsibility (e.g. removal of asbestos contaminated waste) (Refer to Clause 6.7).

Network devices deemed to be necessary to control electricity consumption shall be supplied and maintained by the *distributor* and shall remain their property. All meter and *network device* active terminals shall be connected directly to the Metering Isolation Link or Metering Active Link for direct connected installations.

All phases of a service line are required to be connected at the initial connection of the premises.

All metering and control equipment shall be back-wired and mounted on a side hinged panel attached to a metering enclosure or a switchboard frame.

Customer's ancillary equipment such as surge diverters, voltmeters, phase failure relays etc. shall be connected on the load side of the revenue metering equipment. *Customer* owned current transformers for energy management are permitted on the line side of revenue metering equipment at multiple tenancy installations.

6.2. Controlled loads

Where *controlled loads* are required (Controlled Supply/Night Rate tariffs), provision for a separate *network device* shall be made (Refer to Drawing QECM 6.1 for cable access drilling details). The *network device* will only be installed when the *customer* has requested *controlled load* as part of the EWR for the installation.

Section 7 contains more detail on requirements for connection of controlled loads

6.3. Metering Isolation

To facilitate the requirements of the *Electrical Safety Act 2002 and Electrical Safety Regulation 2013* for performing electrical work, and the *Electricity Act 1994 and Electricity Regulation 2006*, supply to the revenue metering equipment for each *customer* is to be capable of being individually isolated.

All metering shall be connected with suitable active isolation devices connected to the line side of the metering to allow safe access to the metering equipment.

6.3.1 Isolation of Direct Connected Metering

Direct connected metering shall be installed on the line side of the individual installation's main switches.

6.3.1.1 Single Installations

A metering isolation link per phase shall be connected to the line side of the metering. This arrangement maintains supply to electronic meters. (Refer to Clause 6.3.2 and Drawing QECM 6.2).

Exception:

Where overload protection for the *consumer's mains*, in accordance with AS/NZS 3000 (Wiring Rules), cannot be achieved by the positioning of the installation's circuit breaker main switches on the load side of the metering the following shall apply:

A metering isolation D curve circuit breaker connected on the line side of the metering, and sized for overload protection of the *consumer's mains*, shall be installed on the front of the meter panel in place of the metering isolation link. The circuit breaker shall be enclosed in a sealable non-metallic enclosure with a clear cover to allow the *customer* to determine if the circuit breaker is in the open or closed position without removing the cover and shall comply with rating limitations as per the QEMM.

Notes:

1. Enclosures that are lockable only are not acceptable.
2. The *distributor's* service fuse shall not be considered as overload protection (refer to Clause 2.8).
3. Where metering isolation circuit breakers are used in a three phase installation, all three phases must have circuit breakers. If individual CBs are used they must comply with Clause 6.3.2.

If the marking on the circuit breaker is not legible when the cover is in place, the open and closed positions are to be identified by additional marking on the enclosure.

A permanent indelible label shall be fixed on or adjacent to the circuit breaker enclosure stating the following:

Metering isolation circuit breaker
Contact an Electrical Contractor if off.

6.3.1.2 Multiple Installations

A lockable load-break isolator (with facility for locking off) that is capable of isolating supply to the entire electrical installation shall be installed for all multiple *customer* installations including multiple *customers* fed from remote metering points. Where a circuit breaker main switch is installed for overload protection of the *consumer's mains* in accordance with AS/NZS 3000 (Wiring Rules), it shall be lockable, connected on the line side of the metering and can be used in place of the building isolator (Refer to Drawings QECM 6.3-1 and 6.3-2).

Metering isolation links are required for individual *customers*. (Refer to Clause 6.3.2).

6.3.1.3 Metering Isolation - Existing Installations

When minor work is being carried out at an existing installation (including a like for like meter change, *network device* change or connection of additional circuits) it will not be necessary to alter the wiring of the meter to before the main switch. (Refer to the notes below).

This change need only be made where there is a major alteration to the metering or switchboard (for example where the switchboard is replaced, when replacing single phase meters with a polyphase meter or connection of additional phase/s). This will include the addition of metering isolation link/s (Refer to Clause 6.3.1.1).

All meters at the one meter location must follow the same sequence (i.e. be either all "before" or all "after" the main switch/s or any lockable isolator).

Exceptions:

1. Where *direct connected* meters are installed to facilitate a *customer* requested supply/tariff change, additional tariffs (e.g. controlled supply tariff) or installation of an *Micro EG Unit* on an existing single *customer* installation, they shall be

connected on the line side of the individual installation's switchgear and provision for isolation is required in accordance with Clause 6.3.1.1.

2. On existing multi-tenancy installations where the individual tenancy main switch is connected on the line side of the meters, a new meter shall be connected on the line side of the individual tenancy main switch. A means of isolation in accordance with Clause 6.3.1.1 must be provided to allow isolation of the meter without interrupting supply to other *customers*.
3. On existing single phase multi-tenancy installations utilising plug-in meters, the need to fit isolation link/s is not required in situations where a replacement plug-in meter is to be used. These include a single phase tenancy with a *Micro Embedded Generating (EG) Unit* or a tenancy with Time of Use metering (TOU)

Notes for Clause 6.6.1.3:

1. Where the *distributor's* service fuse is greater than 80A, fault current limiting devices (supplied and installed by the *customer*) complying with AS/NZS 3000 (Wiring Rules), are required to protect any *direct connected meters*. Fault current limiting devices shall be installed as per AS/NZS3000. (Refer to Drawings QECM 6.3-1 and 6.3-2).
2. Standard practice in multiple tenancy *direct connected metering* installations, where the service fuse protection is greater than 100A, is to install a 80A fuse in the metering isolation link in place of the solid link. Where fuses are installed, the *metering provider* will provide the fuse and place a label on the panel adjacent to the metering isolation links stating: "WARNING - The metering isolation links have been fused for protection of *metering provider* Equipment".
3. Where the *metering provider* determines that the meter requires an 80A fuse for adequate overload/fault protection, *metering providers* can install an 80A fuse in the metering isolation link provided the Maximum Demand of the installation does not exceed 80A. Should a 100A supply be required, the *metering provider* shall ensure the meter used is suitably rated for, and protected by, the 100A service fuse. All other requirements of Notes 1 and 2 above remain applicable.

6.3.2 Metering Isolation Links/CBs

Metering isolation links/CBs shall be installed in accordance with the following:

- (a) Metering isolation links shall be clear cased type that comply with AS 60269, sealable, back wired, fitted with a tubular link and installed on the line side of all *direct connected metering* equipment; and
- (b) All metering isolation links/CBs on a metering panel shall be connected in the same line - load sequence; and
- (c) The metering isolation links shall be mounted horizontally or vertically on the front of the metering panel and if not obvious, clearly labelled to indicate the meter and portion of the installation that they control. Clearance around the ends of metering isolation links shall be 40mm; and
- (d) The load through a metering isolation link/CB shall not exceed 125A. In multiple supply applications (e.g. general and *controlled supplies*), where the load exceeds 125A,

additional metering isolation links/CBs shall be required. Where a fuse is used to replace the solid link (Refer to Clause 6.3.1.3) the maximum load through the metering isolation link shall not exceed the rating of the fuse; and

- (e) On multiple installations metering isolation links/CBs shall be provided for each *network device* and installed on or adjacent to the relevant meter/metering equipment; and

- (f) For *customers* with three phase supply the metering isolation links/CBs are to be grouped together and if not obvious, permanent labelling must be applied to the meter panel to show the meter(s) and installation that they control.

Within the Energex distribution area where metering isolation links are fitted on an existing meter panel with surface wiring a front wired metering isolation link suitable for this purpose is acceptable.

Aluminium cables are not suitable for connection directly into Metering Isolation Link terminals unless fitted with a suitable means of termination, such as a soft-form bi-metallic sleeve or ferrule that is compatible with the Metering Isolation Link terminal metal.

Where cables of these types are used as *consumers mains*, they shall comply with the requirements of the electrical component/cable manufacturers and AS/NZS 3000, particularly in regard to termination and bending.

6.3.3 Isolation of Current Transformer Metering

Current Transformer metering shall be capable of being individually isolated by a suitable isolator or main switch. All isolation equipment shall be clearly identified and readily accessible and shall be installed and maintained by the *customer*.

Where *direct connected metering* is installed at the same switchboard as *current transformer* metering, the *direct connected metering* is to comply with Clause 6.3.1.

(a) Specific Single Customer Current Transformer Metered Installations

Specific single customer *current transformer metered* installations include installations where:

- (i) Supply to the installation is interrupted for extended continuous periods of time (>2 days) e.g. irrigation pumps, flood lifters, grain silos etc. (i.e. where the main switch is used to control the installation and leave the electronic meter without supply so that it cannot be read); or
- (ii) "Safety Services" are installed and require supply to be maintained.

Note: AS/NZS 3000 (Wiring Rules) permits lockable isolators for installations supplying "Safety Services".

In these specific single *customer current transformer metered* installations the *customer* shall install a lockable load-break isolator (with facility for locking on and off) on the line side of the *current transformer metering* chamber with the main switch(s) installed on the load side. In these specific installations, the isolator may be locked in the on position. (Refer to Drawing QECM 6.3-2).

Where the metering current transformers are installed remote from the main switchboard, the isolator shall be marked "Metering Isolator".

(b) Other Single Customer Current Transformer Metered Installations

This includes all other single *customer current transformer metered* installations where supply to the meter will not be interrupted for extended continuous periods of time.

The preferred arrangement is to connect all single *customer current transformer metered* installations as per (a) above, however, in the interests of reducing costs to the *customer*, a main switch used as the lockable isolator installed on the line side of the *current transformer metering* is permitted provided isolation of customer outgoing

circuits is still provided on the same switchboard as the CTs. The main switch shall be capable of being locked in the off position. (Refer to Drawing QECM6.3-2).

(c) Multiple Customer Current Transformer Metered Installations

(i) Isolation of entire installation (Building Isolator).

A lockable load-break isolator (with facility for locking off) that is capable of isolating supply to the entire electrical installation is required.

Note: A charge will be made where the *distributor* is required to isolate supply.

(ii) Isolation of individual customers.

A lockable load-break isolator (with facility for locking off) shall be installed on the line side of each set of revenue metering current transformers with the *customer's* main switch(s) installed on the load side located on the same switchboard as the CTs. (Refer to Drawings QECM 6.3-1 and 6.3-2).

6.4. Metering Active and Neutral Requirements

6.4.1 Connection of Metering Neutral Conductors to Main Neutral

The metering neutral shall be connected to the main neutral in such a manner that it cannot be disconnected or removed, e.g.

- (a) Soldered or crimped to the main neutral;
- (b) A flag lug under the main neutral connection. Slotted lugs shall not be used;
- (c) A sealable terminal or bolt on the neutral link/bar where -
 - (i) the *consumer's mains* are a busway or busbar arrangement;
 - (iii) the installation main switchboard is supplied by more than one *connection point* and a bus-tie arrangement is in place (the *consumer's mains* neutrals shall be connected to a common neutral link/bar);
- (d) Where the main neutral conductor is 25 mm² or larger a sealable terminal may be used;
- (e) Under a stud fitted with a suitable nut that is drilled and tapped into the *consumer's mains* neutral lug, provided the arrangement can be sealed.

Note: In domestic installations where parallel *consumer's mains* are used the metering neutral conductor shall be soldered to one conductor only.

6.4.2 Accessibility of Neutral Connections

The metering neutral connection is to be readily accessible and shall not be located behind a panel where access requires isolation of supply.

On heavy current switchboards (Refer to AS/NZS 3000 (Wiring Rules)) the main neutral and MEN connections to the busbar shall be located in an accessible position with a minimum of 600mm clearance from exposed live parts. If a minimum clearance of 600mm cannot be achieved, the use of a permanent barrier or location within a chamber separate from that of the main switch or other exposed live parts is acceptable.

The arrangement must allow the main neutral and MEN connections to be safely accessed without isolating the supply to the switchboard or moving other cables. (Refer to AS/NZS 3000 (Wiring Rules)).

The use of shrouds over cable connections is not a sufficient barrier as the shrouds need to be removed during polarity testing (unless access to conductors is provided via test probe holes without the need to remove the shrouds).

6.4.3 Metering Neutral Links

The metering neutral shall be connected to a dedicated terminal of a metering neutral link.

All meter and *network device* neutral terminals shall be connected to a dedicated terminal of the metering neutral link via a separate neutral conductor.

Soldered meter and *network device* neutral connections are not permitted.

Existing installations

Where *direct connected* meters are installed to facilitate a *customer* requested supply/tariff change, additional tariffs (e.g. controlled supply tariff) or installation of an *Micro EG Unit* on an existing single *customer* installation, a metering neutral link shall be installed and connected as per the requirements of Clause 64.3.

6.4.4 Metering Active and Neutral Link Construction

Metering active and neutral links shall -

- (a) incorporate a separate connecting device for the incoming and each outgoing circuit; and
- (b) consist of tunnel terminals using either of methods (i); (ii) or (iii) for termination of the conductors.
 - (i) Two screws shall be provided for each terminal; or
 - (ii) One screw, the outside diameter of which is not less than 80% of the tunnel diameter; or
 - (iii) One screw, which is arranged so that the conductor is clamped by suitable ferrules or plates in direct contact with the conductor.

Where metering active or neutral links are used, they must be sealable or, where this facility does not exist (for larger sized *consumer's mains*), the links must be installed within a suitable dedicated enclosure fitted with a sealable cover.

6.4.5 Metering Active and Neutral Link Mounting

Metering active and neutral links shall be mounted on the rear of the meter panel or meter enclosure.

Where metering active and neutral links are mounted on the rear of the meter panel, they shall be mounted in such a way that they do not interfere with the mounting of the metering equipment.

To not interfere with metering equipment (normally mounted on the upper or middle section of the meter panel) it is preferable for the metering active and neutral links to be mounted as close as practical to the bottom of the meter panel.

Where metering active and neutral links are mounted on the rear of the meter enclosure and the material on which they are mounted is conductive, they shall be mounted on insulating material with low water absorption properties that will extend past the live parts of the link by a minimum of 25mm in all directions. This mounting arrangement is not required where the link has been specifically designed and type tested for installation onto metal surfaces.

Access to metering links must not be obstructed by any structure or wiring within the switchboard.

6.4.6 Metering Active and Neutral Link Labelling

A permanent label is required on the front of the meter panel to indicate the location of the metering active and neutral links.

Metering active and neutral links shall be identified as such and marked to identify which meter is fed from each outgoing circuit of the metering link. Labelling must be legible and durable in accordance with AS/NZS 3000.

6.5. Metering and Control Equipment - Accommodation

The *customer* shall provide and maintain at their expense, suitable space, housing, mounting and connecting facilities to accommodate meters and control equipment for each supply arrangement (e.g. general and *controlled supplies*).

Unless otherwise specified and agreed with the *distributor*, the minimum space requirements for *high voltage metering* panels shall be as specified in Section 9.

6.6. Metering and Control Equipment - Position

6.6.1 General

Meters and control equipment shall be positioned so that they are not subjected to mechanical damage, vibration, high temperature or other environmental situations that might affect their correct operation (e.g. exposure to direct sunlight). Where security of a meter enclosure is necessary, a metering lock must be purchased to allow access. (Refer to Clause 6.10).

The *customer* shall provide safe and ready access so that meters and control equipment may be fixed, read, tested, adjusted and removed without difficulty at any reasonable time but generally between the hours of 8.00am to 5.00pm Monday to Friday. The minimum access requirements for a meter enclosure shall be as per the requirements for switchboards as detailed in AS/NZS 3000 (Wiring Rules).

Unless otherwise approved by the *distributor*, or as varied by Clause 6.6.3, all meters and control equipment supplied for any one installation (as defined in the National Electricity Rules) shall be located in one readily accessible position, preferably on an outside wall at the front of the building.

Current transformer meters should be installed towards the front of the building on a readily accessible outside wall.

Direct connect meters shall be positioned in the same location as the Main switch and MEN point to allow required testing to be undertaken by the *distributor*.

Note: Where a property or building is of a type that may be subdivided, the meters and wiring should be located in an area that would be set aside as *common property* or within each individual lot.

6.6.2 Domestic Properties

On domestic *premises* a meter position suitable to the *distributor* shall satisfy the following criteria:

- (a) Unless otherwise approved in writing by the *distributor*, meters shall be erected on the side of the *premises* facing a street from which there is pedestrian access or within the first 2 m along an adjacent side of the *premises*. (Refer to Drawing QECM 6.4).
- (b) Meters shall not be located behind any fence in an urban area, other than the perimeter fence located at the extremities of the property boundary.

Where access to meters is through locked gates in the perimeter fence, the *distributor's* metering lock purchased from an authorised locksmith must be installed. The lock must be accessible from outside the gate. (Refer to Clause 6.10).

Note: Key/security card boxes or dual locking bars are acceptable.

- (c) On domestic rural or *urban* properties greater than half a hectare, the metering equipment shall be situated in a readily accessible position in accordance with (a) and or (d) of this clause.
- (d) For acreage and farm properties the metering equipment shall be accessible by motor vehicles.

Note: The preferred meter position is at the main residence, central meter position or at the front property boundary.

6.6.3 Unmetered Submains

6.6.3.1 Unmetered Submains - General

Details of the proposed meter positions, *unmetered* submains and their circuit protective devices shall be submitted to the *distributor* for approval before their installation.

Exception: Approval is not required where the *unmetered* submains comply with Clauses 6.6.3.3 to 6.6.3.5.

Voltage drop on *unmetered* submains shall not exceed 2.5% of the supply voltage (voltage drop calculations must be included with the submission). (Refer to page 1 for contact details).

6.6.3.2 Meter Positions – Multiple Metering Points

Installations with multiple metering points as detailed in Clauses 6.6.3.3 and 6.6.3.4 are to have community metering (where required) located on the main switchboard.

6.6.3.3 High Rise Buildings

For buildings up to four floors, a single meter position on common property on the ground floor is approved.

For high rise buildings in excess of four floors, one meter position on every floor is approved.

6.6.3.4 Shopping Centres

For shopping centres, other than high rise buildings complying with Clause 6.6.3.3 above, an additional metering point for every twelve *customers* will be permitted.

6.6.3.5 Community (Strata) Title and Cluster Developments

For reticulation in community title or cluster developments that is not owned by the *distributor*, in general the *distributor* will provide one *connection point* to the installation. Unless otherwise approved by the *distributor*, all community metering shall be located

at one position. Where additional Community Metering points are approved, each shall be treated as a separate *NMI* (Refer to Drawing QECM 6.5).

Where a cluster or community title scheme development consists of a number of multi-tenanted buildings, additional meter position/s located on common property may be permitted.

The following meter positions will also be acceptable:

(a) Overhead Reticulation

- (ii) The main switchboard located on *common property* and all metering equipment installed at this position.
- (iii) The main switchboard and the first metering point located on *common property* and subsequent metering points located on *common property* or as otherwise approved by the *metering provider*.

(b) Underground Reticulation

Arrangements given in either (i) or (ii) above: or

The individual *consumer's mains* (for each unit) installed on *common property* and connected to the *distributor's* reticulation with the metering equipment located at the unit.

Note: Where more than 3 sets of *consumer's mains* are to be connected to a distributor's pillar, approval must be obtained from the *distributor*

Note: A general arrangement is for twelve *customers* or units per metering point or as otherwise approved by the *distributor*.

The *Energex* Subdivision Standards - Developer Design & Construct Estates Manual provides further information regarding Community Title and Cluster Developments in the *Energex* distribution area. It is available for download on the *Energex* website.

6.6.4 Unsuitable Locations

The following locations are unsuitable for the installation of metering equipment:

- (a) Within or at any height above any pool zone as defined in AS/NZS 3000 (Wiring Rules).
- (b) Locations where the only point of access is through the fenced area around the pool.
- (c) Within any hazardous area defined in AS/NZS 3000 (Wiring Rules) or within a gas emitting device (gas meter regulator) exclusion zone defined by AS 5601-2004 (Australian Gas Code) and AS 4645.1. In particular, *electrical contractors* should be aware of the hazardous areas associated with exchange or in-situ fill LPG gas cylinders. (Refer to AS/NZS 3000 (Wiring Rules) and AS/NZS 2430.3.4).
- (d) Over stairways or ramps, in narrow passageways, toilets or fire isolated stairways.
- (e) In vehicle docks, driveways, factory walkways etc. where the equipment, or a person working on the equipment would not be adequately protected.
- (f) In close proximity to machinery.
- (g) Locations where exposure to fumes, dust or dampness may result in unsatisfactory working conditions.
- (h) In positions where the ambient temperature exceeds 50⁰ C (e.g. boiler rooms).
- (i) In areas with insufficient light.

- (j) In confined spaces.
- (k) In areas where the integrity of a security system will be affected by entry of the *metering provider's* personnel, (refer to Clause 6.10), or where access is normally restricted for health or other reasons.
- (l) In multiple installations, the meter position is not to be situated within any lockable portion of an individual tenancy (i.e. shall only be located in a common area).
- (m) Within enclosed carports or verandahs.
- (n) In areas enclosing dogs.
- (o) Behind a property perimeter fence without an adjacent gate. (Refer to Clause 6.6.2 for meter positions on domestic properties).
- (p) In areas subject to varying high intensity magnetic fields. (Refer to QEMM for current transformer meter panels in the vicinity of heavy current carrying conductors).
- (q) On the *distributor's* works. (For exception details refer to Clause 5.9).
- (r) Secured private areas.
- (s) Where the noise level exceeds the LAeq.8h level of 85dB(A) as per the Qld Health and Safety Regulation and Australian Standard AS/NZS 1269.1
- (t) In areas where the *distributor's* staff require inductions to access the site (permanent sites only, building sites/builders temporary supplies are exempt from this item). This item is a recommendation only and may not be possible in all instances.
- (u) Where access may require any additional provisions e.g. EWP or scissor lift to perform a rescue of an injured worker.

6.6.5 Existing Installations

Where work is performed on an existing installation, compliance with the following requirements must be satisfied;

Electrical Additions & Alterations (Major) - Where major upgrades are carried out to a *customer* installation (e.g. *consumer's mains* upgrade and/or meter enclosure replacement and/or replacement of a meter panel not housed in an enclosure) the location of the meters shall comply with all requirements of Section 6.

Note: refer also to clause 5.4.5 (d) for requirements to relocate overhead service *point of attachment* where major alterations are carried out.

Electrical Additions & Alterations (Minor) - Where minor upgrades are carried out to a *customer* installation (e.g. additional tariff or *Micro EG Unit* metering, load centre change, replacement of a meter panel within an enclosure where the enclosure is not being replaced) the meters may be left in the existing location, provided the metering location is suitable to the *metering provider* (refer to Clause 6.6.1 & 6.6.4 for unsuitable locations).

Building Renovations / Alterations - Where building alterations or similar works are carried out to *premises* which results in the metering equipment no longer being in a position that is suitable to the *metering provider* (refer to Clause 6.4 for unsuitable locations), the *customer* shall, at their expense, relocate the metering equipment to an acceptable position complying with Section 6.

Other Repairs & Damage caused outside a person's control (e.g. Natural Disaster) – Compliance with Section 6 is required where the metering is located in an unsuitable location (refer to Clause 6.11.4). In instances where the metering is not located in an unsuitable location, repairs may be carried out by “using methods that were acceptable when that part of the electrical installation was originally installed”, provided those methods satisfy the fundamental safety principles of Part 1 of AS/NZS 3000.

In addition to the above, all new or replacement metering panels shall also comply with Clause 6.9.

Only the appointed *Metering Provider* can work on or remove metering equipment. (Refer to responsibilities section).

6.7. Metering and Control Equipment - Housing

ASBESTOS WARNING

Older type switchboard and meter panels may contain asbestos. Electrical workers who are required to work on these panels need to identify if this hazard is present and, if necessary, take appropriate action. Old Zelemite (black) electrical switchboards can contain up to 20% asbestos. When working on an electrical switchboard that is aged (pre 1987), assume the presence of asbestos, even if it is not marked as such.

Asbestos information including codes of practice and legislative requirements is available on the Workplace Health and Safety Queensland web site www.deir.qld.gov.au/workplace/ under the heading “laws and prosecutions”.

- 6.7.1** Where meters and control equipment are erected in a position exposed to the effects of the weather, direct sunlight, corrosive atmosphere and the like they shall be enclosed in a suitable meter enclosure. Meter reading windows in meter enclosures are not permitted.

Meters, control equipment and their enclosures shall be protected from mechanical damage, by either their location or the manner of mounting.

Note: Where a meter enclosure is installed on a temporary structure, the supporting structure shall be mechanically sound. Where the temporary structure is used for building purposes it shall comply with the requirements of AS/NZS 3012 (e.g. includes the connection of permanent supply for domestic building purposes in a URD estate).

- 6.7.2** Where meters and control equipment are accessible only from the outside of a building, they shall be enclosed in a suitable meter enclosure mounted on, or recessed into the outside wall of the building. Meter enclosures shall not be installed where they protrude or open across a property boundary.

Exception: Meter enclosures mounted on the front boundary may open towards the footpath. It is recommended that meter enclosures mounted in these positions be locked. (Refer to Clause 6.10 for metering lock details).

On a single *direct connected metering* installation a meter enclosure shall comply with either: "Specification for Metallic Enclosures for Meters in Direct Connected Installations" *QECM* Appendix A, or (at the discretion and written approval of the *distributor*) another type of metering enclosure complying with AS 6002.

- 6.7.3** Where a meter enclosure used to house revenue metering equipment is erected on a pole, it shall be constructed of an approved material (not

timber), be adequately fixed in position and where necessary, suitably treated against corrosion.

- 6.7.4** All metallic meter enclosures shall be earthed. Where double insulation is maintained throughout the meter enclosure (in accordance with the requirements of AS/NZS 3000 (Wiring Rules)), earthing is not required.

6.8. Metering and Control Equipment – Spacing Requirements

Item A.3 of the "Specification for Metallic Enclosures for Meters in Direct Connected Installations" in Appendix A, specifies minimum space requirements for metering equipment on direct connected installations.

QEMM minimum space requirements for meter panels for low voltage *current transformer metering*.

Minimum space requirements for mounting of meters and control equipment are shown in TABLE 6.1.

TABLE 6.1

Meter and Network Device Details	Height (mm)	Width (mm)	Depth (mm)	Approx. Weight (kg)
Network device	190	110	110	0.5
Metering Isolation Link	90	45		

A minimum clearance of 25mm is required between any item of metering or control equipment.

The minimum clearance around the ends of metering isolation links shall be 40mm minimum.

All metering enclosures shall include provision for Installation of an Antenna/Aerial.

Exception: Metering isolation links associated with each NMI can be mounted side by side with no clearance between provided the minimum clearance around the ends of metering isolation links is 40mm minimum.

6.9. Metering and Control Equipment - Mounting

- 6.9.1** All meters, *network devices* and metering isolation links must be mounted on a side hinged panel so that the metering and control equipment always remains in the vertical plane. Meters and *network devices* must be mounted vertically with cable connections at the bottom (Refer to Drawing QECM 6.1 and Appendix A).

Existing installations

Where *direct connected* meters are installed to facilitate a *customer* requested supply/tariff change, additional tariffs (e.g. controlled supply tariff) or installation of an *Micro EG Unit* on an existing single *customer* installation, allowance is also to be made for the metering equipment to be mounted on a hinged panel that does not contain asbestos.

- 6.9.2** Meter panels shall be constructed of a durable, non-conducting, fire resistant material with low water absorption properties and shall not contain asbestos. Alterations requiring a replacement meter panel shall comply with the above. Existing meter panels in good condition that do not contain asbestos do not require replacement however insulated fire retardant backing boards with low water absorption properties and not containing asbestos must be installed behind all new and retrofitted electronic equipment associated with the *customers* metering and control equipment on existing panels that are not constructed of fire resistant material.
- 6.9.3** Bolts/screws used to mount and fix equipment on insulated meter panels shall be fit for purpose. Where mounting bolts/screws protrude through the meter panel and can be contacted, a non-conducting bolt/screw (e.g. nylon or plastic) shall be used.

Note: Metal screws with needle points and self drilling tips are not permitted. The insulating of metal screws using silicone or other material is not permitted.

- 6.9.4** The panel within the meter enclosure should be not more than 300 mm from the front of the meter enclosure.
- 6.9.5** The meter panel is dedicated for revenue metering equipment and *network devices*. *Customer* owned equipment (including GPOs, Contactors etc) shall not be installed on the meter panel (this excludes metering isolation links/CBs as this equipment is part of the revenue metering). *Customer* owned metering neutral and active links should also be mounted on the rear of the meter panel or meter enclosure and shall not be mounted on the front of the meter panel (refer to Clause 6.4.5).

Note: Where a larger panel is used, it is permissible for *customer* owned equipment to be installed on the same panel outside of an area dedicated for use for metering equipment provided the meter panel area meets the minimum size specified in Appendix A, is indelibly marked with a demarcation line and is labelled to indicate the meter panel section is dedicated for metering equipment

Meter panels on temporary builder's supplies do not need to be dedicated to revenue metering equipment unless they are intended to be installed in the permanent position.

6.10. Height of Metering and Control Equipment – Mounting Height

Unless otherwise approved in writing by the *distributor*, the top of any metering equipment shall have a maximum height of 2000mm above floor or ground level. The bottom of the meter, *network device* or item of metering equipment shall not be less than 900 mm above floor or ground level when not installed in an enclosure or dedicated switch room or meter room. This

height may be reduced to 700mm (500mm for metering isolation links) above floor or ground level when installed within an enclosure or dedicated switch room or meter room.

Where the *customer* is required to provide a platform to access a meter installation, it shall be designed to AS 1657, be certified by a RPEQ that the structure is suitable for the application, and be designed to support a minimum load of 200kg. A certificate of approval shall be submitted to the *distributor* prior to connection of supply. Where meters and switchboards are installed on service poles, the platform shall be self-supporting and permanently mounted.

The service pole shall not be used to support any platform structure, and any step-type ladder access shall be clear of any fences or sharp objects that may be considered a fall hazard.

For clearances in front of the metering enclosure doors refer to AS/NZS 3000 (Wiring Rules) (i.e. minimum clearances of 600mm).

For existing installations where access is considered unsafe, the *metering provider* may refuse to read the meters until the unsafe condition has been rectified by the *customer* or may repair the access at the *customer's* cost. (Electricity Regulation 2006).

6.11. Metering Locks

Where the *distributor* agrees to meters being erected in an enclosure within an area which may be locked for security reasons, or where meters may be subject to vandalism, the *distributor's* metering lock must be purchased and installed to permit access. (Refer to page 1 for purchasing details and Drawing QECM 6.6 for lock types). The installation of "Private Locks" is not permitted for providing access to metering equipment.

Where the *distributor's* metering lock is installed, all tenants who require access to the meter panel shall be provided with such access.

Note: If the *distributor's* personnel are requested to open the metering lock for tenant access, the *customer* will be charged a call out fee.

Metering locks shall not be used on a garage door, verandah door or similar doors that provide access to private areas. (Refer to Clause 6.6.4 and Drawing QECM 6.6).

The *distributor* may provide master metering lock keys to *metering providers* when requested in accordance with their procedures. *Metering providers* will keep master keys secure and return them to the *distributor* when no longer required or when requested by the *distributor*.

6.12. Current Transformer Equipment supplied by the Distributor

The *distributor* may supply the current transformers, E.S.A.A. pattern test block, voltage circuit fuses with HRC cartridges and fuse sealing blocks with covers. *Energex* provides current transformer ratio and neutral identification labels for use in their area. The *metering provider* will provide the meter and/or communications equipment.

6.13. Current Transformer Metering – Housing

To allow commissioning and testing of *current transformer metering* installations to be performed safely, all live low voltage parts within current transformer chambers are to be individually insulated (insulation must completely cover all live parts). Heat shrink insulation is acceptable for insulating busbars. All bolted busbar or cable connections are to be covered with non-adhesive insulation secured in place by cable ties.

A non-conductive insulated barrier alone (removable cover over CT chamber) is not an acceptable method of insulation.

6.14. Changes to Existing Current Transformer Metering Installations


Check

Ergon Energy requires all LV *current transformer metering* installation designs to have prior approval for the metering arrangement. This requires the submission of Switchboard Layout and Single Line Diagrams as early as possible to allow design modifications to be carried out if necessary prior to switchboards being built.


1 Ver 2
9 Ver 2


If this information is not provided, *Ergon Energy* cannot guarantee supply will be


Electrical Contractor's LV CT Metering Check Sheet			
Address Where CT Metering Installed:			
National Metering Identifier (NMI) (If known):			
Details of Electrical Mechanic Responsible for Testing of CT Installation:			
Name: Licence No:			
Pre-commissioning Checks			
Clause No.	Checklist	Checked	Comments
Switchboard/CT Chamber			
6.6.3	Lockable isolator on line side of CTs:		
QEMM	Dedicated CT chamber provided:		
QEMM	CT chamber correctly labelled:		
QEMM	Removable CT chamber cover fitted with 2 handles:		
Current Transformers			
QEMM	CT ratio matches expected load:		
6.12	No exposed live parts within CT chamber:		
QEMM	Primary and secondary polarity is correct:		
QEMM	Removable bus bars allow CTs to be easily replaced:		
QEMM	CT secondary terminals are accessible:		
Voltage Circuit Fuses			
QEMM	Fuses carriers are accessible and easily removable:		
QEMM	Fuses are connected to the line side of the CTs:		
QEMM	Cables from bus bars to fuses are $\leq 500\text{mm}$ and a minimum. of 10mm^2 SDI:		
QEMM	Correct marking of cables from bus bars to fuses (e.g. trace or bell out cables):		
Meter Neutral & Earthing			
AS/NZS 3000	Test continuity to confirm that cabinets are earthed:		
QEMM	Meter neutral is connected to main neutral and meter neutral label is attached:		
Meter Panel Wiring & Test Block			
6.6.4	Meter panel located in suitable location		
QEMM	Meter panel size is minimum $600 \times 600\text{mm}$ (or $460 \times 600\text{mm}$ for single tariff CT installation):		
QEMM	Meters are mounted at correct height:		
QEMM	Meter panel is hinged:		
QEMM	Meters and wiring spaced from heavy current carrying conductors:		
QEMM	Test block is mounted correctly:		
QEMM	Colour coding is correct:		
QEMM	Meter wiring is correct size for circuit length:		
QEMM	Secondary returns are starred and earthed:		
Sealing			
QEMM	CT chamber, voltage circuit fuses and meter panel are sealable:		




Revision: A	DRILLING DETAILS FOR CABLE ACCESS AF RECEIVER	QECM - 6.1
-----------------------	--	-------------------









OH/UG

	Community Title Scheme / Multi unit dwellings	Customer Reticulated community title schemes	Distributor's Reticulation community title schemes	Single unit dwellings
Meter Position	1 meter position on common property	The MSB and first meter position on common property plus 1 additional Meter position for every additional 12 customers if required	1 meter position per dwelling fed from the point of supply	1 meter position per unit
Point of Supply	1 Point of supply per community title scheme	1 Point of supply per community title scheme	1 Point of supply per unit	1 Point of supply per unit
	refer DWG A (I), (II).	refer DWG C	refer DWG D	refer DWG E

NOTES:

1. Common Property made exclusive use. DWG B

Where the area of common property has been designated for the exclusive use to each lot, ie. Fenced off and prohibiting access to other owners or occupiers to their metering position, service line and/or consumers terminals.


A separate point of supply & metering position shall be required for each unit and conform to Clause 6.6.4.

Under no circumstances shall the service line or consumers mains be permitted to cross or enter the area of exclusive use in order to service another lot.


2. Dual occupancy developments shall only be entitled to have one point of supply and one metering position. ie. Granny flats, sheds, dependant persons accommodation.

Note: Point of supply and metering positions shown on diagrams are indicative only.


□ Point of supply ▨ Common Ground ⊠ Metering Position ⊞ Street/Laneway ▨ Exclusive Use Area




DWG A(I)
Community Title (Small Subdivisions)




DWG A(II)
Community Title




DWG B
Community Title with exclusive use areas



DWG C
Customer Reticulated Community Title



DWG D
Distributor Reticulation













DWG E
Distributor Reticulation. No common ground Single Unit Dwellings

Revision:

A

**SUITABLE LOCATION OF METERING PANELS
COMMUNITY TITLE**

QECM - 6.5

RIM LOCK CYLINDER		
		<p>TYPE 201 CYL FOR USE IN NIGHTLATCH/STREAMLATCH/DEADLATCH TYPE LOCKSETS. (CYLINDER ONLY PROVIDED.)</p>
MORTICE LOCK CYLINDER		
		<p>TYPE 570 CYL FOR USE IN CYLINDER MORTICE LOCKS AND LATCHES. (CYLINDER ONLY PROVIDED.)</p>
KEY - IN - KNOB CYLINDER		
		<p>TYPE 530 CYL FOR USE IN KEY-IN-KNOB AND KEY-IN-LEVER LOCKSETS. (CYLINDER ONLY PROVIDED.)</p>
BRASS PADLOCK		
		<p>TYPE 234 FOR USE IN ERGON ENERGY TYPE 234/SS FOR USE IN ENERGEX</p> <p>234/45/119 - 19mm SHACKLE 234/45/138 - 38mm SHACKLE 234/45/148 - 48mm SHACKLE 234/45/190 - 90mm SHACKLE</p> <p>(COMPLETE LOCK PROVIDED.)</p>
METER CUBICLE LOCK		
		<p>TYPE 'L' HANDLE OR 'T' HANDLE TO BE USED AS A METER CUBICLE LOCK. (COMPLETE LOCK PROVIDED.)</p> <p>NOTES:</p> <ol style="list-style-type: none"> 1. USE 'EX' PREFIX TO INDICATE ENERGEX METERING KEY SYSTEM EG ENERGEX RIM LOCK CYLINDER USE TYPE EX201 CYL. 2. A LIST OF APPROVED LOCKSMITHS IS AVAILABLE ON THE DISTRIBUTORS WEBSITE - SEE CONTACTS PAGE FOR DETAILS.
Revision: A	MASTER KEYED METERING LOCK DETAILS	QECM - 6.6

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

7. CONTROLLED SUPPLIES - METHOD OF CONTROL

7.1. General

For *controlled supplies*, the *distributor* will supply a *network device*.

Two and three switch *network devices* will be utilised for the following situations:

(a) For single installations where a combination of water heating and other *controlled loads* are connected. (Refer to Drawings QECM 7.1, 7.3, 7.5, 7.6 and 7.7).

(b) For multiple installations, such as flats and home units. (Refer to Drawing QECM7.4)

The *electrical contractor* shall install all *network device* wiring.

The *electrical contractor* shall install all meter wiring unless an agreement has been negotiated with the *metering provider*.

Equipment connected to a *controlled supply* is to be permanently connected however specific equipment may be connected via a socket outlet at the *distributor's* discretion (refer to Frequently Asked Questions document in Technical Documents Section of *distributor's* website).

Where a socket outlet is provided for this purpose, it shall be dedicated to the *controlled supply* equipment (spare *controlled supply* outlets are not permitted).

A permanent indelible label shall be fixed on or adjacent to the socket outlet stating the following:

Controlled Supply Only

7.2. Network Devices

7.2.1 Where equipment other than water heating, is to be connected to a controlled supply, this equipment is to be connected via a dedicated circuit and connected to a dedicated switch in a multi-switch network device.

Note: On existing installations where submains are installed from the main switchboard/metering point to a distribution switchboard other equipment can be connected to the *controlled supply*, however, it will be switched at the same time as the hot water supply. This shall only be permitted provided the main switchboard/metering point and distribution switchboard are not located within close proximity (within 20 meters) or back to back with each other.

7.2.2 Single phase installations with *controlled supplies* shall be connected in accordance with Drawings QECM 7.1 - 7.3

7.2.3 Multiple installations where multi-switch *network devices* are utilised must be provided with a *network device* switch per *customer* in accordance with Drawing QECM 7.4. Switching of individual *customer's* hot water by the use of contactors is not permitted.

Notes:

1. Connections to multi-switch *network devices* shall be clearly labelled to identify the switch applicable to each *customer*.
2. A separate metering isolation link is to be used for supply to the *network device(s)*. Where more than one switch per *customer* is required then an individual *network device* per *customer* shall be used as per Clause 7.2.2.

7.2.4 Poly phase installations with direct connected meters shall be connected in accordance with Drawings QECM 7.5 – 7.8.

Note: Three phase loads (e.g. motors) shall be controlled via a *network device* switching a contactor. (Refer Drawing QECM 7.8).

7.3. Contactor for Control of Non-Continuous Load

Where the single phase load to be controlled exceeds 30A resistive (e.g. electric water heaters), 20A inductive (e.g. motors) or a combination of resistive and inductive load (e.g. air conditioners), a contactor is required. Where a contactor is required it shall be supplied by the *customer*, be of a type acceptable to the *distributor* and shall be installed in an accessible position within the Main Switchboard, in a sealable fit for purpose enclosure (if required). (Refer to Drawings QECM 7.2, 7.6, 7.8 and 7.9).

In the Energex distribution area an additional switch of a multi switch *network device* may be used in place of a contactor in domestic installations provided the load on each switch complies with that given above. Paralleling of switches is not permitted.

Contactors with no external moving parts are suitable for use without further protection and do not require provision for sealing.


Three phase installations requiring a contactor shall have the *network device* connected in accordance with Drawing QECM 7.8 for *direct connected meters* and Drawing QECM 7.9 for *current transformer metering*.

The contactor shall not be used for automatic load control (e.g. it shall not have a humidistat, a flow switch, a thermostat, a pressure switch or the like connected in its control circuit).

7.4. Size of Network Device Wiring

The wiring from a *controlled supply* meter to a *network device* (or controlled load main switch) and all meter neutral wiring shall be PVC insulated stranded copper cable of no more than 7 strands, a minimum of 4mm² and shall not exceed 6mm².

Aluminium cables are not permitted for connection directly into *network device* terminals.



ITEMS SUPPLIED BY METERING PROVIDER.

% ITEMS SUPPLIED BY DISTRIBUTOR.

* SWITCH POSITION AND NUMBER OF SWITCHES DETERMINED BY SUPPLY AND LOAD TYPE.

NOTES:


1. ELEMENT 1 FOR PRINCIPAL SUPPLY ONLY, ELEMENT 2 FOR EITHER NIGHT RATE OR CONTROLLED SUPPLY.
2. CONTROLLED CIRCUIT ASSOCIATED WITH SECONDARY SUPPLY CONNECTED TO UNSWITCHED TERMINAL OF TWO ELEMENT METER.
3. SECONDARY SUPPLY SWITCHING IS DONE BY THE NETWORK DEVICE.
4. METERING ARRANGEMENT INDICATIVE FOR PoC AREAS.

Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
SINGLE PHASE PRINCIPAL SUPPLY PLUS
NIGHT RATE OR CONTROLLED SUPPLY**

QECM - 7.1



- # ITEMS SUPPLIED BY METERING PROVIDER.
 % ITEMS SUPPLIED BY DISTRIBUTOR.
 * SWITCH POSITION AND NUMBER OF SWITCHES DETERMINED BY SUPPLY AND LOAD TYPE.

NOTES:


1. ELEMENT 1 FOR PRINCIPAL SUPPLY ONLY, ELEMENT 2 FOR EITHER NIGHT RATE OR CONTROLLED SUPPLY.
2. CONTROLLED CIRCUIT ASSOCIATED WITH SECONDARY SUPPLY CONNECTED TO UNSWITCHED METER TERMINAL OF TWO ELEMENT METER.
3. SECONDARY SUPPLY CONTACTOR CONTROLLED BY THE NETWORK DEVICE
4. METERING ARRANGEMENT INDICATIVE FOR PoC AREAS.

Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
 SINGLE PHASE PRINCIPAL SUPPLY PLUS
 NIGHT RATE OR CONTROLLED SUPPLY WITH CONTACTOR**

QECM - 7.2



ITEMS SUPPLIED BY METERING PROVIDER.

% ITEMS SUPPLIED BY DISTRIBUTOR.

* SWITCH POSITION AND NUMBER OF SWITCHES DETERMINED BY SUPPLY AND LOAD TYPE.

NOTES:


1. ELEMENT 1 FOR PRINCIPAL SUPPLY ONLY, ELEMENT 2 FOR EITHER NIGHT RATE OR CONTROLLED SUPPLY.
2. CONTROLLED CIRCUIT ASSOCIATED WITH NIGHT RATE SUPPLY CONNECTED TO UNSWITCHED TERMINAL OF TWO ELEMENT METER.
3. SECONDARY SUPPLY SWITCHING IS DONE BY THE NETWORK DEVICE.
4. METERING ARRANGEMENT INDICATIVE FOR PoC AREAS.

Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
SINGLE PHASE PRINCIPAL SUPPLY PLUS
NIGHT RATE AND CONTROLLED SUPPLIES**

QECM - 7.3




Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
SINGLE PHASE PRINCIPAL SUPPLY PLUS
NIGHT RATE OR CONTROLLED SUPPLY
MULTIPLE INSTALLATIONS**

QECCM - 7.4



ITEMS SUPPLIED BY METERING PROVIDER.

% ITEMS SUPPLIED BY DISTRIBUTOR.

* SWITCH POSITION AND NUMBER OF SWITCHES DETERMINED BY SUPPLY AND LOAD TYPE.

NOTES:


1. METERING ARRANGEMENT INDICATIVE FOR PoC AREAS.

Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
TWO PHASE PRINCIPAL SUPPLY PLUS
SINGLE PHASE NIGHT RATE OR CONTROLLED SUPPLY**

QECM - 7.5



ITEMS SUPPLIED BY METERING PROVIDER.

% ITEMS SUPPLIED BY DISTRIBUTOR.

* SWITCH POSITION AND NUMBER OF SWITCHES DETERMINED BY SUPPLY AND LOAD TYPE.

NOTES:


1. ## CURRENT LIMITING DEVICES FOR THE PROTECTION OF WHOLE CURRENT METERING CIRCUITS SHALL BE NO GREATER THAN A 100A HRC FUSE OR EQUIVALENT (REFER CLAUSE 6.3.1.3).
2. IF THE PRINCIPAL SUPPLY AND CONTROLLED SUPPLY LOAD EXCEED THE METERING ISOLATION LINK RATING, A SEPARATE SET OF METERING ISOLATION LINKS FOR EACH METER SHALL BE PROVIDED.
3. METERING ARRANGEMENT INDICATIVE OF PoC AREAS (REFER CLAUSE 6.3.1.3).

Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
TWO PHASE PRINCIPAL SUPPLY PLUS
TWO PHASE NIGHT RATE OR CONTROLLED SUPPLY**

QECM - 7.6



NOTES:


1. OTHER CONTROLLED SUPPLY LOAD CANNOT BE CONNECTED IN CONJUNCTION WITH NIGHT RATE LOAD ON THE ONE METER (REFER TO DRAWING QECCM 7.3).

2. METERING ARRANGEMENT INDICATIVE FOR PoC AREAS.

Revision:
A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
THREE PHASE PRINCIPAL SUPPLY PLUS
SINGLE PHASE NIGHT RATE OR CONTROLLED SUPPLY**

QECCM - 7.7



ITEMS SUPPLIED BY METERING PROVIDER.

% ITEMS SUPPLIED BY DISTRIBUTOR.

* SWITCH POSITION AND NUMBER OF SWITCHES DETERMINED BY SUPPLY AND LOAD TYPE.

NOTES:

1. TWO SWITCH NETWORK DEVICE WITH SEPARATE SUPPLY AND SWITCH CIRCUITS IS TO BE USED TO CONTROL CONTACTOR.

2. INSTALL APPROVED BACK WIRED METERING ISOLATION LINKS.

NOTE: WHERE METER NOT INSTALLED REMOVE SOLID LINKS TO ENSURE NO EXPOSED LIVE TAILS.

3. ## CURRENT LIMITING DEVICES FOR THE PROTECTION OF WHOLE CURRENT METERING CIRCUITS SHALL BE NO GREATER THAN A 100A HRC FUSE OR EQUIVALENT.

4. IF THE PRINCIPAL SUPPLY AND CONTROLLED SUPPLY LOAD EXCEED THE METERING ISOLATION LINK RATING, A SEPARATE SET OF METERING ISOLATION LINKS FOR EACH METER SHALL BE PROVIDED.


5. METERING ARRANGEMENT INDICATIVE FOR PoC AREAS.

Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
THREE PHASE PRINCIPAL SUPPLY PLUS
THREE PHASE NIGHT RATE OR CONTROLLED SUPPLY**

QECM - 7.8



Revision:
A

**WIRING DIAGRAM - CURRENT TRANSFORMER METERING
THREE PHASE PRINCIPAL SUPPLY PLUS
THREE PHASE NIGHT RATE OR CONTROLLED SUPPLY**

QECM - 7.9

Queensland Electricity Connection Manual



Part of the Energy Queensland Group

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

8. ARRANGEMENTS FOR EMBEDDED GENERATING SYSTEMS CONNECTED TO THE DISTRIBUTION NETWORK

8.1. Explanation of Metering Schemes Available

Two metering schemes are available for the grid-connected Embedded Generating (EG) systems, known as the “*Net Energy*” and the “*Gross Energy*” schemes. All *EG* systems installations must be compliant with the *distributor’s* connection standards.

The Queensland Government Solar Bonus Scheme requires the installation of a *Net Energy* metering solution.

The *Net Energy* metering scheme has a single import/export meter installed in the place of the existing general supply energy consumption meter(s).

The *Gross Energy* metering scheme may require an additional import/ export meter installed on the meter panel to record the *EG* system supply energy generation only.

8.2. Agreements

All *customers* with an EG system must have an Network Connection Agreement for the *EG* system in place with the *distributor* before the *EG* system can be connected to the *distributor’s* supply network. This includes systems that are configured as minimal-export or non-export back to the distribution network.

The *customer* or their agent shall nominate the metering scheme on the application form for network connection of an *EG* system, and the *electrical contractor* shall nominate the metering scheme on their *Electrical Work Request* sent to the *distributor*.

Customers wishing to be compensated for any electricity exported by the *EG* system to the *distributor’s* supply network other than through the Queensland Government Solar Bonus Scheme must also have a Power Purchase Agreement in place with their *retailer*. Details on determining eligibility for the Queensland Government Solar Bonus Scheme can be found at the Queensland Government website <https://www.qld.gov.au/housing/buying-owning-home/feed-in-tariffs>.

8.3. Approval of Equipment

Typical *direct connected metering* arrangements have been developed in line with *EG* system requirements and *retailer* offered supply types however it is up to the *metering provider* to install suitable metering arrangement to meet site requirements

For the “*Net Energy Scheme*” Drawings QEMM 7.1 to 7.8 cover typical single and polyphase supply/service connections for single and polyphase *EG* systems.

For the “*Gross Energy Scheme*” Drawings QEMM 8.1 and 8.2 cover typical single and three phase supply/service connections for single and polyphase *EG* systems.

Notes:

1. Exceptions to the above standards may be approved upon receipt of a written application in exceptional circumstances. Applications shall be made in writing to the *distributor*. Standard charges will apply for such arrangements.
2. It must be noted that the “*Gross Scheme*” may require an additional meter, and the end user must be made aware that provision of this space is required at the current metering location.
3. In a “*Net Scheme*”, if the principal metering has more than one phase, it is a requirement that a polyphase meter must be used.

8.4. Connection Requirements for EG Systems


Connection requirements associated with *EG systems* connected to the distribution network shall be in accordance with:

Total Inverter Rating (kVA)	Energex	Ergon Energy
Up to and including 30kVA	STD01143	STNW1170
Greater than 30 kW to 1,500 kW where <i>connection point</i> with <i>distributor</i> is at low voltage (LV)	STD01618	STNW1174
Greater than 30 kW and less than 5MW where <i>connection point</i> with <i>distributor</i> is at high voltage (HV)	STNW1175	STNW1175

Any *EVSE* installation capable of export to the grid (i.e. vehicle to grid) will be treated as an *EG system*.

8.5. Labelling Requirements to AS/NZS 4777.1

For installations sized 200 kVA and less, installation shall be compliant with the labelling requirements of AS/NZS 4777.1.



ITEMS SUPPLIED BY METERING PROVIDER.

% ITEMS SUPPLIED BY DISTRIBUTOR.

* SWITCH POSITION AND NUMBER OF SWITCHES DETERMINED BY SUPPLY AND LOAD TYPE.

NOTES:

1. BI-DIRECTIONAL SINGLE PHASE ELECTRONIC METER REQUIRED FOR IMPORT / EXPORT ENERGY REGISTRATION.
2. INVERTER ENERGY SYSTEM (IES) COMPLIANT TO AS4777 CONNECTED WITHIN THE INSTALLATION ON THE CUSTOMERS SIDE OF THE IES SUPPLY MAIN SWITCH.
3. TWO ELEMENT METER TERMINAL DESCRIPTION.

1	A - ACTIVE IN
3	N - NEUTRAL IN
4	Lm - ELEMENT 1 (MAIN - PRIMARY LOAD)
5	Lt - ELEMENT 2 (UNSWITCHED - IES SUPPLY)
6	S1 - NOT USED


4. METERING ARRANGEMENT INDICATIVE FOR PoC AREAS.

Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
GROSS METERING SCHEME
SINGLE PHASE PRINCIPAL SUPPLY PLUS
NIGHT RATE OR CONTROLLED SUPPLY**

QECM - 8.1



NOTES:

1. INVERTER ENERGY SYSTEM (IES), COMPLIANT TO AS4777, CONNECTED WITHIN THE INSTALLATION ON THE CUSTOMERS SIDE OF THE IES SUPPLY MAIN SWITCH.
2. METERING ARRANGEMENT INDICATIVE FOR PoC AREAS.

Revision:

A

**WIRING DIAGRAM - DIRECT CONNECTED METERING
GROSS METERING SCHEME
THREE PHASE PRINCIPAL SUPPLY PLUS
SINGLE PHASE NIGHT RATE OR CONTROLLED SUPPLY**

QECM - 8.2

9. HIGH VOLTAGE METERING

9.1. General Requirements

The *customer* is required to supply, install and maintain all electrical equipment supplied by the *customer*. All high voltage equipment must be compatible with the *distributor's* supply. Relays, current transformers and other protective equipment must have characteristics compatible with the *distributor's* existing protective system.

The design, construction and installation of all high voltage equipment shall comply with the appropriate Australian Standards (e.g. AS/NZS 3000 (Wiring Rules) and AS 2067) or other equivalent Standards (e.g. IEC Standards). Plans, drawings and particulars describing the proposed installation and its operating conditions shall be provided.

The *distributor* will advise the *customer* of the prospective fault level and the normal fluctuations of supply voltage for which provisions should be made.

9.2. Testing Requirements

The *customer* shall meet the cost of any high voltage testing as required by AS 2067 and auditing in accordance with the Electrical Safety Act 2002.

The metering coordinator shall ensure that high voltage revenue metering instrument transformers are tested and maintained in accordance with the National Electricity Rules.

9.3. Operation of High Voltage Equipment

The *customer* is responsible for ensuring that the high voltage installation is operated in accordance with the requirements of the Electrical Safety Act 2002, the Electrical Safety Regulation 2013 and the Code of Practice for Electrical Work.

The *customer* has an obligation to ensure all persons who are involved in the high voltage isolation and access procedures have been trained and assessed as competent to perform the roles for which they are responsible.

Testing, earthing and safety equipment suitable for operation of the high voltage equipment shall be readily available on site.

For high voltage installations consisting of more than one item of switchgear, an operating diagram in the form of a single line schematic of the complete installation is to be permanently displayed adjacent to the main switch or switches.

Where items of switchgear are remote from the main switchboard, it is recommended that the operating diagram also be permanently displayed at these locations.

9.4. Maintenance and Repairs of High Voltage Equipment

A *customer* who takes supply at high voltage shall ensure that the high voltage installation is maintained so that any malfunction will not create a hazard or cause interference to the *distributor's* supply.

All costs associated with the maintenance or repairs of the *customer's* high voltage installation shall be met by the *customer*.

Note: The *customer* must be prepared for power interruptions during high voltage testing procedures, maintenance or repairs.

9.5. Conversion from Low Voltage Supply to High Voltage Supply

A *customer* planning to convert from supply at low voltage to supply at high voltage shall negotiate with the *distributor* before commencement of work.

Options to be considered may include the following:

- (a) Replacement of the *distributor's* substation and other assets or purchase of this equipment from the *distributor*; and

- (b) Any costs associated with converting the installation for compliance with AS/NZS 3000 (Wiring Rules) and AS 2067.

9.6. Metering Requirements

The *customer* or *customer's* representative (electrical contractor or consultant) must contact the *distributor* prior to commencing any project that may require high voltage metering. High voltage metering is complex and the following may need to be considered:

- (a) Specialised metering design (voltage change-over schemes etc.).
- (b) Compliance with the *National Electricity Rules*.
- (c) Equipment with long lead times (e.g. 6 to 12 months) may be required.
- (d) Full or partial check metering requirements for large loads.
- (e) Generator connections and import/export load flows.
- (f) Test certificates for metering instrument transformers from an accredited laboratory.

The relevant metering requirements in previous chapters also apply to high voltage installations. Where there are differences between the information in Section 9 and the remainder of the *QECM*, the requirements of Section 9 prevail in relation to *high voltage metering*. The additional details contained in Section 9 are specific to *high voltage metering* installations. The *distributor* or *metering provider* can be contacted for additional information.

9.7. Establishing a Network Connection and *NMI*

For high voltage connections the process of metering the site, data collection and settlement of energy requires the following steps:

1. The *customer* is required to engage an electricity *retailer* licensed to operate in Queensland.
2. The *retailer* is required to appoint a *metering coordinator*.
3. The *metering coordinator* is required to appoint the *metering data provider* and the *provider*.
4. The *retailer* is required to submit a *SOR* to the *distributor* to make the network connection.

The above process will establish a *NMI* per *connection point* in line with the *distributor's* policies and the *AEMO* "National Metering Identifier Procedure" (refer to Flowchart 7 – Initial Connection – High Voltage Installation in Responsibilities Section).

9.8. Offer of Supply Letter and/or Network Connection Agreement

The *distributor* will negotiate a connection agreement detailing the conditions for the high voltage supply. This correspondence will include network requirements and the responsibility for providing the *high voltage metering*.

9.9. Connection point

Refer to Clause 5.2.2 for *connection point* arrangements.

The revenue metering point shall be located as close as practicable to the *connection point*.

9.10. Revenue Metering

The arrangement for the high voltage revenue metering installation will be determined during the connection enquiry and application process:

- (a) A Type 1-3 metering installation; as required for HV connections is an unregulated distribution service in Queensland and the *customer* is responsible for supplying, installing, maintaining and testing the metering installation including the instrument transformers.
- (b) The metering installation contains the metering current transformers and the metering voltage transformers (revenue metering instrument transformers). Wherever practicable this equipment shall be located within the *customer's* installation and be accessible to the *metering provider*. The metering installation shall comply with the requirements outlined in the AEMO Metrology Procedure Part A and the National Electricity Rules Chapter 7 and be approved by the *metering coordinator*.
- (c) The *customer* shall provide revenue metering instrument transformers, associated equipment and plant. The equipment must be ready for the nominated *metering provider* to connect metering and communication equipment.
- (d) Revenue metering instrument transformers will remain the *customer's* property, and the *customer* will be responsible for maintaining, servicing and if failure occurs, replacing the metering instrument transformers in accordance with the requirements of the National Electricity Rules.

Note: Any fault or defect is required to be rectified within 2 business days or the *metering coordinator* must obtain an exemption from AEMO.

- (e) The revenue metering instrument transformers are to be specified, installed, tested and maintained in accordance with the requirements of the National Electricity Rules, relevant Australian Standards (AS/NZS 3000 (Wiring Rules), AS 2067, AS 1243, AS 60044 series) and the QECM
- (f) Instrument Transformer test certificates in accordance with the requirements of the National Electricity Rules Schedules 7.2 and 7.3 shall be provided to the *metering provider* prior to installation of the equipment.
 - i) Where revenue metering instrument transformers are tested in Australia, endorsed reports from a laboratory accredited by NATA are required; or
 - ii) Where revenue metering instrument transformers are tested overseas, endorsed reports from a laboratory accredited by an organisation recognised by ILAC (International Laboratory Accreditation Cooperation) are required.
- (g) Metering installation designs that are approved by a *metering provider* or *metering coordinator* shall also be provided to the *distributor* prior to connection. The *customer* shall supply a single line diagram, HV switchboard layout, and a schematic diagram showing the wiring details from the instrument transformers (current and voltage transformers) to the metering panel.
- (h) The *customer* is required to supply, install and test the secondary wiring and meter enclosure/panel and terminate the secondary wiring at the meter panel and the metering instrument transformers.
- (i) The *customer* is responsible for ensuring that all requirements and steps in the metering installation process are coordinated in an efficient and timely manner to allow supply to be connected when required.
- (j) The *customer* shall provide readily accessible high voltage test points on either side of the metering instrument transformers, in the specification/design of

their switchgear. This will enable the *metering provider* to conduct the periodic high voltage metering instrument transformer accuracy tests (e.g. primary injection tests), required by the National Electricity Rules, with minimal power outages and disruption to the *customer* and their equipment.

- (k) For metering installations greater than 1000 GWh pa per connection point, the current transformer core and secondary wiring associated with the meter(s) shall not be used for any other purpose unless otherwise agreed by AEMO.
- (l) For metering installations less than 1000 GWh pa per connection point the current transformer core and secondary wiring associated with the meter(s) may be used for other purposes (e.g. local metering or protection) provided the *metering coordinator* demonstrates to the satisfaction of AEMO that the accuracy of the metering installation is not compromised and suitable procedures/measures are in place to protect the security of the metering installation.
- (m) The metering voltage instrument transformers may be used to supply *customers* metering at the discretion and approval of the *metering provider* on a case by case basis. The secondary voltage supply from the voltage transformers will be separately fused with fuses located in an accessible position as near as practicable to the voltage transformer secondary connection. The revenue metering instrument transformers' secondary wiring is to be earthed at one point only in accordance with the *metering provider's* requirements.
- (n) The minimum spacing between the meter wiring and other current carrying conductors shall comply with QEMM
- (o) Adequate and safe access must be provided for the installation, routine and corrective maintenance of revenue metering equipment in accordance with AEMO requirements.

9.11. Meter Enclosure

The following requirements apply to *high voltage metering* enclosures:

- (a) Unless otherwise detailed in the supply agreement the *customer* must supply a pre-wired meter panel and enclosure to the requirements of the *metering provider*. Wiring diagrams can be obtained from the *metering provider*.
- (b) Any metering enclosure mounted externally must have an appropriate IP rating and be positioned so that adequate mechanical protection is provided.
- (c) A hinged panel with minimum dimensions of 600mm x 600mm is required for the mounting of meters and metering test block on the same vertical surface.
- (d) A metering enclosure installed on a pole in association with a *distributor* owned metering unit, will be supplied and maintained by the *distributor*.
- (e) No *customer* owned equipment is to be installed within the *metering provider's* dedicated metering enclosure.
- (f) The supply and wiring of the meter panel may be carried out by the *metering provider* as part of a negotiated agreement.
- (g) The *customer* is responsible for earthing of the metering enclosure in accordance with relevant standards and practices including consideration for earth potential rise.
- (h) The *customer* should consider providing lockable front meter doors in locations where security may be an issue.

9.12. Secondary Wiring

The following requirements apply to metering units supplied by the *metering provider* and revenue metering instrument transformers owned and installed by the *customer*.

- (a) The *customer* shall supply and install the secondary wiring between the revenue metering instrument transformers and the test block or terminal strip.
- (b) Revenue metering instrument transformer secondary wiring is to follow the most direct route and the number of terminations and links must be kept to a minimum.
- (c) Revenue metering instrument transformer secondary wiring is to be PVC insulated stranded cable of no more than 7 strands.
- (d) The secondary wiring shall be sized to ensure that the burden on the revenue metering instrument transformers is not exceeded.
- (e) All taps of multi-tap CTs to be brought out to the marshalling box or metering enclosure (in the absence of a marshalling box).
- (f) Any connection point in the revenue metering instrument transformers' secondary circuit (terminals, links, fuses etc.) that is accessible must be identified as "Revenue Metering" and must be able to be covered and sealed.

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK

APPENDIX A - SPECIFICATION FOR METALLIC ENCLOSURES FOR METERS IN DIRECT CONNECTED INSTALLATIONS

Foreword

This specification provides for metallic enclosures only. The use of other materials, such as fibreglass or plastic is subject to the approval of the *distributor*. In such cases, the general requirements of this specification may provide guidance.

A.1 Scope and General

A.1.1 Scope

This specification provides standard requirements for metallic enclosures for revenue meters and control equipment used in Direct Connected installations.

A.1.2 Definitions

A.1.2.1 *Approved* - means approved by the *metering provider*.

A.1.2.2 *Direct Connected Installation* - means an installation that is metered by Direct Connected meters.

A.1.2.3 *Meter Enclosure* - means an enclosure used for the purpose of housing revenue metering equipment.

A.1.2.4 *Meter Panel* - means a panel to be mounted in the meter enclosure and on which metering equipment is fixed.

A.1.2.5 *Metering Equipment* - means the equipment used for measuring or controlling the supply of electrical energy.

A.1.2.6 *Weatherproof* - means so constructed and installed as to exclude rain, hail and external splashing so that the safe and efficient operation of the equipment contained therein shall not be impaired. (e.g. IP23).

A.2 Design and Construction

A.2.1 Materials

The meter enclosure may be constructed from the following:

MATERIAL	MINIMUM THICKNESS (mm)
Mild Steel	Enclosure Type A 1.0 Enclosure Type B 1.2
Aluminium	To be equivalent in strength and rigidity to the above mild steel requirements
Other Materials	To be approved

A.2.2 Construction

- A.2.2.1** The enclosure should be constructed free of burrs at the opening.
- A.2.2.2** The enclosure, if of steel construction, shall be of galvanised or zincalume material and shall comply with the requirements of AS 1397 "Steel sheet and strip - hot dip zinc-coated or aluminium/zinc-coated".
- A galvanised steel meter enclosure shall have all galvanised surfaces repaired with a suitable zinc rich coating. All exterior surfaces of the enclosure should be painted with one coat of "etch primer".
- A.2.2.3** The use of aluminium shall be restricted to corrosion resistant alloys as recommended for the exposure to be encountered in service (stainless steel is an acceptable alternative).
- A.2.2.4** Rivets shall be of a material that is compatible with the case material and must not react to set up points of corrosion.
- A.2.2.5** Where additional mechanical strength is required stiffening ribs may be utilised. Such ribs must not in any way reduce the minimum internal dimensions.

A.2.3 Door

- A.2.3.1** The meter enclosure is to be fitted with a hinged door of sufficient strength to prevent buckling or warping.
- A.2.3.2** The door shall be side hinged, unless otherwise approved by the *metering provider*, and fitted with a suitable non-corroding chain or other approved means to limit the door travel to approximately 100 degrees. The door may be hinged at either the left or right side of the meter enclosure and shall be fitted with a simple self-latching device.
- A.2.3.3** Hinges provided shall be of non-corroding material and so designed or fitted with non-corroding pins as to prevent seizing.

A.2.4 Door Latch

The latching device provided shall engage automatically and hold the door firmly closed.

A.2.5 Entry of Wiring

Adequate provisions shall be made for knockouts or slots for the entry of wiring to the meter enclosure. (Refer to AS/NZS 3000 (Wiring Rules) for fire protection requirements).

Entries may be provided in the top of the enclosure but in this case the final assembly should withstand the test in Appendix A Clause 2.7.

A.2.6 Earthing

To ensure an effective Earth of the Switchboard Surround an earthing stud or terminal complying with the requirements of AS/NZS 3000 (Wiring Rules) shall be provided for the connection of an earthing conductor within the enclosure. The stud or terminal shall not obstruct equipment within the enclosure.

A.2.7 Weatherproofing

The enclosure is to comply with AS/NZS 60529 "Degrees of Protection Provided by Enclosures" to a minimum of IP23.

The enclosure shall provide adequate ventilation to minimise condensation and be capable of draining any moisture that may collect within the enclosure.

A.2.8 Meter Panel

A.2.8.1 Meter panels shall be constructed of durable, non-conducting, fire resistant material with low water absorption properties and shall not contain asbestos.

A.2.8.2 The meter panel shall be side hinged on a vertical axis so that the metering equipment always remains in the vertical plane.

A.2.8.3 Panel hinges should be of the double off-set type that allows for the panel to be swung into the fully opened position and shall be of adequate strength to support the meter panel, and associated metering equipment.

The hinges shall be constructed of a suitable non-corroding material. When the meter panel is opened at an angle of 90 degrees, the design of the enclosure and hinges should be such to withstand without undue distortion a weight of 25kg suspended vertically at a position 25mm from the outer edge of the panel.

A.3 Dimensions

A.3.1 General

Two basic types of meter enclosures are provided for, the dimensions of which are to be suitable for recessing into brick, block or framed walls. Other meter enclosures of adequate size to house the meters with recommended clearances and suitable construction may be used. The meter panel must meet the minimum size set out in the table below. This table is indicative of the most commonly supplied metering enclosures that comply with the QECM.

Metal Enclosure	Minimum Thickness Mild Steel	Minimum Space Required For Metering Equipment	Clearance From Back of Meter Panel to Back of Enclosure	Clearance From Back of Meter Panel to Inside of Door
Type A	1.0mm	480mm x 460mm (high) (wide)	75mm	185mm
Type B	1.2mm	600mm x 550mm (high) (wide)		

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK.

APPENDIX B - GLOSSARY OF TERMS

Accredited Auditor	<p>A person appointed under section 129 of the <i>Electrical Safety Act 2002</i> to audit high voltage or hazardous area installations before connection to supply.</p> <p>Further information may be obtained from the Electrical Safety Office.</p>
AEMO	<p>‘Australian Energy Market Operator’ is responsible for the day to day management of wholesale and retail energy market operations and emergency management protocols; on-going market development required to incorporate new rules, infrastructure and participants; and long term market planning through demand forecasting data and scenario analysis.</p>
AF Receiver	<p>See “Network Device”</p>
Capital Contribution	<p>A contribution towards costs associated with a standard control service, such as any necessary augmentation of connection assets at the connection point, dedicated network extension or augmentation of the shared distribution network to accommodate the connection/modification. A capital contribution will only be levied where there is a difference between the cost to provide the connection service and the revenue that will be earned by the <i>distributor</i> from the connection service.</p>
Card Operated Meter	<p>A meter that contains control equipment that switches on and off in accordance with the amount of credit stored in the meter.</p>
Common Property	<p><i>Common property</i> means so much of a parcel as from time to time is not comprised in any lot. <i>Building Units and Group Titles Act 1980</i></p>
Connection Point	<p>The agreed point of supply established between Network Service Provider(s) and another Registered Participant, Non-Registered <i>Customer</i> or franchise <i>customer</i>.</p> <p>Note (1): AS/NZS 3000 refers to the ‘<i>Connection Point</i>’ as the ‘<i>Point of Supply</i>’. Previous editions of AS/NZS 3000 referred to the ‘<i>Connection Point</i>’ as the ‘<i>consumer’s terminals</i>’.</p> <p>Note (2): The <i>Queensland Electricity Regulation 2006</i> uses the definition ‘<i>consumer’s terminals</i>’.</p> <p>Note (3): The <i>National Electricity Rules</i> uses the definition ‘<i>connection point</i>’.</p> <p>Note (4): This is the point which differentiates the responsibilities of the Network Service Provider and the application of AS/NZS 3000.</p>
Connection Policy	<p>The <i>distributor’s</i> connection policy provides an outline of connection services, when connection charges may be payable by <i>customers</i> and how those charges are calculated.</p>
Consumer’s Mains	<p>The conductors between the <i>connection point</i> and the main switchboard.</p>
Consumer’s Terminals	<p>See <i>connection point</i>.</p>

Controlled Load, Controlled Supply	Those loads that are wired separately from other appliances, are controlled by means of frequency injection receiver or time clock, and are separately metered from the remaining load at the metering point.
Current Transformer Metering	A metering arrangement where electricity flow is measured by a meter using current transformers (CTs).
Customer	A person, including a relevant body corporate, who receives, or wants to receive, a supply of electricity for a <i>premises</i> from an electricity entity or special approval holder.
Direct Connected Meter	A meter where the electricity flow is directly measured by the meter i.e. the current under measurement passes through the meter itself.
Distribution Entity, Distributor	A distribution entity is a person who holds a distribution authority that authorises its holder to supply electricity using a supply network within its distribution area. See sections 37, 38 and 39 of the <i>Queensland Electricity Act 1994</i> . (Refer to definition for Relevant Distribution Entity).
EG system (s)	One or more electricity generating units and auxiliary equipment that are <i>interconnected</i> with a <i>distributor's</i> network.
Electrical Contractor (EC)	A person licensed under the <i>Electrical Safety Act 2002</i> to conduct a business or undertaking that includes the performance of electrical work.
Electrical Work Request (EWR)	The request from the <i>customer's</i> electrical contractor to a <i>distributor</i> to perform a distribution service e.g. (i) Energex - Form 2; or (ii) Ergon Energy - Form A - <i>Request for Initial Connection, Metering Change or Service Alteration</i>
Energex	Energex Limited - ABN 40 078 849 055
Enhanced Metering	A scheme, which is not normally considered to be part of standard metering as described in this manual (e.g. has pulse inputs, outputs, or remote communications). Additions that are above and beyond the metering provided in this manual.
Ergon Energy	Ergon Energy Corporation Limited ABN 50 087 646 062
EVSE	Electric Vehicle Supply Equipment as defined in AS/IEC 62196
Excluded Customer	A <i>customer</i> who cannot choose their <i>retailer</i> . For example, <i>customers</i> connected to isolated power systems.
Gross Energy Scheme	The <i>Gross Energy Scheme</i> separately meters the full energy output of the <i>Micro EG Unit</i> . The energy consumed at the <i>premises</i> is metered normally.
High Voltage Metering	A high voltage metering arrangement where electricity flow is measured by a meter using current transformers and voltage transformers.

Interconnected	Connection of an <i>EG system</i> capable of parallel operation with a <i>distributor's</i> network.
Isolated Power System	A supply network that does not form part of and is not connected to the national grid and may include an isolated feeder.
Large Customer	A <i>customer</i> whose annual consumption is equal to, or greater than, 100MWh, and is connected to the distributor's network.
Large Non-market Customer	A <i>large non-market customer</i> , for <i>premises</i> , is a <i>large customer</i> for the <i>premises</i> who is also a non-market <i>customer</i> for the <i>premises</i> .
Metering Coordinator	A person who has been registered by AEMO under Chapter 2 of the <i>National Electricity Rules</i> to engage in the coordination and provision of metering services at a connection point in accordance with Chapter 7 of the <i>National Electricity Rules</i> .
Metering Data Agent	An agent appointed by <i>AEMO</i> to undertake the collection, processing and transfer of metering data to <i>AEMO</i> and other registered participants.
Metering Data Provider	A person who meets the requirements listed in schedule 7.3 of the <i>National Electricity Rules</i> and has been accredited and registered by AEMO to undertake the collection, processing, storage and delivery of metering data and the management of NMI Standing Data.
Metering Provider (MP)	<p>A person who meets the requirements listed in schedule 7.2 of the <i>National Electricity Rules</i> and has been accredited and registered by AEMO to undertake the provision, installation and maintenance of metering installations.</p> <p>Note: The <i>distributor</i> is the <i>metering provider</i> in <i>non-NEM</i> areas.</p>
Micro EG Unit	A grid connected Micro Embedded Generating Unit as defined in AS/NZS 4777.1.
NATA	The National Association of Testing Authorities.
National Electricity Rules	The rules under which the National Electricity Market operates.
National Metering Identifier (NMI)	A <i>National Metering Identifier (NMI)</i> is a unique national identifier that relates to the metering installation at a <i>customer's premises</i> .
Net Energy Scheme	The <i>Net Energy Scheme</i> provides for the separate measurement of the energy supplied from the LV network to the <i>customer's</i> installation in excess of the <i>Micro EG Unit</i> generation, and the excess energy supplied to the LV network from the <i>premises</i> by the <i>Micro EG Unit</i> after the energy needs at the <i>premises</i> are met.

Network Device, AF Receiver	Apparatus or equipment that: (a) enables a <i>distributor</i> to monitor, operate or control the network for the purposes of providing network services, which may include switching devices, measurement equipment and control equipment; and (b) is located at or adjacent to a metering installation at the connection point of a <i>customer</i> .
NMI Classification	Small - annual consumption less than 100MWh Large - annual consumption equal to, or greater than 100MWh.
Point of Attachment	The point at which aerial conductors of a <i>service line</i> or aerial <i>consumer's mains</i> are terminated on a <i>customer's</i> structure.
Point of Entry	The point at which the <i>consumer's mains</i> or the underground service cable enters a structure.
Premises	<i>Premises</i> includes - (a) a building or other structure; and (b) a part of a building or other structure; and (c) land where a building or other structure is situated. <i>Premises, of a customer, means premises owned or occupied by the customer. Queensland Electricity Act 1994</i>
QECM	Queensland Electricity Connection Manual
QECMM	Queensland Electricity Connection and Metering Manual. On 24 th August 2018 the QECMM content was separated into two new documents, the QECM and the QEMM and the QECMM was withdrawn.
QEMM	Queensland Electricity Metering Manual
Relevant Distribution Entity, Distributor	The <i>relevant distribution entity</i> for a <i>premises</i> , means the <i>distribution entity</i> to whose supply network the <i>premises</i> are, or will be, connected. Note: For the purposes of this document the relevant <i>distribution entity</i> will be referred to as the ' <i>distributor</i> '.
Relevant Retail Entity, Retailer	The <i>relevant retail entity</i> for a <i>premise</i> , means the retail entity who, under a retail contract, supplies or has agreed to supply electricity to the <i>premises</i> . Note: For the purposes of this document the <i>relevant retail entity</i> will be referred to as the ' <i>retailer</i> '.
Retail Entity	A person who holds a retail authority to sell electricity and retail services (a 'retail authority' authorises its holder to provide <i>customer</i> retail services under the terms of the authority).
RPEQ	Registered Professional Engineer Queensland.

Rural/Isolated Area	<p>A <i>rural/isolated area</i> is defined as one with a density of less than 5 lots per hectare (i.e. would generally have a dedicated supply transformer).</p> <p>Note: This definition is only applicable within the <i>Ergon Energy</i> distribution area.</p>
Service Line	<p>An electric line that-</p> <ul style="list-style-type: none">(a) forms part of the works of an electricity entity; and(b) connects <i>consumer terminals</i> to -<ul style="list-style-type: none">(i) other parts of the works of the electricity entity; or(ii) the works of another electricity entity. <p>Schedule 9 of the <i>Queensland Electricity Regulation 2006</i>.</p>
Small Customer	<p>A <i>customer</i> who consumes less than 100MWh per annum and is connected to the <i>distributor's</i> network.</p>
SOR	<p>Service Order Request - This is a request from a <i>Retailer</i> to a <i>Distributor</i> to perform a distribution service (e.g. New Connections, Metering Alterations and Service Upgrades). It is also referred to as a B2B request.</p>
Suitable Mains Connection Box	<p>A mains connection box that is deemed to be compliant with the <i>distributor's</i> technical specifications. Details are available by contacting the <i>distributor</i> via the methods listed on page 1</p>
Two element Meter	<p>A single phase two element device which includes both metering and load switching within one meter.</p>
Type 1-7 Metering Installation	<p>As defined in the National Electricity Rules</p>
Unmetered Supply	<p>A Type 7 metering installation classification (<i>NER</i>) where a metering installation does not require a meter to measure the flow of electricity in a power conductor and accordingly there is a requirement to determine by other means the energy data that is deemed to flow in the power conductor and managed by the relevant Distribution Entity.</p>
Urban	<p>A residential area with a system of street lighting.</p>

THIS PAGE HAS BEEN DELIBERATELY LEFT BLANK.

APPENDIX C - AMENDMENT RECORD

Please note: It is not possible to cover all of the changes in the following list, nor can the changes be covered in the detail and context as they appear within the manual. As an *Electrical Contractor* it is the responsibility of you and your endorsees to be fully conversant with the content and requirements of the Queensland Electricity Connection Manual.

Date 24/08/18 Previous Version: Version 12 of the QECMM

Version 1 update includes the separation of the metering component from this manual to the QEMM. Additionally, clauses have been rearranged to group similar items together. Changes are extensive and have not been included in detail in this Appendix.



Part of the Energy Queensland Group

ergon.com.au

energex.com.au

PO Box 1090, Townsville QLD 4810

GPO Box 1461, Brisbane QLD 4001

Ergon Energy Network
ABN 50 087 646 062

Energex is the trading name of
Energex Limited
ABN 40 078 849 055