



3. FAQ

Q1. What racks can I order?

A1. Only new racks can be ordered.

Q1. Are the new racks backward compatible?

A1. Yes.

Q2. I've already ordered an old rack what happens?

A2. In conjunction with procurement Sub Standards are managing all orders of the old stock codes. There are only a limited number of existing orders.

Q3. Do I replace the existing rack in a modular building?

A3. No, unless you notice issues with the floor. If you do observe issues with an existing floor Substation Civil Design should then be contacted before proceeding.

Q3. What issues do the old racks cause with the floor?

A3. The point loads of the old base can cause buckling of the floor panel in modular substations.

4. Deployment Expectations

It is the Asset Standards expectation that best endeavours be applied to the implementation of this change. It is expected that the new standard is fully adopted for all new designs.

5. Further Information

For further information, please contact Greg Carlill, 3664 4948, (greg.carlill@energyq.com.au)