

Draft Project Assessment Report



Pittsworth Regional Reinforcement

This document describes the *identified need* for investment at Broxburn substation and the preferred option for addressing the identified need.

Publication Date: 7 April 2020

Consultation Period Starts: 7 April 2020

Consultation Period Closes: 29 May 2020

Disclaimer

While care was taken in preparation of the information in this **Draft Project Assessment Report**, and it is provided in good faith, Ergon Energy Corporation Limited accepts no responsibility or liability for any loss or damage that may be incurred by any person acting in reliance on this information or assumptions drawn from it. This document has been prepared for the purpose of inviting information, comment and discussion from interested parties. The document has been prepared using information provided by a number of third parties. It contains assumptions regarding, among other things, economic growth and load forecasts which may or may not prove to be correct. All information should be independently verified to the extent possible before assessing any investment proposal.

Executive Summary

ABOUT ERGON ENERGY

Ergon Energy Corporation Limited (Ergon Energy) is part of the Energy Queensland Group and manages an electricity distribution network which supplies electricity to more than 740,000 customers. Our vast operating area covers over one million square kilometres – around 97% of the state of Queensland – from the expanding coastal and rural population centres to the remote communities of outback Queensland and the Torres Strait.

Our electricity network consists of approximately 160,000 kilometres of powerlines and one million power poles, along with associated infrastructure such as major substations and power transformers.

We also own and operate 33 stand-alone power stations that provide supply to isolated communities across Queensland which are not connected to the main electricity grid.

IDENTIFIED NEED

Broxburn 33/11kV substation (BROX) has two 5MVA 33/11kV transformers supplying the township of Pittsworth and surrounding rural areas including some relatively significant chicken farm loads. Peak demand was 10.46MVA in February 2018 which exceeded the substation nameplate capacity and is expected to exceed the emergency cyclic capacity by 2022.

The two transformers at BROX were manufactured in the 1960s (58yrs old) and the Condition Based Risk Management (CBRM) methodology calculates the end of life of the transformers at 2025 and 2029 respectively. Neither transformer has bunding or oil containment systems posing an environmental risk for aged transformers in poor condition. Adding to this, the transformers are of an unusually narrow configuration. This is problematic because if a failure occurs they cannot be replaced with any Ergon Energy standard transformers or contingency spares due to lack of clearance to the bus. There are also a large number of high voltage switches that have reached their end of life, and the protection scheme does not meet current standards.

Based on load forecasts, the substation is expected to exceed its emergency cyclic capacity with both transformers in service by 2022. Without addressing these emerging constraints proactively, during peak load times this will result in forced load shedding.

A significant number of primary plant is at the end of life as determined by the CBRM methodology. If this aged equipment is not replaced before the nominated end of life there will be an increased likelihood of plant failure. As well as presenting safety risks, the unplanned, sporadic and uncontrolled nature of such failures increases the costs of rectification. The proposed investment under this project addresses these limitations in an economic, efficient and safe manner.

APPROACH

The National Electricity Rules (NER) require that, subject to certain exclusion criteria, network business investments for meeting service standards for a distribution business are subject to a Regulatory Investment Test for Distribution (RIT-D). Ergon Energy has determined that network

investment is essential in this case for it to continue to provide electricity to the consumers in the Pittsworth supply areas in a reliable, safe and cost-effective manner. Accordingly, this investment is subject to a RIT-D.

Ergon Energy published a Non-Network Options Report for the above described network constraint on 1 July 2019. No submissions were received by the closing date of 10 January 2020.

Given the number of issues faced at BROX, only one potentially feasible option has been identified and investigated:

- Install a 10MVA skid-mounted substation at Broxburn substation: \$6,865,316

This is a Draft Project Assessment Report (DPAR), where Ergon Energy provides both technical and economic information about the internal options in accordance with the requirements of clause 5.17.4(i). Ergon Energy's preferred solution to address the identified need is to install a 10MVA skid-mounted substation at the Broxburn Substation site.

The DPAR seeks information from interested parties about possible alternate solutions to address the identified need.

Submissions in writing are due by **29 May 2020 by 4:00 PM** and should be lodged to Ergon Energy's Demand Management Inbox below.

Any inquiries about this RIT-D may also be sent to:

E: demandmanagement@ergon.com.au

P: 13 74 66

Table of Contents

Executive Summary	1
1. Introduction	6
1.1 Structure of the report	6
1.2 Contact Details	6
2. Background.....	7
2.1. Existing Substation Capacity.....	8
2.2. BROX Substation Load Profile and Forecast	8
3. Identified Need.....	10
3.1. Description of the Identified Need	10
3.1.1 Aged and poor condition assets.....	10
3.1.2 Future substation capacity	10
3.2. Quantification of the Identified Need	11
3.2.1 Capacity constraint	11
3.2.2 Reliability	11
3.2.3 Risk management.....	11
3.3. Assumptions in Relation to Identified Need.....	11
3.3.1 Load Profile	11
3.3.2 Forecast Maximum Demand	11
3.3.3 System Capability – Transformer capacity	12
4. Non-Network Alternatives	12
4.1. Feasible vs Non-Feasible Options	12
4.1.1 Potentially Feasible Options	12
4.1.2 Options that are unlikely to be feasible	12
4.1.3 Timing of feasible options	13
5. Technical requirements of the solution.....	13
5.1. Substation Capacity.....	13
5.2. Aging Plant and Equipment.....	13
5.3. Compliance with Regulations and Service Standards	13
5.3.1 Minimum Service Standards	13
5.3.2 Safety Net.....	14

5.4. Land and proximity to Substation	14
6. Internal Options Identified	15
6.1. Scope of the Preferred Internal Option.....	15
6.2. Options considered but rejected	16
7. Summary of Submissions Received in Response to the Non-Network Options Report	17
8. Market Benefits.....	17
9. Economic Analysis.....	18
10. Submissions and Next Steps.....	18
10.1. Submissions from Solution Providers	18
10.2. Next Steps.....	19
11. Compliance Statement	20
Appendix A - Risk Assessment at Broxburn substation	21
Appendix B - Internal Assessment for Non-network Alternatives.....	22
Appendix C – Ergon Energy’s Minimum Service Standards and Safety Net Targets.....	25
Appendix D – The RIT-D Process	26
Appendix E - Glossary of Terms	27

List of Figures and Tables

Figure 1: Overview of the 33KV subtransmission network from Yarranlea T10	7
Figure 2: Geographic view of existing network arrangement	8
Figure 3: BROX substation historical load.....	9
Figure 4: BROX load duration curve.....	9
Figure 5: BROX substation forecast.....	10
Figure 6: BROX substation land and site dimensions.....	14
Figure 7: BROX SLD with proposed skid substation	16
Table 1: BROX transformer ratings	8
Table 2: Safety Net restoration times. BROX is classified rural area.	14
Table 3: Ergon Energy's internal cost for the preferred option.....	15
Table 4: Timetable for this RIT-D	19
Table 5: SAIDI (minutes per customer) and SAIFI (interruptions per customer) limits	25
Table 6: Ergon Energy Safety Net Targets.....	25

1. Introduction

This DPAR has been prepared by Ergon Energy in accordance with the requirements of clause 5.17.4(e) of the National Electricity Rules (NER).

This report represents the second stage of the consultation process in relation to the application of the Regulatory Investment Test for Distribution (RIT-D) on potential credible options to address the identified need for BROX.

In preparing this RIT-D, Ergon Energy is required to consider reasonable future scenarios. With respect to major customer loads and generation, Ergon Energy has, in good faith, included as much detail as possible while maintaining necessary customer confidentiality. Potential large future connections that Ergon Energy is aware of are in different stages of progress and are subject to change (including outcomes where none or all proceed). These and other customer activity can occur over the consultation period and may change the timing and/or scope of any proposed solutions.

1.1 Structure of the report

This report:

- Provides background information on the network capability limitations of the distribution network supplying the Pittsworth area.
- Identifies the need which Ergon Energy is seeking to address, together with the assumptions used in identifying and quantifying that need.
- Describes the credible options that Ergon Energy currently considers may address the identified need, including for each:
 - Its technical definitions;
 - The estimated commissioning date; and
 - The total indicative cost (including capital and operating costs)
- Sets out the technical characteristics that a non-network option would be required to deliver in order to address the identified need.
- Is an invitation to registered participants and interested parties to make submissions on credible options to address the identified need.

1.2 Contact Details

For further information and inquiries please contact:

E: demandmanagement@ergon.com.au

P: 13 74 66

2. Background

Pittsworth is a township southwest of Toowoomba known for its agricultural and animal industries. Electricity is supplied to 2,877 customers which comprises of 2,258 domestic and 619 industrial loads. These customers are supplied by substations at Broxburn (BROX) and Yarranlea South (YASO). The 33kV subtransmission supply comes from Yarranlea T10 (YARA T10) 110/33kV bulk supply point that also supplies the substations Norwin (NORW), Cecil Plains (CEPL), Pampas (PAMP), and Millmerran (MILM). Figure 1 and Figure 2 below provide an overview of the subtransmission network in the region and the location of Broxburn substation.

YARA T10 110/33kV and PAMP 33/11kV show capacity constraints in an N-1 contingency which are addressed in other projects outside the scope of this report. The 33kV subtransmission network is not constrained until past the 2028 forecast.




Figure 1: Overview of the 33KV subtransmission network from Yarranlea T10




Figure 2: Geographic view of existing network arrangement

2.1. Existing Substation Capacity

Table 1: BROX transformer ratings

ZS	Transformer	Nameplate Rating (MVA)	kV	YOM	Cooling	NCC	ECC
BROX	1	5	33/11	1962	ONAN	5.5	5.8
BROX	3	5	33/11	1966	ONAN	5.5	5.8

2.2. BROX Substation Load Profile and Forecast

As shown in Figure 3, BROX load is currently breaching N-1 ECC and is approaching substation NCC and ECC. Peak demand was 10.46MVA in February 2018.

The annual load duration curve for BROX shown in Figure 4 illustrates that currently when either transformer is out of service, substation load exceeds the N-1 ECC rating 7.5% of the time. This is equivalent to 657 hours annually.




Figure 3: BROX substation historical load




Figure 4: BROX load duration curve

Figure 5 is the load forecast at BROX and shows an abrupt increase in demand in 2019 and 2022 due to two customer connection applications.

It can be seen that the N-1 ECC rating of the substation is currently being exceeded and that by year 2022, the NCC and ECC (with both transformers in service) ratings will be exceeded as well.




Figure 5: BROX substation forecast

3. Identified Need

3.1. Description of the Identified Need

3.1.1 Aged and poor condition assets

The two power transformers at BROX substation and a number of high voltage switches are approaching the end of life as determined by the CBRM methodology. If this aged equipment is not replaced before the nominated end of life, there will be an increased likelihood of plant failure. As well as presenting safety risks, the unplanned, sporadic and uncontrolled nature of such failures increases the costs of rectification.

The power transformers don't have any oil containment systems around them, which presents an environmental risk in case of an oil leak. The protection scheme also does not conform to current standards.

3.1.2 Future substation capacity

Based on load forecasts, the substation is expected to exceed its normal cyclic and emergency cyclic capacities with both transformers in service by 2022. Without addressing these emerging constraints proactively, during peak load times this will result in forced load shedding.

3.2. Quantification of the Identified Need

3.2.1 Capacity constraint

Ergon Energy has to ensure that there is sufficient capacity to enable customers to connect new loads and to avoid customer load shedding during peak demand. Loads at BROX are forecast to exceed the normal cyclic and emergency cyclic capacities of its transformers in 2022 with both transformers in service. Without addressing these emerging constraints proactively, during peak load times this will result in forced load shedding as well as the inability to connect new customers.

3.2.2 Reliability

The second objective of this investment is to maintain the reliability of customer supply by managing network assets at BROX.

3.2.3 Risk management

The final objective of the investment in this part of the network is to mitigate all risks identified to As Low As Reasonably Practicable (ALARP). Refer to Appendix A - Risk Assessment at Broxburn substation.

3.3. Assumptions in Relation to Identified Need

Below is a summary of key assumptions that have been made when the identified need has been analysed and quantified. It is recognised that the below assumptions may prove to have various levels of correctness, and they merely represent a 'best endeavours' approach to predict the future identified need.

3.3.1 Load Profile

Characteristic peak day load profiles shown in Section 2 are unlikely to change significantly from year to year, i.e. the shape of the load profile will remain virtually the same with increasing maximum demand.

3.3.2 Forecast Maximum Demand

It has been assumed that peak demand at BROX substation will grow as per the base case load forecast.

Factors that have been taken into account when the load forecast has been developed include the following:

- load history
- known future developments (new major customers, network augmentation, etc.)
- temperature corrected start values (historical peak demands)
- forecast growth rates for organic growth

3.3.3 System Capability – Transformer capacity

Transformer ratings are normally specified by a continuous rating, supplied by the manufacturer on the nameplate. This corresponds to the load that will cause the oil and winding temperature rise to meet the specified limit, assuming a constant temperature and a constant rated load.

Cyclic ratings in excess of nameplate ratings are possible because the typical load cycle is not continuous, nor is the daily temperature cycle. Each transformer also has a typical thermal time constant of a few hours. All these factors are combined to enable cyclic loading of a transformer in excess of the nameplate rating before the temperature limits are reached.

Each transformer has two cyclic ratings for both summer and winter, based on the load profile and the ambient temperature for that transformer location.

4. Non-Network Alternatives

Ergon Energy's Demand and Energy Management (DEM) team has conducted an internal assessment of the potential for non-network alternatives. Their assessment is available at Appendix B - Internal Assessment for Non-network Alternatives.

4.1. Feasible vs Non-Feasible Options

4.1.1 Potentially Feasible Options

The identified need presented in this RIT-D report is driven by the limitation in transformer capacity and the near end of life of plant which are necessary for the reliable supply of electricity. As such, solutions that cost-effectively address the capacity and end-of-life plant at BROX through augmentation and/or replacement within the required parameters are likely to represent reasonable options. Any option must also address the objectives to mitigate environmental and safety risks to ALARP.

A non-exhaustive list of potentially feasible options includes:

- Additional transformer capacity to supply the forecast demand for the next 40-50 years.
- Replacement of plant nearing end-of-life.
- Providing demand management or generation strategies that postpone the required augmentation/replacement expenditure.

4.1.2 Options that are unlikely to be feasible

Without attempting to limit a potential proponent's ability to innovate when considering opportunities, some technologies/approaches are unlikely to represent a technically or financially feasible solution. Unproven, experimental or undemonstrated technologies are unlikely to be feasible if the:

- Option does not meet all of the objectives stated in Section 3
- Option requires completion beyond 2022.
- Options that do not meet or are unable to demonstrate they can meet the Service Standards of Ergon Energy.

4.1.3 Timing of feasible options

The consequence of not addressing aging plant and equipment and not meeting Safety Net is significant. As a result of this it is expected that for an option to be considered feasible it will be required to be completed, commissioned, accepted by Ergon Energy, and fully operational by 2022.

5. Technical requirements of the solution

A suitable solution to meet Ergon Energy's operational requirements should address the limitations in substation capacity, aging plant and equipment and identified network and safety risks at BROX. Ergon Energy is willing to consider other possible solutions which may be identified as part of the RIT-D process. The alternate non-network solutions must comply with a number of Ergon Energy standards which include, but are not limited to, Safety Net reliability standards, quality of supply, design and safety standards.

The following are general parameters to which a non-network option must comply with. It is expected that any proposed solution is in accordance with good electricity industry practices, such that a high reliability and availability solution is delivered.

5.1. Substation Capacity

The following pertains to substation capacity for any non-network solution:

1. Transformer capacity (or capacity) will be available to accommodate demand, large customer applications, and load forecast.
2. Capacity will be available in the event of transformer failure.
3. Capacity will be adequate when transferring load to another substation and/or source during contingency.

5.2. Aging Plant and Equipment

The existing plant at Broxburn is mostly 1960s era. A non-network option must address the risk to the network and plant and personnel from operating such plant which is at the end of its lifecycle (year of manufacture, use, end of life).

5.3. Compliance with Regulations and Service Standards

5.3.1 Minimum Service Standards

Under its Distribution Authority (DA) Ergon Energy is responsible for electricity supply to the Pittsworth area. The DA requires that Ergon Energy must:

- Comply with the Guaranteed Service Levels regime notified by the Queensland Regulator which includes reliability of supply to customers;
- Plan and develop its supply network in accordance with good electricity industry practice, having regard to the value that end users of electricity place on the quality and reliability of electricity services;
- Use all reasonable endeavours to ensure that it does not exceed in a financial year the Minimum Service Standards (System Average Interruption Duration Index and System Average Interruption Frequency Index limits) applicable to its feeder types; and

- Ensure, to the extent reasonably practicable, that it achieves its Safety Net targets (refer to Table 2).

5.3.2 Safety Net

The non-network option must satisfy the Safety Net reliability standard and meet the restoration times for loads not supplied during contingencies outlined in Table 2 below.

Table 2: Safety Net restoration times. BROX is classified rural area.

Safety Net – Load not supplied and maximum restoration time following a credible contingency	
Regional Centre	Rural Area
Less than 20MVA (8000 customers) after 1 hour; Less than 15MVA (6000 customers) after 6 hours; Less than 5MVA (2000 customers) after 12 hours; and Fully restored within 24 hours.	Less than 20MVA (8000 customers) after 1 hour; Less than 15MVA (6000 customers) after 8 hours; Less than 5MVA (2000 customers) after 18 hours; and Fully restored within 48 hours

5.4. Land and proximity to Substation

Ergon Energy owns some additional land at BROX (refer to Figure 6). Ergon Energy is open to discussions around the use of these lands as part of the non-network solution.



Figure 6: BROX substation land and site dimensions.

6. Internal Options Identified

Ergon Energy's preferred internal option is to install a skid transformer at BROX which will address capacity and aged plant limitations. The estimated project delivery timeframe has the target year for completion in 2022, prior to the forecast limitations at BROX.

Table 3 provides the approximate anticipated capital cost for the proposed solution. It is noted at the time of writing the RIT-D more detailed cost estimates are being performed which may cause some change to the below figures. Operating expenses¹ for new infrastructure are typically 0.5% of the capital cost.

Table 3: Ergon Energy's internal cost for the preferred option

Internal option	10MVA skid at Broxburn Substation
ACP	\$6,865,316

6.1. Scope of the Preferred Internal Option

The following works are proposed to be carried out as part of the preferred network solution at BROX:

- Extend BROX substation earth grid to accommodate the installation of a skid-mounted substation
- Install a standard 10MVA 33/11kV skid with 1 x 10MVA 33/11kV transformer (Dyn11), 1 x 33kV recloser, 3 x 11kV reclosers and 1 x 63kVA 11/0.415kV station service transformer
- Include provision for statistical and revenue metering
- Extend / rebuild substation security fence to include the new skid
- 11kV distribution works to pick up Springside, Pittsworth and Copps Hill 11kV feeders from the 10MVA skid-mounted transformer.
- Install communications cabling between skid and the existing control room

¹ Details of operating expenses have not been presented in this report due to the lack of other credible options and the need to do a comparative analysis.




Figure 7: BROX SLD with proposed skid substation

6.2. Options considered but rejected

Base Case / Do Nothing

This option has been rejected due to the risks involved (see Appendix A - Risk Assessment at Broxburn substation). The business as usual approach is to maintain the aging plant at BROX until plant failure occurs, which will occur most likely due to exceedance of plant capacity. The following outcomes are expected under this scenario:

- If a transformer fails during high load periods at either BROX, load shedding will be required in order to not exceed the emergency cyclic capacity of the remaining in-service transformer
- The forecast exceeds the substation N rating at BROX in year 2022. Once this occurs new customers may not be able to connect within normal timeframes. This may require the regulator to be notified and almost certainly will impact NECF timeframes
- In 2022 load on BROX is forecast to be approximately 13MVA with a substation ECC capacity of 11.6MVA. At this point in time additional customers will not be able to be connected.

No economic analysis of this option has been conducted as this option has been rejected due to the risk of non-compliance with Regulations and Service Standards (see Section 5.3).

7. Summary of Submissions Received in Response to the Non-Network Options Report

On 1 July 2019, Ergon Energy published the Non-Network Options Report providing details on the identified need at BROX substation. This report sought information from Registered Participants, AEMO and Interested Parties regarding alternative potential credible options or variants to the potential credible option presented by Ergon Energy.

In response to the Non-Network Options Report, Ergon Energy received no submissions by 10 January 2020, which was the closing date for submissions to the Non-Network Options Report.

8. Market Benefits

The purpose of the RIT-D is to identify the option that maximises the present value of net market benefits to all those who produce, consume and transport electricity in the National Electricity Market (NEM).

In order to measure the net market benefit or costs, Ergon Energy usually considers the following classes of market benefits:

- Value of customer reliability
- Voluntary load shedding / demand management
- Load transfer capability
- Network losses

In this RIT-D only one option has been identified that is credible and that meets all the technical requirements. This option is also considered the only economically equivalent solution that addresses the need. Accordingly, the above classes of market benefits are not considered material for the purposes of this RIT-D.

9. Economic Analysis

Only one credible network option has been identified which will meet all the technical parameters identified in Section 5 above. Furthermore, no non-network solutions have been received from the market as a result of the Non-Network Options Report. As there is no need to determine economic ranking of multiple options, a comparative Net Present Value (NPV) analysis has not been carried out in this report.

10. Submissions and Next Steps

10.1. Submissions from Solution Providers

Ergon Energy invites written submissions on this report from registered participants and interested parties.

Ergon Energy will not be legally bound in any way or otherwise obligated to any person who may receive this RIT-D report or to any person who may submit a proposal. At no time will Ergon Energy be liable for any costs incurred by a proponent in the assessment of this RIT-D report, any site visits, obtainment of further information from Ergon Energy or the preparation by a proponent of a proposal to address the identified need specified in this RIT-D report.

The RIT-D process is aimed at identifying a technically feasible non-network alternative to the internal option that has greater net economic benefits. However, the selection of the solution provider to implement the preferred option will be done in accordance with Ergon Energy's standards for procurement.

Submissions in writing are due by **29 May 2020 by 4:00 PM** and should be lodged to Ergon Energy's Demand Management Inbox below.

Any inquiries about this RIT-D may also be sent to:

E: demandmanagement@ergon.com.au

P: 13 74 66

10.2. Next Steps

Following Ergon Energy's consideration of submissions received in response to this report, the preferred option, and a summary of and commentary on any submissions received will be included as part of the Final Project Assessment Report (FPAR). The FPAR represents the final stage of the consultation process in relation to the application of the RIT-D.

Ergon Energy intends to publish the FPAR no later than 1 June 2020. Ergon Energy will use its reasonable endeavours to publish the FPAR by the above date. This may however not be achievable due to changing power system conditions or other circumstances beyond the control of Ergon Energy.

At the conclusion of the consultation process, Ergon Energy intends to take steps to progress the recommended solution(s) to ensure any statutory non-compliance is addressed and undertake appropriately justified network reliability improvement(s), as necessary.

Table 4: Timetable for this RIT-D

Step 1	Publish Non-Network Options Report (this report) inviting non-network options from interested participants	Date Released: 1 Jul 2019
Step 2	Consultation period	Concluded
Step 3	Release of Draft Project Assessment Report (DPAR)	7 Apr 2020
Step 4	Consultations in response to the DPAR	7 Apr 2020 – 29 May 2020
Step 6	Publish the Final Project Assessment Report (FPAR)	1 Jun 2020
Ergon Energy reserves the right to revise this timetable at any time. The revised timetable will be made available on the Ergon Energy RIT-D website.		

Ergon Energy will take all reasonable efforts to maintain the consultation schedule listed above. Due to various circumstances the schedule may change, however, up-to-date information will be available on Ergon Energy's RIT-D website:

<https://www.ergon.com.au/network/network-management/network-infrastructure/regulatory-test-consultations>

During the consultation period, Ergon Energy will review, compare and analyse all internal and external solutions. Detailed economic options analysis and comparisons of expected market benefits will be undertaken during this time. At the end of the consultation and review process Ergon Energy will publish a final report which will detail the most feasible option and proceed to implement that option.

11. Compliance Statement

This Draft Project Assessment Report complies with the requirements of NER section 5.17.4(j) as demonstrated below:

Requirement	Report Section
(1) a description of the identified need for investment;	3
(2) the assumptions used in identifying the identified need (including, in the case of proposed reliability corrective action, why the RIT-D proponent considers reliability corrective action is necessary);	3.3
(3) if applicable, a summary of, and commentary on, the submissions received on the NNOR;	7
(4) a description of each credible option assessed	6
(5) where a <i>Distribution Network Service Provider</i> has quantified market benefits in accordance with clause 5.17.1(d), a quantification of each applicable market benefit of each credible option	NA
(6) a quantification of each applicable cost for each credible option, including a breakdown of operating and capital expenditure	6
(7) a detailed description of the methodologies used in quantifying each class of costs or market benefit	NA
(8) where relevant, the reasons why the RIT-D proponent has determined that a class or classes of market benefits or costs do not apply to a credible option	8
(9) the results of a NPV analysis of each credible option and accompanying explanatory statements regarding the results	9
(10) the identification of the proposed preferred option	6
(11) for the proposed preferred option, the RIT-D proponent must provide: (i) details of the technical characteristics; (ii) the estimated construction timetable and commissioning date (where relevant); (ii) the indicative capital and operating costs (where relevant); (iv) a statement and accompanying analysis that the proposed preferred option satisfied the RIT-D; and (v) if the proposed preferred option is for reliability corrective action and that option has a proponent, the name of the proponent	6, 6.1
(12) contact details for a suitably qualified staff member of the RIT-D proponent to whom queries on the draft report may be directed.	1.2

Appendix A - Risk Assessment at Broxburn substation

Risk Category	Equipment	Risk Scenario	Inherent / Untreated Risks			Target (Residual)	
Customer	Other	Substation ECC breach at BROX results in > 1min changeover outage > 3 times in one week during high load times to allow Nomad load support connection.	C	L	Risk Score	L	Risk Score
			3	5	15 (Moderate)	1	3 (Very Low) ALARP
Customer	Transformer	Fault or Non-Spurious Trip on 33/11kV Transformer at BROX results in interruption >24 hours.	C	L	Risk Score	L	Risk Score
			4	4	16 (Moderate)	1	3 (Very Low) ALARP
Environment	Transformer	Catastrophic failure of a 33/11kV transformer at BROX results in an oil spill > 1000 litres that extends beyond the property boundary (transformers not bunded).	C	L	Risk Score	L	Risk Score
			4	3	12 (Moderate)	1	4 (Very Low) ALARP
Safety	Isolator / Insulator	Catastrophic failure of 33kV isolator at BROX results in serious injuries to multiple field workers or members of public.	C	L	Risk Score	L	Risk Score
			4	2	8 (Low)	1	4 (Very Low) ALARP
Safety	Transformer	Catastrophic failure of 33/11kV transformer at BROX results in serious injuries to multiple field workers or members of public. Likelihood based on condition, loading and history	C	L	Risk Score	L	Risk Score
			4	4	16 (Moderate)	1	4 (Very Low) ALARP

Appendix B - Internal Assessment for Non-network Alternatives

Internal Assessment Report
Non-network Alternatives
Pittsworth Regional Reinforcement WR 1266675

Non Network Alternatives (NNA)

BROXBURN SUBSTATION (BROX) 33/11kV

CI has assessed the potential demand management options required to defer the identified BROX network option and determine if there is a viable non network option to replace or reduce the need for the proposed Network option. CI has reviewed the customer base and considered a number of demand management technologies based on the primary project driver of augmentation to meet a growth forecast to exceed the emergency cyclic capacity by 2022. It is unclear that demand management could assist in any way with addressing the secondary project driver of aged asset replacement. The DM goal would be to extend the life of the transformers by de-loading them at peak times.

There are 2131 residential customers and 581 business customers connected to BROX (refer Figure 1.) 36 business customers are classified as Large, 8 of these sites have significant (> 200 kVA) maximum demand.




Figure 1
Residential

Residential customers appear to drive the daily peak of demand which occurs between 4.00pm-7.30 pm, (Figure 2) the summer period producing the highest yearly demand. BROX has 1599 customers on tariff T31 and T33 hot water load control (LC); the estimated demand reduction value of which is 959 kVA+. Broxburn substation LC signals are controlled from Yarranlea BSP 110/33 kV substation. The Tariff 33 and 31 Hot water LC channels are dynamic (i.e. respond to exceedance settings not on a timetable) currently LC is scheduled to activate when the BSP exceeds 23.5 MVA; this strategy does not directly address peaks experienced at BROX. Tariff 33 Air-conditioning channels are under manual control of the control room and used as required.

+ Hot water diversified demand saving estimated at 0.6kVA per system

Internal Assessment Report
Non-network Alternatives
Pittsworth Regional Reinforcement WR 1268675




Figure 2
Business



Figure 3

Further analysis of the business customers (seen in Figure 3) shows that 4 of the 8 highest consumption sites have maximum demands of 860 kVA, 674 kVA, 285 kVA, and 65 kVA respectively for a total demand of 1.88MVA. Other notable demands are 355 kVA, 260kVA and 320 kVA. New connection with a demand of 1.5MVA is forecast in 2019 and 2MVA in 2021.

Solar

665 business and residential customers have solar PV systems with a connected kW capacity of 2198 kW's. Pittsworth, Linthorpe, Southbrook and Springside Feeders are registered as at risk of experiencing reverse power flows*.

* Using the total installed capacity of Micro EG Units (with 20% diversity) and Estimated Light Load (20% of Daily Maximum Demand) a rough estimate can be made as to whether generation will exceed the consumption on a feeder.

Demand management – BROX

The customer base has a significant industrial and commercial presence interspersed with small business and residential customers. There is opportunity for demand savings in all these customer market segments. The most cost effective demand reduction measure for the residential market in a short timeframe could be increased utilisation of the existing LC measure (which is currently around 959 kVA) on customers by Ergon to de-load BROX.

The large amount of customer solar PV (2198 kW) adds potential for a BESS offering in future.

Commercial incentives for lighting and power factor could be offered for demand reductions but would take a longer term to be realised.

Demand response – BROX

Demand response through customer embedded generation, call off load and load curtailment contracts has been assessed as technically viable as there is significant business customer opportunity with the top existing 7 customer sites. They have significant diesel generation assets and have previously indicated their interest in entering into commercial arrangements for this generation. If the new connection of 1.5MVA is included to the current total demand, the demand reduction would be 3.3MVA.

Other DR opportunities may exist with sites with > 200 kVA maximum demand sites at the Hospital etc.

Summary - BROX

- 665 customers have 2198 kW's PV on the Network
- 4 feeders registered as at risk of experiencing reverse power flows*.
- 959 kVA (est.) of potential T31 and T33 hot water load control.
- Peak demand occurs in summer 4 pm to 7.30 pm driven by residential market
- Significant Industrial and commercial business customers with > 200kVA and existing diesel generation available
- The new connection is willing to enter into NSA for diesel generation

Conclusion

Based on the demand management options considered above, it is deemed that sufficient demand management measures could be feasibly implemented to contribute to technically and economically deferring the network investment required at BROX. Particularly as the primary investment drivers are augmentation triggered by growth with aged asset replacement, reliability, environmental risk, safety and standards compliance listed as secondary drivers.

CI believes there could be financial benefits from seeking expressions of interest from the market for a Non Network Alternative to proposed Network investment suggested in the Planning Report.

Appendix C – Ergon Energy’s Minimum Service Standards and Safety Net Targets

The legislated System Average Interruption Duration Index (SAIDI) and System Average Interruption Frequency Index (SAIFI) limits from Ergon Energy’s Distribution Authority are detailed in Table 5.

Table 5: SAIDI (minutes per customer) and SAIFI (interruptions per customer) limits


Feeder Category	SAIDI MSS Limits	SAIFI MSS Limits
Urban	149	1.98
Short Rural	424	3.95
Long Rural	964	7.40

The legislated Safety Net Targets from Ergon Energy’s Distribution Authority are provided in Table 6. Broxburn is classified a ‘Rural Area’.

Table 6: Ergon Energy Safety Net Targets

Area	Targets (for restoration of supply following an N-1 Event)
Regional Centre	<p>Following an N-1 event, load not supplied must be:</p> <ul style="list-style-type: none"> ○ Less than 20 MVA after 1 hour; ○ Less than 15 MVA after 6 hours; ○ Less than 5 MVA after 12 hours; and ○ Fully restored within 24 hours.
Rural Areas	<p>Following an N-1 event, load not supplied must be:</p> <ul style="list-style-type: none"> ○ Less than 20 MVA after 1 hour; ○ Less than 15 MVA after 8 hours; ○ Less than 5 MVA after 18 hours; and ○ Fully restored within 48 hours.
<p>Note: All modelling and analysis will be benchmarked against 50 POE loads and based on credible contingencies.</p> <p>‘Regional Centre’ relates to larger centres with predominantly urban feeders.</p> <p>‘Rural Areas’ relates to areas that are not Regional Centres.</p>	

Appendix D – The RIT-D Process



Appendix E - Glossary of Terms

Abbreviation	Description
ACP	Approved Cost Plan
BROX	Broxburn substation 33/11kV
CBRM	Condition Based Risk Management
CEPL	Cecil Plains substation 33/11kV
CI	Customer Interactions team (currently DEM)
DEM	Demand and Energy Management
ECC	Emergency cyclic capacity
MILM	Millmerran substation 33/11kV
N-1 ECC	Capacity available when the largest transformer fails
NCC	Normal cyclic capacity
NORW	Norwin substation 33/11kV
ONAN	Oil Natural Air Natural
PAMP	Pampas substation 33/11kV
RIT-D	Regulatory Investment Test for Distribution
SLD	Single line diagram
YARA T10	Yarranlea (T10) 110/33kV bulk supply point
YOM	Year of manufacture
ZS	Zone Substation (or simply substation)