



**Ergon Energy Network
Register of completed distribution connected
resource projects
1 July 2020 to 30 June 2025**

Contents

1.	Introduction	3
2.	Purpose of this Register	3
3.	Details to be included in the register	3
4.	More Information	3
5.	Register of completed distribution connected resource projects	4
6.	Single Line Diagram Types	10
7.	Protection Schemes and Requirements	14
8.	PQ Voltage and Power Factor Control.....	14
9.	Fault Level Contribution Factor	15

1. Introduction

This register provides a record of completed distribution connected resource projects that are connected to the distribution network and owned, operated, or controlled by Ergon Energy Network. It has been developed to improve access to technical information on projects that have been successfully integrated into the network.

2. Purpose of this Register

Under the NER, Ergon Energy Network is required to publish a register of completed distribution connected resource projects. This register must:

- include in the register the details contained in paragraph (b) for all completed distribution connected resource projects within the 5 year period preceding the establishment of the register; and
- update the register by the DAPR date each year thereafter with details of all completed distribution connected resource projects in the 5 year period preceding the DAPR date.

3. Details to be included in the register

A register of completed distribution connected resource projects includes, but is not limited to:

- technology of distribution connected unit (e.g. synchronous generating unit, induction generator, photovoltaic array, etc) and it's make and model;
- maximum generating capacity of all distribution connected units comprised in the system;
- contribution to fault levels;
- the size and rating of the relevant transformer;
- a single line diagram of the connection arrangement;
- protection systems and communication systems;
- voltage control and reactive power capability; and
- details specific to the location of a facility connected to the network that are relevant to any of the details in the bullet points above.

4. More Information

For more information around connecting a large Distribution Energy Resource (DER) system, please refer to the following web pages:

- **For High Voltage DER systems:** [Large high voltage DER systems | Ergon Network](#) , or
- **For Low Voltage DER systems:** [Solar connections & other technologies | Ergon Network](#)

Alternatively, you can refer to [Large customer connections support | Ergon Network](#).

5. Register of completed distribution connected resource projects

Year Completed = Connected	Location	Technology of each distribution connected unit	Network Connection Voltage (kV)	System details (Make and Model)	Generator Voltage Level (kV)	maximum power generation capacity of all distribution connected units comprised in the system (kW)	Contribution to fault levels (kA) at connection point	The size and rating of the relevant transformer (Voltages & kVA)	A single line diagram of the connection arrangement	Protection systems and communication systems	Voltage control, power factor control and/or reactive power capability	Details specific to the location of a facility connected to the network, that are relevant to any of the details.
2020/21	West Gladstone	Solar PV	LV	ECO 27.0-3-S, ECO 25.0-3-S, SYMO 20.0-3-M, SYMO 17.0-3-M	LV	224	0.39	315kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var	Partial Export
2020/21	Earlville	Solar PV	LV	3 x SolarEdge SE82.8kW	LV	248.4	0.43	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var	Non-Export
2020/21	Cannonvale	Solar PV	LV	2 x Sungrow SG110CX	LV	220	0.38	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Bayview Heights	Solar PV	LV	2 x Huawei SUN2000-50KTL-Mo	LV	210	0.36	500kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2020/21	Kingaroy	Solar PV	LV	5 x SMA Sunny Tripower Core 1 STP 50-40	LV	250	0.43	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2020/21	Smithfield	Solar PV	LV	SMA STP 25000TL, SMA STP 15000TL x 2, SMA STP 20000TL, SMA STP 10000TL	LV	333	0.58	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Edmonton	Solar PV	LV	Solar Edge 27.6K Inverters	LV	303	0.52	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2020/21	Garbutt	Solar PV	LV	9 x SE27.6K	LV	248	0.43	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Bundaberg	Solar PV and Battery	LV	26 x Fronius ECO 25.0-3-S, Tesla Powerpack 2.5	LV	940	1.63	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2020/21	Mackay	Solar PV	LV	Sungrow Power Supply SG110CX x 2	LV	220	0.38	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Thuringowa	Solar PV	11kV	ABB PVS-50-TL – S x 5	LV	650	0.04	1MVA + 1.5MVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2020/21	Woree	Solar PV	22kV	SMA STP 15000TL, SMA STP 25000TL x 2, SMA STP 10000TL, SolarEdge SE82.8kW x 4	LV	496	0.02	2x 1.5MVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Rockhampton	Solar PV	LV	Sungrow SG110CX x 3 & SG50CX	LV	380	0.66	1500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2020/21	Kingaroy	Synchronous EG	LV	Perkins 4012-46TAG0A with Stamford P1734F	LV	1250	12.63	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Fixed power factor	Non-Export
2020/21	Edmonton	Solar PV	LV	SolarEdge 2 x SE82.2K, 1x SE50K	LV	225	0.39	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Garbutt	Solar PV	LV	15 x SolarEdge SE27.6K	LV	414	0.72	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Parkhurst	Solar PV	LV	4 x SMA SHP75-10	LV	300	0.52	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Highfields	Solar PV	LV	3 x SMA SHP5-10	LV	225	0.39	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2020/21	Railway Estate	Solar PV	LV	2 x Sungrow SG110CX	LV	220	0.38	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2020/21	Bowen	Solar PV	LV	4 x SMA SHP75-10	LV	300	0.52	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export

Register of completed distribution connected resource projects - July 2020 to June 2025

Year Completed = Connected	Location	Technology of each distribution connected unit	Network Connection Voltage (kV)	System details (Make and Model)	Generator Voltage Level (kV)	maximum power generation capacity of all distribution connected units comprised in the system (kw)	Contribution to fault levels (kA) at connection point	The size and rating of the relevant transformer (Voltages & kVA)	A single line diagram of the connection arrangement	Protection systems and communication systems	Voltage control, power factor control and/or reactive power capability	Details specific to the location of a facility connected to the network, that are relevant to any of the details.
2020/21	Maryborough	Solar PV	LV	2x SolarEdge SE82.8K + 2x SMA STP20000TL-30	LV	205	0.36	315kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2021/22	Townsville	Solar PV	LV	SolarEdge SE50K x 1 + SE25K x 1 + SE8K x 2	LV	291	0.46	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	Maryborough	Solar PV	LV	2x SMA STP 110-60	LV	220	0.35	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2021/22	Heatley	Solar PV	LV	3x SolarEdge 82.8kVA Inverter	LV	248	0.39	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	Bentley Park	Solar PV	LV	SolarEdge SE82.8K-AU0P0BNU4, SE50K-AU0P0BNU4, SE30K-AU00IBNV4	LV	378	0.60	500kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	Gunyarra	Solar PV	LV	4x SolarEdge SE82.8K	LV	331	0.53	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2021/22	Manunda	Solar PV	LV	SolarEdge SE82.8K-AU0P0BNU4, SE50K-AU0P0BNU4, SE27.6KAU000BNU4, SE17K-AU0T0BNU4	LV	487	0.77	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	Proserpine	Solar PV	LV	Fronius Aust + SolarEdge Tech + Selectronic Aust Model: ECO 27.0-3-S x 4 + SE50K x 1 + SPMC482-AU x 3, ABB Trio 27.6-TL x 3 + PVI-12.5-TL x 1	LV	253	0.40	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2021/22	Chinchilla	Synchronous Machine	LV	Cummins C275 D5	LV	220	2.22	315kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2021/22	Annandale	Battery	LV	Tesla Powerpack	LV	232	0.37	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2021/22	Annandale	Solar PV	LV	SMA STP15000TL-30 x 2 + STP20000TL-30 x 2 + STP25000TL-30 x 1, STP20000TL-30 x 11 + STP25000TL-30 x 8	LV	515	0.82	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2021/22	Bohle	Solar PV	LV	SMA Sunny Tripower Core2 x 6, Sunny Tripower Core2 x 3	LV	990	1.57	2 x 750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2021/22	Annandale	Solar PV	LV	Sungrow Power SG50CX x 4 + SG30CX x 5 + SG5K-D x 5	LV	374	0.59	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	West Mackay	Solar PV	LV	Huawei Technologies SUN2000-50KTL-M0 x 4	LV	220	0.35	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2021/22	Cairns	Solar PV	LV	SolarEdge SE82.8K-AU0P0BNU4 x4	LV	391	0.62	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	Alloway	Solar PV	LV	ABB TRIO-20.0 x2 + TRIO-27.6 x8, (ABB) Power-One PVS-100-TL x2	LV	460	0.73	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2021/22	Gladstone	Solar PV	LV	SolarEdge SE82.8K-AU0P0BNU4 x2	LV	248	0.39	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	Deeragun	Solar PV and Battery	LV	SMA STP15000TL-30 x 11 + STP20000TL-30 x 4 + STP25000TL-30 x 3, STP50-60 x 1, Tesla Powerpack	LV	544	0.86	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2021/22	Kirwan	Solar PV	LV	SMA STP25000TL-30 x 6 + STP2000TL-30 x 5 + STP15000TL-30 x 5 + STP 50-40 x 6, Tesla Power Pack	LV	973	1.54	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	Chinchilla	Solar PV	LV	Sungrow SG110CX x 2	LV	220	0.35	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2021/22	Redlynch	Solar PV	LV	SolarEdge SE82.8K-AU00IBNV4 x4	LV	348	0.55	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export

Register of completed distribution connected resource projects - July 2020 to June 2025

Year Completed = Connected	Location	Technology of each distribution connected unit	Network Connection Voltage (kV)	System details (Make and Model)	Generator Voltage Level (kV)	maximum power generation capacity of all distribution connected units comprised in the system (kw)	Contribution to fault levels (kA) at connection point	The size and rating of the relevant transformer (Voltages & kVA)	A single line diagram of the connection arrangement	Protection systems and communication systems	Voltage control, power factor control and/or reactive power capability	Details specific to the location of a facility connected to the network, that are relevant to any of the details.
2021/22	Yeppoon	Solar PV	LV	Sungrow SG50CX x 5	LV	250	0.40	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2021/22	Yeppoon	Battery	LV	Sungrow SC50HV x 5	LV	250	0.40	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2021/22	Yeppoon	Solar PV and Battery	LV	Sungrow Power SC50HV x 3, SG110CX x 2	LV	370	0.59	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Yeppoon	Solar PV	LV	SolarEdge SE82.8K, 2xSE66.6K	LV	216	0.31	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2022/23	Burnett Heads	Solar PV	LV	ABB UNO-DM-5.0TL Plus x 100	LV	500	0.72	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Deeragun	Solar PV and Battery	LV	SMA STP15000TL30x4, STP20000TLx4, STP25000TLx5, Tesla Powerpack	LV	265	0.38	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Cranbrook	Solar PV and Battery	LV	SMA STP20000TL30x7, STP15000TL30x2, STP25000TL30x7, Tesla Powerpack	LV	345	0.50	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Burdell	Solar PV and Battery	LV	Various SMA and ABB, Tesla Powerpack	LV	431	0.62	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Hyde Park	Solar PV and Battery	LV	SMA STP15000TL30x2, STP20000TLx5, STP25000TLx4, Tesla Powerpack	LV	230	0.33	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2022/23	Martyville	Solar PV	LV	Sungrow SG110CXx3	LV	330	0.48	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Innisfail	Solar PV	LV	SolarEdge82.8K, SE25K	LV	381	0.55	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2022/23	Mundubbera	Solar PV	LV	Sungrow SG110CX x2	LV	220	0.32	315kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Currajong	Solar PV	LV	ABB PVS100TL, ABB TRIO50.0TL, Sungrow SG110CXx2	LV	370	0.53	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	North Rockhampton	Solar PV	LV	SolarEdge SE82.8K, SE66K	LV	232	0.33	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2022/23	Ayr	Solar PV and Battery	LV	Various SMA inverters, Tesla Powerpack	LV	225	0.32	315kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Mackay	Solar PV	LV	Solar Edge 66.6K, SE82.8K	LV	232	0.33	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2022/23	Urangan	Solar PV	LV	Sungrow SG110CX x 2	LV	220	0.32	315kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Tully	Synchronous Machine	22kV	SIEMENS, 1DU2049-8AE0	11	18000	3.31	12.5MVA 22/11kV	As per Figure 3	As per Figure 5	Reactive power control	Non-Export
2022/23	Tully	Synchronous Machine	22kV	Leroy Somer, SR4BHV	6.6	1600	0.29	2MVA 11/6.6kV	As per Figure 3	As per Figure 5	Reactive power control	Non-Export
2022/23	Bargara	Solar PV	LV	SMA STP110-60x2, Sungrow SG50CX	LV	270	0.39	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Dulacca	Wind	132kV	Vestas Wind turbine, V150	33kV	173000	1	2x 132/33kV 125MVA	As per Figure 2	As per Figure 5	Voltage control	Full Export

Register of completed distribution connected resource projects - July 2020 to June 2025

Year Completed = Connected	Location	Technology of each distribution connected unit	Network Connection Voltage (kV)	System details (Make and Model)	Generator Voltage Level (kV)	maximum power generation capacity of all distribution connected units comprised in the system (kw)	Contribution to fault levels (kA) at connection point	The size and rating of the relevant transformer (Voltages & kVA)	A single line diagram of the connection arrangement	Protection systems and communication systems	Voltage control, power factor control and/or reactive power capability	Details specific to the location of a facility connected to the network, that are relevant to any of the details.
2022/23	Rockhampton	Solar PV	LV	SMA STP110-60 x2	LV	220	0.32	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Tinana	Solar PV	LV	Sungrow SG110CX x2	LV	220	0.32	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2022/23	Rasmussen	Solar PV	LV	Sungrow SG110CX x3	LV	330	0.48	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2022/23	Pialba	Solar PV	LV	Sungow SG110CX x4	LV	440	0.64	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2023/24	Gordonvale	Solar PV	LV	Sungrow SC 110CX	LV	220	0.32	1000kVA 22/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Full Export
2023/24	Kearney Springs	Solar PV	LV	Fronius Australia Eco 25.0-3-S, Fronius Australia Eco 27.0-3-S	LV	208	0.30	1000kVA 11/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Full Export
2023/24	Pialba	Solar PV	LV	Sungrow SG110CX	LV	220	0.32	1000kVA 11/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Full Export
2023/24	Ayr	Synchronous Machine	LV	Caterpilla C13 DE400E0	LV	400	0.58	500kVA 11/0.433kV	As per Figure 6	As per figure 7	Fixed power factor	Non-Export
2023/24	Yeppoon	Solar	LV	Sungrow SG110CX	LV	220	0.32	750kVA 11/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Full Export
2023/24	Annandale	Solar	LV	Sungrow SG110CX	LV	550	0.79	1500kVA 11/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Partial Export
2023/24	Charters Towers	Solar PV and Battery	LV	Fronius Australia Eco 100-3-P, Fronius Australia Symo 15.0-3-M, Sungrow SC50HV, SMA Australia STP 25000TL, SMA Australia STO 20000TL	LV	550	0.79	500kVA 11/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Partial Export
2023/24	Mareeba	Solar	LV	Fronius Australia Eco 100-3-D, Fronius Australia Symo 15 0-3-M	LV	215	0.31	1000kVA 11/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Full Export
2023/24	Ayr	Solar	LV	Sungrow SG110CX	LV	220	0.32	1000kVA 11/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Full Export
2023/24	Garbutt	Solar	LV	Sungrow SG110CX, Sungrow SG50CX	LV	210	0.30	1000kVA 11/0.433kV	As per Figure 6	As per figure 7	Volt-var and volt-watt	Full Export
2023/24	ARRIGA	Synchronous Machine	66kV	Shinko 7MW unit	11	31000	44.74	20000kVA66/11kV	As per Figure 3	As per figure 5	Voltage Control	Partial Export
2023/24	ARRIGA	Synchronous Machine	66kV	Perkins 4016-61TRG3	11	2000	2.89	20000kVA66/11kV	As per Figure 3	As per figure 5	Fixed power factor	Partial Export
2023/24	Toowoomba	Solar	11kV	SungrowCG110CX	LV	1430	2.06	2x1500kVA 11/0.433kV	As per Figure 3	As per Figure 5	Volt-var and volt-watt	Full Export
2023/24	Paget	Solar	LV	Solaredge Technologies SE82.8K	LV	82.8	0.12	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2023/24	Mount Louisa	Solar	LV	Fronius Symo 20.0-3-M	LV	80	0.12	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2023/24	Smithfield	Solar	LV	Solar edge (SE27.6K, SE25K, SE10K-AUS), Sungrow SG110CX, Delta Electronics PCS100HV	LV	300.2	0.43	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2023/24	Mossman	Solar	LV	Sungrow SG110CX	LV	330	0.48	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export

Register of completed distribution connected resource projects - July 2020 to June 2025


Year Completed = Connected	Location	Technology of each distribution connected unit	Network Connection Voltage (kV)	System details (Make and Model)	Generator Voltage Level (kV)	maximum power generation capacity of all distribution connected units comprised in the system (kw)	Contribution to fault levels (kA) at connection point	The size and rating of the relevant transformer (Voltages & kVA)	A single line diagram of the connection arrangement	Protection systems and communication systems	Voltage control, power factor control and/or reactive power capability	Details specific to the location of a facility connected to the network, that are relevant to any of the details.
2023/24	Hewitt	Solar	LV	Sungrow SG110CX	LV	220	0.32	315kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2023/24	Yarwun	Solar	LV	Solaredge Technologies SE82.8K	LV	331.2	0.48	1500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2023/24	Parkhurst	Solar	LV	Sungrow SG110CX, Sungrow SG50CX	LV	270	0.39	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2023/24	Svensson Heights	Solar	LV	Solaredge SE30K, Sungrow CG110CX, Sungrow CG50CX	LV	250	0.36	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2023/24	ACACIA RIDGE	Solar	LV	Sungrow CG110CX	LV	330	0.48	1500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2023/24	ANNANDALE	Solar	LV	ABB Trio-27.6-TL, SMA Australia STP 110-60	LV	275.2	0.40	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2023/24	ELI WATERS	Solar	LV	Sungrow CG110CX	LV	220	0.32	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2023/24	Bundaberg	Solar	LV	Sungrow SG110CX	LV	440	0.64	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	St George	Synchronous Machine and Solar	LV	Viking T-HAWK300-C, Fronius ECO 25.0-3-S	LV	350	3.54	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Fixed power factor / Volt-var and volt-watt	Partial Export
2024/25	Toowoomba	Solar	LV	SMA Australia STP 110-60	LV	220	0.38	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Mt Isa City	Solar	LV	Sungrow SG110CX	LV	380	0.66	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Maryborough West	Solar	LV	Sungrow SG110CX	LV	330	0.57	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Ingham	Solar	LV	Sungrow SG110CX	LV	220	0.38	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	North Rockhampton	Solar	LV	SMA Australia STP 110-60	LV	330	0.57	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Bargara	Solar	LV	Sungrow SG3K-S, Sungrow SG20RT	LV	460	0.80	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export
2024/25	North Rockhampton	Solar	11kV	Sungrow SG50CX, SG30CX, SG2RT	11kV	619.9	0.04	11kV RMU	As per Figure 2	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	North Rockhampton	Solar	11kV	Sungrow100CX	11kV	880	0.06	11kV RMU	As per Figure 2	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Injune	Solar	LV	Power-One Italy PVS-100-TL, Fronius Tauro Eco 50-3-D	LV	250	0.43	1000kVA 33/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Lakeland	Solar	LV	Sungrow SG110CX	LV	330	0.57	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Thuringowa	Solar	LV	Sungrow SG110CX	LV	220	0.38	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Thuringowa	Solar	LV	Sungrow SG110CX	LV	110	0.19	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Non-Export

Register of completed distribution connected resource projects - July 2020 to June 2025

Year Completed = Connected	Location	Technology of each distribution connected unit	Network Connection Voltage (kV)	System details (Make and Model)	Generator Voltage Level (kV)	maximum power generation capacity of all distribution connected units comprised in the system (kw)	Contribution to fault levels (kA) at connection point	The size and rating of the relevant transformer (Voltages & kVA)	A single line diagram of the connection arrangement	Protection systems and communication systems	Voltage control, power factor control and/or reactive power capability	Details specific to the location of a facility connected to the network, that are relevant to any of the details.
2024/25	Kalkie	Solar and Battery	LV	Solaredge SE15K, SE17K, SE27.6K, SE82.8K, SE66.6K, Sungrow samsuncg SC100 BESS	LV	544.2	0.94	500kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Cairns	Solar	LV	Sungrow SG110CX, SG20RT	LV	240	0.42	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Westcourt	Solar	LV	ENPHASE ENERGY IQ7A-72-2-INT	LV	517.567	0.90	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Glenvale	Solar	LV	Goodwe GW2000-NS, GW2000-XS, Sungrow SG2K-S, SG2KTL-S, SG3KTL-D, SG5KTL-D	LV	236	0.41	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Dalby	Solar	LV	SolarEdge SE27.6, SE100K	LV	282.8	0.49	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Urangan	Solar	LV	Sungrow SG110CX	LV	220	0.38	750kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Harlaxton	Solar and Synchronous Machine	LV	Fronius Symo 15.0-3-M, Caterpillar C13	LV	480	0.83	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Fixed power factor / Volt-var and volt-watt	Non-Export
2024/25	Westcourt	Solar	LV	Sungrow SG110CX	LV	270	0.47	500kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Emerald	Solar	LV	Sungrow SG110CX	LV	220	0.38	500kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Bowen	Solar	LV	Sungrow SG110CX, SG50CX, SG30CX, SG50HV	LV	479.8	0.83	2x 315kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Emerald	Solar	LV	Sungrow SG110CX	LV	330	0.57	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Avoca	Solar	LV	Sungrow SG110CX	LV	220	0.38	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Cairns	Solar	LV	GoodWe Technologies GW110KT-HT	LV	440	0.76	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Annandale	Solar	LV	Sungrow SG50CX, SG30CX	LV	374	0.65	1000kVA 11/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Partial Export
2024/25	Port Douglas	Solar	LV	Sungrow SG50CX, SG30CX	LV	378	0.65	1000kVA 22/0.433kV	As per Figure 6	As per Figure 7	Volt-var and volt-watt	Full Export
2024/25	Blackwater	Synchronous Machine	LV	Caterpillar C9 Diesel Generator	LV	300	3.03	500kVA 22/0.433kV	As per Figure 6	As per Figure 7	Fixed power factor	Non-Export

6. Single Line Diagram Types


Figure 1: HV DER System Connected to Subtransmission via T-Off Connection



NOTES

- ☐ The DNSP shall own the T-substation primary and secondary plant for all Large Customer types.
- ☐ Addition of generation may increase protection and communications requirements.
- ☐ Installations with more than 1.5 MVA DER system capacity shall have a grid disconnection device and a grid isolation device installed as per 4.6.1. Consideration should be given to long-term site needs to avoid costly retrofits.

Figure 2: HV DER System Connected to Sub transmission via Switching Station




NOTES

- ☐ The DNSP shall own the switching substation.
- ☐ This arrangement is used to cut into radial lines where power flows are uni-directional.
- ☐ This arrangement would be required based on the Large Customers' need for high reliability (compared to T-substation or 3 bay tee), etc.

Register of completed DER System Projects > 200 kW July 2020 to June 2025


Figure 3: HV Connected DER System Via Direct Feed From Substation



NOTES

- **Arrangement 1** shows a Large Customer owned feeder. Protection scheme elements at customers end can be either Large Customer or DNSP owned.
- **Arrangement 2** shows a DNSP owned feeder. Secondary protection scheme elements (protection relays and associated communications equipment) at Large Customers end shall be owned by the DNSP. Other elements of the Protection Scheme (circuit breakers, CT, VT, DC supplies, etc.) can be either Large Customer or DNSP.

Figure 4: HV DER System Connected via T-Off from Distribution Feeder



NOTES

- DER Systems requiring NVD protection shall require a HV VT measurement used by a DNSP relay to trip the Customer disconnection device. This design is currently not available in Energex Distribution Network.
- Installations with more than 1.5 MVA DER system capacity shall have a GDD installed. Consideration shall be given to have space provision for a GDD with long-term site needs.

Register of completed DER System Projects > 200 kW July 2020 to June 2025

Figure 5: Dual Communications for DER Systems >5MW





Figure 6: Single Line – LV Connected DER System



LOW VOLTAGE DER SYSTEMS AND DEDICATED LOW VOLTAGE CONNECTION

Low voltage DER system with parallel low voltage load – Dedicated low voltage connection – Shared HV feeder

Register of completed DER System Projects > 200 kW

July 2020 to June 2025

Figure 7: Protection Requirements for LV Connected DER System





Figure 8: Protection for HV DER Systems <5MVA



7. Protection Schemes and Requirements

Level 1 Backup Protection

- Over and under voltage
- Over and under frequency
- Voltage vector shift and
- Rate of change of frequency
- Reverse Power

Level 2 Backup Protection

- Neutral voltage detection/unbalance, or
- Direct intertrip from network circuit breaker (for systems above 200kW).

Protection Function	Shared LV Circuit Nil-Export	Dedicated LV Circuit Nil-Export	Dedicated Transformer Up to 200kW Nil Export	Dedicated Transformer Up to 200kW Export	Dedicated Transformer 200<x<1000kW Nil-Export	Dedicated Transformer 200<x<1000kW Export	Dedicated Transformer(s) Greater than 1000kW Export/Nil export
Over/under voltage	✓	✓	✓	✓	✓	✓	✓
Over/under frequency	✓	✓	✓	✓	✓	✓	✓
Voltage vector shift					✓	✓	✓
Rate of change of frequency					✓	✓	✓
Reverse Power	✓	✓	✓	✓	✓	✓	✓
Neutral voltage displacement ²					✓	✓	✓
Direct Intertrip							✓
CADA link							✓

8. PQ Voltage and Power Factor Control

Ergon Energy Network has published connection standards that apply to all new and upgraded Distributed Energy Resource (DER) systems. These standards ensure compliance with technical and regulatory requirements. Applicable Standards: STNW1174, STNW3511, STNW1175.

For low voltage customers, under Electricity Regulation clause 36(2)(d), customers must ensure that inverters operate in accordance with Volt-Var and Volt-Watt settings specified in STNW1174 or STNW3511.

For high voltage customers, Power factor must reflect the agreed voltage or power factor control arrangement. Connections must comply with STNW1175 requirements.

All standards and supporting documents are available on the Ergon Energy Network website under: [Standards, manuals & fact sheets | Ergon Energy](#).

Register of completed DER System Projects > 200 kW July 2020 to June 2025

9. Fault Level Contribution Factor

Indicative fault level contribution from DER Systems:

Type	Fault level contribution factor
Synchronous distribution connected unit	7 X Rating
Solar/Inverter distribution connected unit	1.2 X Rating

Note: It is assumed that bumpless systems do not contribute to fault levels.