

Standards Alert

Part of the Energy Queensland Group

Quarantine of 11kV 1500kVA Padmount Substation (2461473)		Control Ref No: StdsA493
		Date Issued: 12/07/2019
		Supersedes: N/A
For Policy/Procedure/Manual: Ergon UG Construction Manual Issue 13	Expiry Date: 12/01/2020	
Originating Dept: Asset Standards – Line Standards		
Target Audience: Northern & Southern		

1. Objective

This Standards Alert is to advise that the following padmount substation has been quarantined and is not to be used until further notice.

- 11kV 1500kVA Padmount Substation.

2. Introduction

The 11kV 1500kVA Padmount Substation S/C 2461473 (PM11/1500/8DJH2S1CB, Assembly 614-7) is not to be used.

It has been identified that Test and Commissioning procedures have not been developed for the HV protection relay and the LV circuit breaker. The lack of procedures is causing delays in energising jobs, so the decision has been made to quarantine this product while this is addressed.

3. Design and Construction - Advise

Please notify Line Standards, via the contact details below of any projects / jobs which involve the 11kV 1500kVA padmount substation which are in the following phases:

- Offers which include the 1500 kVA padmount substation (accepted or otherwise)
- Design
- Construction

4. Further Information

For further information, please contact

Adam Bletchly, Phone Number 07 4931 2783, email adam.bletchly@energyq.com.au