



Because of these changes previous Energex 2 legged structure (drawing LOSTD-ST033-05) will not be suitable for use with PLP items on the new contract. PLP are planning to provide adaptor plates and brackets should we need to retrofit a new contract item to an existing structure if required, contact Substation Standards if further information required.

North/South: Separate stock codes have been created for the disconnecter heads, earth switches and support structures.

#### 4. Further Information

For further information, please contact Shaun Ferguson, 07 3851 6715, [shaun.ferguson@energyq.com.au](mailto:shaun.ferguson@energyq.com.au)

<i>Page: 2 of 2</i>	<i>This Technical Instruction will remain in force until either the expiry date is exceeded or update of the relevant sections of the specified manuals has occurred. tsd0204b - substation disconnectors</i>	<i>Dept Head J Lansley</i>
-------------------------	---	--------------------------------